



1. (35 points) An open-loop transfer function is given by,

$$G(s) = \frac{1}{s^3 + 2.0s^2 + 3.03534s + 7.03534}$$


Which of the following PI controllers stabilizes the system in a unit-feedback closed-loop configuration?

- A.  $F(s) = -9.78789 + \frac{2.5707}{s}$
- B.  $F(s) = 0.6414 + \frac{2.5707}{s}$
- C.  $F(s) = -2.5707 + \frac{0.53534}{s}$
- D.  $F(s) = 0.71211 + \frac{1.0707}{s}$
- E.  $F(s) = -9.8586 + \frac{1.0707}{s}$

2. (35 points) Which one of the following unit impulse responses corresponds to a system that does not overshoot when subjected to a unit step input?




3. (30 points) A design point on the root-locus plot for a P-type controller is shown below.




A zero is added so that the root-locus passes through this design point. Which of the following represents the correct angle condition for this design?


$$\sum \theta = 115.0^\circ + 97.0^\circ - 32.0^\circ =$$




$$\sum \theta = 65.0^\circ + 97.0^\circ + 32.0^\circ =$$



$$\sum \theta = 115.0^\circ + 83.0^\circ + 32.0^\circ =$$



$$\sum \theta = 115.0^\circ + 97.0^\circ + 32.0^\circ =$$



$$\sum \theta = 115.0^\circ + 97.0^\circ + 148.0^\circ =$$

