

1. (100 points) An open-loop transfer function is given as,

$$G(s) = \frac{1}{s^3 + 2.0s^2 + 3.22221s + 4.44444}$$

which of the following PI-controllers stabilizes the system in a closed-loop unit feedback structure?

A.  $F(s) = -0.8889 + \frac{2.22221}{s}$

**B.**  $F(s) = -2.6111 + \frac{0.27777}{s}$

C.  $F(s) = 1.1111 + \frac{1.22221}{s}$

D.  $F(s) = -5.8889 + \frac{1.1111}{s}$

E.  $F(s) = -0.8889 + \frac{1.1111}{s}$

Q	A
1	B