

1. (35 points) An open-loop transfer function is given by,


$$G(s) = \frac{1}{s^3 + 2.0s^2 + 3.19696s + 7.19696}$$

Which of the following PI controllers stabilizes the system in a unit-feedback closed-loop configuration?


- A. $F(s) = -2.89394 + \frac{0.69696}{s}$
- B. $F(s) = 1.68181 + \frac{1.39394}{s}$
- C. $F(s) = -9.21213 + \frac{1.39394}{s}$
- D. $F(s) = 1.28787 + \frac{2.89394}{s}$
- E. $F(s) = -8.81819 + \frac{2.89394}{s}$

2. (35 points) Which one of the following unit impulse responses corresponds to a system that does not overshoot when subjected to a unit step input?


A.



B.




3. (30 points) A design point on the root-locus plot for a P-type controller is shown below.




A zero is added so that the root-locus passes through this design point. Which of the following represents the correct angle condition for this design?


$$\sum \theta = 115.9^\circ + 81.2^\circ + 34.7^\circ = 231.9^\circ$$




$$\sum \theta = 115.9^\circ + 98.8^\circ - 34.7^\circ = 180.0^\circ$$




$$\sum \theta = 115.9^\circ + 98.8^\circ + 145.3^\circ = 360.0^\circ$$



$$\sum \theta = 64.1^\circ + 98.8^\circ + 34.7^\circ = 197.5^\circ$$



$$\sum \theta = 115.9^\circ + 98.8^\circ + 34.7^\circ = 249.4^\circ$$



Q	A
1	A
2	A
3	B