

1. (35 points) An open-loop transfer function is given by,


$$G(s) = \frac{1}{s^3 + 2.0s^2 + 3.20706s + 7.20706}$$

Which of the following PI controllers stabilizes the system in a unit-feedback closed-loop configuration?


- A. $F(s) = -9.17172 + \frac{1.41414}{s}$
- B. $F(s) = -8.75758 + \frac{2.91414}{s}$
- C. $F(s) = -2.91414 + \frac{0.70706}{s}$
- D. $F(s) = 1.32828 + \frac{2.91414}{s}$
- E. $F(s) = 1.74242 + \frac{1.41414}{s}$

2. (35 points) Which one of the following unit impulse responses corresponds to a system that does not overshoot when subjected to a unit step input?


A.



B.




3. (30 points) A design point on the root-locus plot for a P-type controller is shown below.




A zero is added so that the root-locus passes through this design point. Which of the following represents the correct angle condition for this design?


$$\sum \theta = 64.0^\circ + 98.9^\circ + 34.9^\circ = 197.8^\circ$$




$$\sum \theta = 116.0^\circ + 98.9^\circ - 34.9^\circ = 180.0^\circ$$




$$\sum \theta = 116.0^\circ + 98.9^\circ + 34.9^\circ = 249.8^\circ$$



$$\sum \theta = 116.0^\circ + 81.1^\circ + 34.9^\circ = 232.0^\circ$$



$$\sum \theta = 116.0^\circ + 98.9^\circ + 145.1^\circ = 360.0^\circ$$



Q	A
1	C
2	B
3	B