

glasstech, inc.

Service Bulletin

Customer Service Department

TELEPHONE: 419-661-9000 FAX: 419-661-9639

INTERNET: <http://www.glasstech.com>

E-mail: service@glasstech.com

Hot Fan Cooling Water

Reference 032

It is vital to the longevity of the hot fans used on the Glasstech FCH and FCH2 furnaces that the cooling water is of sufficient clarity as to avoid any buildup of foreign material in the piping that could limit the water flow provided to the fans.

The following two excerpts provide the basic requirements for water clarity:

From the Glasstech in the Technical Information Manual concerning cooling water:

"A closed loop re-circulating water system may be used, however, the supply pressure must be sufficient to maintain flow rates against any back pressure in the system. It is highly recommended that a closed loop re-circulating water system be connected to a municipal water supply at all times, to maintain water level, and as an emergency back-up."

From the Glasstech in the Maintenance & Service Manual – Direct Drive Recirculating Hot Fans:

Once Through systems

In general, potable drinking water quality is adequate. Water must be free from sludge or foreign matter that will cause blockage in the cooling water passages and could cause damage to the fan and / or create a dangerous condition. Water should be pH neutral to minimize corrosive attack on water system materials and tendency to scale. Industrial grade general-purpose water may need to be treated to inhibit biological growth such as algae, slime or bacteria that might attack water system materials or block water passages.

Recirculating systems

Recirculating systems must meet these additional treatment requirements. Water must be treated with antifreeze (non alcohol based) if the water cooling system is exposed to freezing temperatures (0 degrees C, 32 degrees F) or less. Evaporative loss cooling towers must be drained periodically to prevent excessive concentration of dissolved solids that increase the tendency to scaling. Closed cooling systems need to be treated with chemical oxygen scavengers and corrosion inhibitors. De-mineralized or de-ionized water is not recommended for our cooling water systems. This water is aggressive and requires special attention to water treatment needs.

Use of Water Treatment Specialist

Because water quality varies throughout the world, Glasstech strongly recommends that you enlist the services of a local water treatment specialist to analyze your specific conditions and recommend a treatment program.

Consult the fan manufacturers specifications for additional cooling water requirements.
(Contact Glasstech if you cannot locate the manufacturers specifications.)