

Normal Operating Parameters	Parameter
PV Panel Grounding	Floating
Nominal Input Voltage Reference	MPPT
Nominal Power (Watts)	226730
Nominal Voltage Inverter (AC)	209 V
Inverter data Logging time interval (min)	5

Maximum - Minimum setpoints of inverters	Parameters
Inverer Maximum Current without temperature derating	400
Vac minimum voltage Disconnect (Volts)	188
Vac maximum voltage Disconnect (Volts)	230
Maximum Frequency Tripping (Hz)	61.8
Minimum Frequency Tripping (Hz)	58.2
Maximum Power (Watts)	249410
Frequency Based Power reduction system: Activation (Hz)	61
Frequency Based Power reduction system: Deactivation (Hz)	59
Frequency Based Power reduction system: Maximum reduction (Hz)	62.4
VAC_min_num_cycles (Instant Fault)	60
VAC_max_num_cycles (Instant Fault)	60
Ambient Temperature Reduction	78 °C
Max Temperature tripping	80 °C

Start-Stop parameters	Parameters
Fan Activation temperature set point	45 °C
Starting Inpute Voltage VDC	586
Stopping input Voltage VDC	528
Starting Vin Time (Sec)	60
Stopping Vin Time (Sec)	5