S07 | Utility P05 equipment layout


PARKING LEVEL

Isaak Meakin | 01 Oct 2026

Issue: v001 / training model


PURPOSE Establish a traceable four-item equipment layout before devices, connections and raceways.

01 PARKING PLAN



Utility P05 and door swing / user model

02 3D PLACEMENT



Section-boxed room / wall gear and floor transformer

03 EQUIPMENT REGISTER

Transcribed from the Revit equipment schedule; marks and level checked against the capture.

MARK	FAMILY	NOMINAL TYPE	PANEL NAME	LEVEL
P-480-1	Lighting and Appliance Panelboard - 480V MLO	125 A	P-480-1	Parking
TX-1	Dry Type Transformer - 480-208Y120 - NEMA Type 2	30 kVA	TX-1	Parking
P-208-1	Lighting and Appliance Panelboard - 208V MLO	100 A	P-208-1	Parking
DS-1	Disconnect Switches	480V - Fusible 60A	(blank)	Parking

MODEL CHECK Four unique marks; plan and 3D show no visible overlap; door swing appears clear.

OPEN CHECK Exact working space, mounting, circuit relationships, protection and ratings require design review.

SIMULATED TRAINING LAYOUT - Not a construction or code-approved electrical design.