



**NOTE A**

The Wiedmuller 24VDC supplies the PLC Bus which in turn supplies 24VDC to the EL3255 modules and these modules will then output 10VDC supply to the feedback pots.

**IWCO**  
**PCU Replacement Concept**

Updated by Tim Rose, AVT  
Nov. 3, 2017