


Meridian-480 Distribution Switchboard

Manufacturer: Caldra Meridian Electric
Product family: Meridian-480 Distribution Switchboard
Application: indoor service distribution for a fictional training project.

Project: Asterquay Learning Workshop
Equipment Tag: MSB-1 | **Spec Section:** 26 24 13
Demo fixture: citation evidence only | **Revision:** demonstration

1. PRODUCT OVERVIEW & MECHANICAL CONSTRUCTION

- Enclosure: indoor, floor-mounted steel assembly with front service access.
- Main protective device: molded-case main breaker sized by the final design load.
- Branch positions: configurable to suit the listed feeder breaker schedule.
- Short-circuit rating: selected during engineered configuration for the application.
- Product drawings: issued after the fictional order review is complete.



2. ELECTRICAL RATINGS & OPERATING PARAMETERS

SPECIFICATION PARAMETER	SUBMITTED RATINGS & EQUIPMENT CHARACTERISTICS
ELECTRICAL DATA	Nominal system: 480V, 3-phase, 4-wire.
Bus arrangement	copper main bus with full neutral and ground bars.
Short-circuit rating	selected during engineered configuration for the application.
Main protective device	molded-case main breaker sized by the final design load.
Branch positions	configurable to suit the listed feeder breaker schedule.
Enclosure	indoor, floor-mounted steel assembly with front service access.
Product drawings	issued after the fictional order review is complete.

This cut sheet is invented for SpecGuard and does not describe a real product.

3. FIELD CONNECTION DATA & TERMINATION RATINGS

FIELD CONNECTION PARAMETER	SUBMITTAL REQUIREMENT & FIELD PROVISION
FIELD CONNECTION DATA	Field conductor terminations: 90 deg C minimum.
Accepted conductor material	copper conductors within the marked lug range.
Installation access	front removable barriers support routine field landing work.
Torque information	ship a terminal schedule with the configured assembly.

4. NAMEPLATES AND RECORDS

- Provide equipment identification and breaker labels with the final shipment.
- Provide a wiring diagram that identifies all main and feeder field connections.
- Provide factory routine test documentation for the completed assembly.

SPEC GUARD DEMO REVIEW CONTEXT	
PROJECT: Asterquay Learning Workshop SPEC SECTION: 26 24 13 (Distribution Switchboards) EQUIPMENT TAG: MSB-1	STATUS: DEMO FIXTURE · NOT A PROJECT APPROVAL FIXTURE: CITATION DEMO REVISION: DEMONSTRATION DEMO DATE: 20 August 2026 ACTION: NO PROJECT APPROVAL

All names, values, and statements on this cut sheet are fictional demo content.
No endorsement, certification, or product availability is implied by this fixture.