Energy & Recommendations Report

Building: Campus Building A
Generated: 2026-11-09 11:05
Note: recommendations generated by the rule-based fallback engine.

Energy overview

Area (sqm)	800.0	Total kWh	5123.4
Cost (EUR)	1537.0	Carbon (kg CO2)	2049.3
Avg indoor temp	23.4	Score / Grade	38.0 / D

Total estimated savings across recommendations: **42.8%**

Recommendations

#	Recommendation	Severity	Savings %
1	**Audit HVAC scheduling** The sustainability score is below benchmark. Review HVAC run-times and enable setback schedules outside occupied hours to cut baseline load.	critical	15.5
2	**Lower heating setpoint** Average indoor temperature is 23.4 degC. Reducing the heating setpoint by 1-2 degrees typically saves 6-10% on heating energy.	medium	8.0
3	**Target the highest-use room** 'Lecture Hall 101' is the largest consumer at 2600.0 kWh. Add occupancy sensors and LED lighting there first.	medium	9.3
4	**Investigate consumption spikes** 2 anomalous usage spike(s) were detected. Check equipment left running or faulty metering during those periods.	medium	5.0
5	**Switch to LED and smart controls** Replace remaining fluorescent fixtures with LEDs and add daylight/occupancy controls in common areas for steady, low-risk savings.	low	5.0