

Performance study of 10 MW_p grid connected photovoltaic systems installed at Arizona State University campus

Vivek Sharma
Solar Power Lab
Arizona State University

April 20th, 2012





overview

Fossil fuel dependence and emissions

ASU campus solarization status


Campus Metabolism

Peak electricity load offset

Dust storms

Capacity factor of PV systems

CAMPUS ENERGY USAGE ACCOUNTED FOR 75% OF TOTAL CO₂ EMISSIONS



Electricity purchased from local utility companies was generated from fuel sources such as coal, natural gas & nuclear

campus solarization

campus wide
PV system
installations to
reduce CO₂
emissions &
achieve carbon
neutrality

more than 14
MW dc installed
capacity on 38
structures
(rooftops,
parking lots,
open spaces)

PV systems
vary in type
(fixed tilt vs.
tracking), size
(13 kW - 2.6
MW)










data collection




Campus Metabolism

Availability of weather data, building energy usage & PV generated electricity data

Real time (1 hour interval) energy data collection for Tempe campus for 1 year

Actual measured PV data & electricity usage data instead of simulated data



peak electricity load offset - I




electricity consumed does not include cooling load – chilled water circulation from central plant



resembles a typical office weekday electricity demand curve different from general buildings (residential halls, libraries, parking structures)



50% peak demand offset by closely matched PV generation



peak electricity load offset - II



Bldg. B: Standalone structure with heating and cooling load factored into the electricity load




Gymnasium building – higher demand during night hours



PV system easily offsets approx. 85% of the electricity demand

peak load offset – Tempe campus total



6 am

12 pm

6 pm

12 am Time of day

Summer

6 am

12 pm

6 pm

12 am

seasonal effects

CO₂ emission reductions



PV electricity offsets 20% of university's electricity demand



Total PV electricity generated:

8887000 kWh

(Oct. 1st 2010 –
Sept. 31st 2011)




US annual non-baseload emission rate:
6.895 x 10⁻⁴ metric ton CO₂/kWh

total annual CO₂ offset: 6128 metric tons

dust storm – July 5th 2011




effect of dust storm



Minimal (~ 5%) drop in system performance (July 6th)


Performance was recovered after little (0.2") precipitation (July 11th)

Changes in system performance were independent of module temperature




capacity factor

Capacity factor =
$$\frac{\text{Energy Output (kWh)}}{\text{System size (kW)} * \text{Time (h)}}$$




capacity factor – nuclear plant



3.9 GW Palo Verde nuclear power plant, Arizona

Avg. annual capacity factor = 90.4%

capacity factor – PV system at ASU



effect of seasonal variations in solar radiation, ambient and cell temperature on capacity factors

710 kW_p single axis tracking PV system at ASU Avg. annual capacity factor: 22.4%

annual capacity factors – PV systems at ASU

BUILDIN	G SYSTEM SIZE (KW)	SYSTEM TYPE	MODULE TYPE	AVG. CAPACITY FACTOR (%)
Α	161	FIXED	POLY-SILICON	20.3
В	80	FIXED	POLY-SILICON	20.3
C	70	FIXED	POLY-SILICON	20.1
D	108	FIXED	CdTe THIN FILM	19.4
Е	76	FIXED	POLY-SILICON	21.0
F	42	FIXED	POLY-SILICON	18.5
G	880	1-AXIS TRACKER	POLY-SILICON	23.0
Н	711	1-AXIS TRACKER	POLY-SILICON	22.4
ı	23	FIXED	POLY-SILICON	20.4



acknowledgments

Robert Vandling – ASU campus metabolism

This material is based upon work primarily supported by the Engineering Research Center Program of the National Science Foundation and the Office of Energy Efficiency and Renewable Energy of the Department of Energy under NSF Cooperative Agreement No. EEC-1041895. Any opinions, findings and conclusions or recommendations expressed in this material are those of the author(s) and do not necessarily reflect those of the National Science Foundation or Department of Energy.

Image source: Getty Images