

## Submittal #02-3000-3.0 - New Precast Drainage Structures (S-4A & S-4B) 02-3000 - Earthwork

### Distribution Summary

Distributed by Carlos Duarte (Atlantic Pacific Community Builders) on Nov 4, 2024

**To** Roberto Gonzalez (Atlantic Pacific Community Builders), Elieser Zayas (E & M Equipment Corp.), Nick Stula (Atlantic Pacific Community Builders), Nicolas Caceres (Atlantic Pacific Community Builders), Carlos Duarte (Atlantic Pacific Community Builders), Daniella Ordonez (Atlantic Pacific Community Builders)

**Message** Good morning,

Please see attached *New Precast Drainage Structures (S-4A & S-4B)* marked "Approved as Noted" and please proceed accordingly. Should you have any questions or comments, please feel free to give us a call.

Thank you,  
Carlos Duarte  
(305) 842.0121

### Attachments

Name	Response	Attachments	Comments
Aref Shehadeh (HSQ Group, Inc.)	Approved As Noted	<a href="#">210102-HSQ Approved - New Precast Drainage Structures (S-4A &amp; S-4B) Submt. - 09.25.2024.pdf</a>	Approved as Noted. My only comment is to increase the wall thickness to 8". Thanks
Ena Cordoves (Corwil Architects)	For Record Only	<a href="#">210102-HSQ Approved - New Precast Drainage Structures (S-4A &amp; S-4B) Submt. - 09.25.2024 FRO.pdf</a>	MAY NOT BE USED IN PEDESTRIAN AREAS
Daniella Ordonez (Atlantic Pacific Community Builders)	For Record Only		
Nick Stula (Atlantic Pacific Community Builders)	For Record Only		
Roberto Gonzalez (Atlantic Pacific Community Builders)	For Record Only		

<b>Revision</b>	0	<b>Submittal Manager</b>	Carlos Duarte (Atlantic Pacific Community Builders)
<b>Status</b>	Closed	<b>Date Created</b>	Sep 25, 2024
<b>Issue Date</b>	Sep 25, 2024	<b>Spec Section</b>	02-3000 - Earthwork
<b>Responsible Contractor</b>	E & M Equipment Corp.	<b>Received From</b>	Elieser Zayas (E & M Equipment Corp.)
<b>Received Date</b>	Sep 25, 2024	<b>Submit By</b>	Sep 25, 2024
<b>Final Due Date</b>	Oct 10, 2024	<b>Lead Time</b>	
		<b>Cost Code</b>	02-3000 - Earthwork
<b>Location</b>		<b>Type</b>	Shop Drawing

## Submittal Package

**Approvers** Roberto Gonzalez (Atlantic Pacific Community Builders), Daniella Ordonez (Atlantic Pacific Community Builders), Nick Stula (Atlantic Pacific Community Builders), Ena Cordoves (Corwil Architects), Aref Shehadeh (HSQ Group, Inc.)

## Ball in Court

**Distribution** Carlos Duarte (Atlantic Pacific Community Builders), Daniella Ordonez (Atlantic Pacific Community Builders), Nick Stula (Atlantic Pacific Community Builders), Nicolas Caceres (Atlantic Pacific Community Builders), Roberto Gonzalez (Atlantic Pacific Community Builders)

## Description

## Submittal Workflow

Name	Sent Date	Due Date	Returned Date	Response	Attachments
General Information Attachments					<a href="#">BTV5 - New Precast Drainage Structures (S-4A &amp; S-4B) Submt. - 09.25.2024.pdf</a>
Roberto Gonzalez	Sep 25, 2024	Sep 26, 2024	Sep 26, 2024	For Record Only	
Daniella Ordonez	Sep 25, 2024	Sep 26, 2024	Sep 26, 2024	For Record Only	
Nick Stula	Sep 25, 2024	Sep 26, 2024	Sep 26, 2024	For Record Only	
Ena Cordoves	Sep 26, 2024	Oct 10, 2024	Nov 3, 2024	For Record Only	<a href="#">210102-HSQ Approved - New Precast Drainage Structures (S-4A &amp; S-4B) Submt. - 09.25.2024 FRO.pdf</a> (Current)
<b>Comment</b>	MAY NOT BE USED IN PEDESTRIAN AREAS				
Aref Shehadeh	Sep 26, 2024	Oct 10, 2024	Oct 14, 2024	Approved as Noted	<a href="#">210102-HSQ Approved - New Precast Drainage Structures (S-4A &amp; S-4B) Submt. - 09.25.2024.pdf</a> (Current)
<b>Comment</b>	Approved as Noted. My only comment is to increase the wall thickness to 8". Thanks				