



Atlantic Pacific Community Builders
161 NW 6th Street
Suite 1020
Miami, Florida 33136
P: (305) 357-4700
F: (305) 476-1557

Project: BTV5 Brownsville Transit Village V
5115 NW 29th Avenue
Miami, Florida 33142

Submittal #02-3000-1.0 - Precast Drainage Structures 02-3000 - Earthwork

Distribution Summary

Distributed by Carlos Duarte (Atlantic Pacific Community Builders) on Jul 2, 2024

To Edrey Rodriguez (E & M Equipment Corp.), Roberto Gonzalez (Atlantic Pacific Community Builders), Ana Diaz (E & M Equipment Corp.), Teresa Anon (Corwil Architects), David Rodriguez (E & M Equipment Corp.), Elieser Zayas (E & M Equipment Corp.), Nick Stula (Atlantic Pacific Community Builders)

Message Good morning,

Please see attached *Precast Drainage Structures* marked "Approved as Noted" and please proceed accordingly. Should you have any questions or comments, please feel free to give us a call.

Thank you,
Carlos Duarte
(305) 842.0121

Attachments

Name	Response	Attachments	Comments
Aref Shehadeh (HSQ Group, Inc.)	Approved As Noted	210205-Approved BTV5 - Precast Drainage Structures Subm. - 05.20.2024.pdf	
Teresa Anon (Corwil Architects)	For Record Only	210205-BTV5 Sheet PD-1 (2024-07-01) .pdf , 210205-HSQ Reviewed (7-1-24) of BTV5 - Precast Drainage Structures Subm. - 05.20.2024_C.pdf	Please note that Civil has replaced the Submittal previously uploaded to Procore by the one we are uploading today, dated 07/01/24. The 10" weep holes should be included on every drainage structure, as part of MDC Public Works requirements. Also, the new structures S-4A and S-4B will require shop drawings. Please find the latest PD-1 sheet for the contractor to use as a reference. If you have specific questions about the comments on the Submittal please contact Aref.
Roberto Gonzalez (Atlantic Pacific Community Builders)	For Record Only		

Revision	0	Submittal Manager	Nick Stula (Atlantic Pacific Community Builders)
Status	Closed	Date Created	May 20, 2024
Issue Date	May 20, 2024	Spec Section	02-3000 - Earthwork
Responsible Contractor	E & M Equipment Corp.	Received From	Elieser Zayas (E & M Equipment Corp.)
Received Date	May 17, 2024	Submit By	May 20, 2024
Final Due Date	Jun 4, 2024	Lead Time	
		Cost Code	02-3000 - Earthwork
Location		Type	Shop Drawing

Submittal Package

Approvers Roberto Gonzalez (Atlantic Pacific Community Builders), Teresa Anon (Corwil Architects), Ena Cordoves (Corwil Architects), Aref Shehadeh (HSQ Group, Inc.)

Ball in Court

Distribution Nick Stula (Atlantic Pacific Community Builders), Roberto Gonzalez (Atlantic Pacific Community Builders), Teresa Anon (Corwil Architects)

Description

Submittal Workflow

Name	Sent Date	Due Date	Returned Date	Response	Attachments
General Information Attachments					BTV5 - Precast Drainage Structures Subm. - 05.20.2024.pdf
Roberto Gonzalez	May 20, 2024	May 21, 2024	May 20, 2024	For Record Only	
Teresa Anon	May 20, 2024	Jun 4, 2024	Jul 1, 2024	For Record Only	210205-BTV5 Sheet PD-1 (2024-07-01).pdf (Current) 210205- HSQ Reviewed (7-1-24) of BTV5 - Precast Drainage Structures Subm. - 05.20.2024 _C.pdf (Current)
Comment	Please note that Civil has replaced the Submittal previously uploaded to Procore by the one we are uploading today, dated 07/01/24. The 10" weep holes should be included on every drainage structure, as part of MDC Public Works requirements. Also, the new structures S-4A and S-4B will require shop drawings. Please find the latest PD-1 sheet for the contractor to use as a reference. If you have specific questions about the comments on the Submittal please contact Aref.				
Ena Cordoves	May 20, 2024	Jun 4, 2024		Pending	
Aref Shehadeh	May 20, 2024	Jun 4, 2024	May 28, 2024	Approved as Noted	210205-Approved BTV5 - Precast Drainage Structures Subm. - 05.20.2024.pdf (Current)