

Sample Code: 26MA61481N	Nominal Size: 75 mm	Pipe Class: 3	Type: A
-------------------------	---------------------	---------------	---------

#	Clause	Parameter	Specified Requirement	Observed Value
1	10.1	Colour	As in CI 10.1	Satisfactory
2	10.1	Surface Finish	As in CI 10.1	Satisfactory
3	7.2.1.1 Table 3	Angle of taper (Note-1)	Specified : Shall not exceed 0 degree 30minute	Socket Inside diameter shall be measured by manufactureres only as per Note 2 of CI 7.2.1.1
4	5	CLASSIFICATION OF PIPES	Class 1/2/3/4/5/6	Class 3 (As declared)
5	5.2	The pipes shall be classified based on their application	a) Type A ? Pipes for water supply; and b) Type B ? Pipes for agricultural use.	A (As declared)
6	7	DIMENSIONS-PIPE-Nominal Diameter	Nominal Outside Diameter (Nominal Size)	75 (As declared)
7	7.1.1.1	DIMENSIONS-PIPE-Mean O.D. (Minimum)	75 mm,Min	(Pending)
8	7.1.1.1	DIMENSIONS-PIPE-Mean O.D. (Maximum)	75.3 mm, Max	(Pending)
9	7.1.1.1	DIMENSIONS-PIPE-Mean O.D. Variation	0.30 mm, max	(Pending)
10	7.1.1.2	DIMENSIONS-PIPE-O.D. at any Point (Minimum)	74.0 mm, Min	This requirement has not been checked according to foot note 1 of table 1
11	7.1.1.2	DIMENSIONS-PIPE-O.D. at any Point (Maximum)	76.0 mm, Max	This requirement has not been checked according to foot note 1 of table 1
12	7.1.1.2	DIMENSIONS-PIPE-Ovality (Maximum)	1	(Pending)
13	7.1.2.1	DIMENSIONS-PIPE-Thickness (Minimum)	2.6mm	(Pending)
14	7.1.2.1	DIMENSIONS-PIPE-Thickness (Maximum)	3.1mm	(Pending)
15	7.1.2.1	DIMENSIONS-PIPE-Average Thickness	3.1mm	(Pending)
16	7.2.1	DIMENSIONS-Socket		Satisfactory
17	7.2.1.1 Table 3	DIMENSIONS-Socket-Sockets for solvent cement jointing-Minimum Length	Socket Length (min): 44 mm	(Pending)
18	7.2.1.2 Table 4	DIMENSIONS-Sockets for elastomeric sealing ring joints-Socket inner Diameter	mm	NA
19	8	SEALING RINGS	Conforms With IS 5382	NA

Sample Code: 26MA61481N		Nominal Size: 75 mm		Pipe Class: 3	Type: A
20	9.1	PIPE ENDS	The ends of the pipes meant for solvent cementing (both plain and bell ended) shall be cleanly cut and shall be reasonably square to the axis of the pipe or may be chamfered at the plain end	Full length not provided	
21	10.1	PHYSICAL AND CHEMICAL CHARACTERISTICS-Visual Appearance	The colour of the pipes shall be light grey. Slight variations in the appearance of the colour are permitted.	Satisfactory	
22	10.1.1	PHYSICAL AND CHEMICAL CHARACTERISTICS-Visual Appearance	The colour of the pipes shall be light grey. The internal and external surfaces of the pipe shall be smooth, clean and free from grooving and other defects.	Satisfactory	
23	10.2	PHYSICAL AND CHEMICAL CHARACTERISTICS-Opacity	The wall of the plain pipe shall not transmit more than 0.2 percent of the visible light falling on it when tested in accordance with IS 12235 (Part 3).	(Pending)	
24	10.3	PHYSICAL AND CHEMICAL CHARACTERISTICS-Effect on Water	The pipes shall not have any detrimental effect on the composition of the water flowing through them.	Satisfactory	
25	11.1	MECHANICAL PROPERTIES-Reversion	Maximum: 5 %	(Pending)	
26	11.2	MECHANICAL PROPERTIES-Vicat Softening Temperature	Min: 80 °C	(Pending)	
27	11.3	MECHANICAL PROPERTIES-Density	1.40 and 1.46	(Pending)	
28	11.4	MECHANICAL PROPERTIES-Resistance to Sulphuric Acid	The mass of the pipe shall not increase by more than 0.316 g or decrease by more than 0.013 g.	Not Done	
29	11.5	HYDROSTATIC CHARACTERISTICS -Type Test	Acceptance	Acceptance	
30	11.5	HYDROSTATIC CHARACTERISTICS -Acceptance Test	Min: 1 hour	Not rupture	
31	12	MARKING	a) Manufacturer?s name or trade-mark, b) Outside diameter, c) Class of pipe and pressure rating, d) Batch number, and e) The word ?Water? or ?Agriculture?	Satisfactory	
32	12.2	MARKING	BIS Certification Marking	Satisfactory	