

**25-123**  
**PETITION FOR GRANT OF LOCATION,  
NATIONAL GRID, NORTH ANDOVER, MASSACHUSETTS,  
PROPOSED IINSTALL OF NEW GAS MAIN BETWEEN 136-190 BOSTON AV.  
(NATIONAL GRID PLAN: # WO-1491849)  
MEDFORD, MASSACHUSETTS  
CITY CLERK'S OFFICE**

You are hereby notified that by order of the Medford City Council, the Medford City Council will hold a Public Hearing in the Howard F. Alden Chambers at Medford City Hall, 85 George P. Hassett Drive, Medford, and via Zoom on Tuesday, September 9<sup>th</sup> at 7:00 p.m., a link to be posted no later than Friday, September 5<sup>th</sup>, 2025, on a petition by Massachusetts Electrical Company dba National Grid, for permission to install a new gas main, including necessary sustaining and protecting fixtures, located at 136-190 Boston Av.

Wherefore it requests that after due notice and hearing as provided by law, it be granted a GOL permit for a new gas main on Boston Av, together with such sustaining and protecting fixtures as it may find necessary for the transmission of gas, in accordance with Plan #WO-1491849 originally dated July 14<sup>th</sup>, 2025 and received and filed in the Office of the City Clerk on August 21<sup>st</sup>, 2025 and available for inspection in the Office of the City Clerk, Medford City Hall, Room 103, 85 George P. Hassett Drive, Medford, Massachusetts 02155.

The following are the streets and highways referred to: in Plan #WO-1491849 136 – 190 Boston Av. National Grid to install a new gas main as depicted on the plan.

The Engineering Division recommends that this grant of location be approved with the following conditions:

1. The Grant of Location (GOL) is limited to approximately 125 feet of duel (x2) 8-inch gas main within the southernmost sidewalk across the Boston Avenue bridge as depicted on the Plan.
2. Before starting work, the contractor shall notify Dig safe and shall obtain all applicable permits from the Engineering Division. The project must obtain a Trench Permit pursuant to Section 74-141 of the City Ordinances prior to commencing work.
3. No other utility structures, conduits, duct banks, pipes, or any other appurtenances are adversely impacted. National Grid shall ensure that all sewer, water, and drain lines are marked prior to any excavation.
4. The project site must be swept after installation (or daily) and shall be kept free of debris for the duration of the installation.
5. At least 72-hours prior to the start of the project, National Grid must coordinate abutter communications with the Director of Communications and submit any required information that may be requested to effectively inform the public.

**Approved – City Engineer**

Call 781-393-2425 for any accommodation/aids

s/Adam L. Hurtubise  
City Clerk



Plans can be viewed in the City Clerk's Office, 781-393-2425.

RECEIVED  
CITY CLERK  
MEDFORD, MASS.  
2025 AUG 25 PM 3:27