

	FAN	FAN SCHEDULE*	*	
UNIT NUMBER	EF-1	EF-2	EF-3	SF-1
AREA SERVED (ROOMS)	REST-	REST-	KITCHEN	KITCHEN SUPPLY FAN
MANUFACTURER	GREENHECK	GREENHECK	DAYTON	GREENHECK
MODEL NUMBER	G-095-E	G-095-E	4HX96	RSF-100
CFM	50	50	4,000	3,200
STATIC PRESSURE	.1″	.1"	.25″	,25,
FAN H.P.	1/30	1/30	3/4	1/2
DRIVE	DIRECT	DIRECT	DIRECT	BELT
RPM	1050	1050	1060	807
ELECTRICAL SERVICE	120/1/60	120/1/60	115/1/60	240/1/60
ROOF OPENING REQ'D.	12.5×12.5	12.5×12.5	19X19	17X17
DUCT SIZE	10×10	10×10	16"×18"	18ø"
DUCT VELOCITY				


ALTERNATE FAN MANUFACTURERS: GREENHECK FAN CORP. PENN V. CORP.





FAN UNIT ANCHORAGE DETAIL APPROVED FIRE-EXTINGUISHING SYSTEMS SHALL BE PROVIDED FOR THE PROTECTION OF COMMERCIAL FOOD HEAT PROCESSING EQUIPMENT.
AUTOMATIC FIRE-EXTINGUISHING SYSTEM SHALL BE INTERCONNECTED TO THE FUEL OR ENERGY SOURCE FOR THE COOKING EQUIPMENT AND ARRANGED TO AUTOMATICALLY SHUT OFF EQUIPMENT UNDER THE HOOD WHEN THE SYSTEM IS ACTIVATED. SHUTOFF VALVES OR SWITCHES SHALL BE OF A TYPE THAT REQUIRES MANUAL OPERATION TO RESET. RE STRUCTURE FOR ANCHORING ĮΣ PROVIDE MOTORIZED VOL. DAMPER FOR THE OUTDOOR AIR INLET ON FAIL. TO COOL UNE NOTE: CONTRACTOR TO USE SEJUMF OUNE PENETRATIONS AS PER C.O.H. STANDARDS. STEAM TABLE 6.8.3 H.C.E.C.C. MINIMUM PIPE INSULATION CONTRACTOR TO ENSURE PIPING IS THERMALLY INSULATED IN ACCORDANCE WITH TABLE 6.8.3 H.C.E.C.C. FLOID > 1.5" - 4"d

KITCHEN HOOD NOTE:



1 1/2 ۷ 4**ط

MECHANICAL

03/02/10 DATE M.A. M.A. PRO. NO. SCALE

MECHANICAL PLAN FOR A PROPOSED BUILD-OUT "LA BOTANA REGIA" LOCATED AT 7610 KEMPWOOD, STE A HOUSTON TX 77055





12/24/09

с.в.н. соммент

M-2