

TC10 Series

Digital Room Thermostats with LCD

Features

- Ultra slim wall-mount display control unit to match any decor
- Large easy-to-read liquid crystal display (LCD), with LED backlight (white)
- A stylish bi-directional rotating dial and two compact touch keys to provide ease of operation
- Choice of constant display of ambient temperature or temperature set point value
- Output relays employed for direct connection of valve actuators and 3speed fan
- Slim separate power supply unit to fit on all sizes of fan coil units and to provide highly reliable power source
- Configurable operating parameters
- Choice of °C or °F temperature display via parameter setup menu
- Adjustable proportional band and integral time for PI control
- Choice of valve stroke time for 3-wire on-off/floating models
- Field adjustable high and low occupied set point limit values
- Field adjustable cooling and heating unoccupied set point values (applicable to some models only)
- Choice to retain last entered settings on power resumption
- 2-wire on-off, 3-wire on-off/floating and 0-10 VDC output models available
- Dual-output models with auto cooling/ heating changeover (deadband operation) and manual override
- Adjustable 1 to 5 K deadband for dual-output models
- Choice of operating sequence for dual-output models
- Choice of unoccupied mode activation in operating mode only or in both standby and operating modes
- Choice of fan action in unoccupied mode

- Window contact closure to lock out all thermostat functions
- Provides one on-off output for external device interlocking; output is on whenever fan at any speed is running.
- Field recalibration capability of measured temperature
- Continuous or auto fan operation
- External and seasonal changeover temperature sensor capability
- Output relays to provide high current ratings and performance
- Optional infer-red remote control unit



The TC10 Series digital room thermostats are available in various models for 2-wire on-off, 3-wire on-off/ floating or 0-10 VDC proportional control of valves and High-Medium-Low-Auto speed control of fan motors in fan coil units and heat pumps for commercial, industrial and residential installations.

All 3-wire floating and 0-10 VDC proportional thermostats adopt true proportional-integral (PI) control algorithm. The microprocessor combines a proportional plus integral (PI) algorithm with advanced adaptive control logic. The proportional component of the algorithm adjusts the control output in response to changes in the measured temperature. The integral component of the algorithm adjusts the control output to eliminate offset (difference between the set point and the actual temperature). This provides precise and stable control under various system capacity and varying load conditions without the need for tuning or calibrating the control algorithm in the field. The digital display of ambient temperature, set point and operating mode provides



the user with an attractive and functional thermostat that is easy to use.

A fan-speed touch key allows control of a 3-speed fan. The speed control touch key has 4 positions: "Hi-Med-Low-Auto". In the "Hi", "Med" or "low" position, the fan runs continuously at the selected speed. In the "Auto" mode, the fan speed is temperature dependent and controlled automatically in 2 K differential increments from low to medium and from medium to high speed. For actual activating temperature differential values, refer to the parameter setup menu in Page 7.

A bi-directional rotating dial allows change of settings such as temperature set point values.

Ordering

To order, specify model numbers of complete set, display control unit or power supply unit.

Figure 1: TC10 Series Digital Room Thermostat Model Number Selection Guide


TC1	0	_	1AM	R
Product Type	Power Supply	Separator	Control Type	Options
C1 = TC10 Series	0 = 100-230 VAC		1 = Single 2-wire on-off output, cool only or	R = with infra-red
digital room			heat only	Ireceiver for RCU-1
thermostats	2 = 230 VAC		1M* = Single 2-wire on-off output, manual	B = with buzzer for
	+ 24 VAC*		cool/heat changeover	key touch sounding
	3 = 120 VAC		1F = Single 3-wire floating output, cool only or	W = with white color
	+ 24 VAC*		heat only	faceplate
			1FM* = Single 3-wire floating output, manual cool/heat changeover	
	* Suitable for line-voltage		1A = Single 0-10 VDC output, cool only or	
	fan control and 24 VAC		heat only	
	valve control		1AM* = Single 0-10 VDC output, manual cool/heat	
			changeover	
			2 = Dual 2-wire on-off outputs, manual or auto	
			cool/heat changeover	
			2F = Dual 3-wire floating outputs, manual or auto	
			cool/heat changeover	
			2A = Dual 0-10 VDC outputs, manual or auto	
			cool/heat changeover	
			2AH = 0-10 VDC cooling output, 2-wire on-off	
			heating output, manual or auto cool/heat	
			changeover	
			*These models do not provide	
			unoccupied mode capability	

	Power Supply Unit Model Number Selection Guide				
PSU1	0	_	1	Α	M
Product Type	Power Supply	Separator	Number of Outputs	Control Type	Seasonal Changeover
PSU1 = Power Supply Units	0 = 100-230 VAC		1 = Single output	Nil = 2-wire on/off	Nil = Auto by
for TC10 Series			2 = Dual outputs	F = 3-wire floating	external
	2 = 230 VAC + 24 VAC*			A = 0-10 VDC	sensor
	3 = 120 VAC + 24 VAC*				M = Manual
	* Suitable for line-voltage fan control and 24 VAC valve control				

Display Control Unit Model Number Selection Guide				
DCU1	1	Α	М	R
Product Type	Number of Outputs	Control Type	Seasonal Changeover	Options
DCU1 = TC10 Series	1 = Single output	Nil = 2-wire on/off	Nil = Auto	R = with infra-red
Display Control	2 = Dual outputs	F = 3-wire floating	M = Manual	Receiver for
Units		A = 0-10 VDC output		RCU-1
		AH = 0-10 VDC cooling output +		B = with buzzer for
		line-voltage 2-wire on-off		key touch sounding
		heating output		W = with white color
				faceplate

Figure 2: TC10 Series Application Guide Unoccupied Model **Outputs Applications** Cooling/Heating External **System** Fan Control Number Mode Seasonal Modes Mode Changeover TC1x-1 Cooling Only Cool or Heat-Fan Hi-Med-Low-Auto Single Auto Only Yes Yes 2-Wire or Heating Only Only-Off On-Off (2-Pipe System) Cooling/Heating Cool or Heat-Fan Hi-Med-Low-Auto TC1x-1M Single Manual Only No Yes 2-Wire (2-Pipe System) Only-Off On-Off TC1x-1F Cool or Heat-Fan Hi-Med-Low-Auto Single Cooling Only Auto Only Yes Yes 3-Wire or Heating Only Only-Off Floating (2-Pipe System) TC1x-1FM Single Cooling/Heating Manual Only No Cool or Heat-Fan Hi-Med-Low-Auto Yes Line-Voltage (2-Pipe System) Only-Off 3-Wire Floating TC1x-2 Dual Cooling and Manual No Cool-Heat-Auto-Hi-Med-Low-Auto Yes 2-Wire Heating or Auto Fan Only-Off On-Off (4-Pipe System) Or Auto-Off TC1x-1A Single Cooling Only Cool or Heat-Fan Hi-Med-Low-Auto **Auto Only** Yes Yes 0-10 VDC or Heating Only Only-Off (2-Pipe System) Cooling/Heating Cool or Heat-Fan Hi-Med-Low-Auto TC1x-1AM Single Manual Only No Yes 0-10 VDC (2-Pipe System) Only-Off TC1x-2A Dual Cooling and Manual Cool-Heat-Auto-Hi-Med-Low-Auto Yes No 0-10 VDC Heating or Auto Fan Only-Off (4-Pipe System) Or Auto-Off

Figure 6: Dimensions in mm



Specifications				
Product model numbers	See Figure 1: TC10 Series Model Number Selection Guide			
Power requirements	100-230 V, ±10%, 50/60 Hz or 120 V or 230 V, +10% and -15%, 50/60 Hz depending on models			
0-10 VDC output impedance	Minimum 10,000 Ω			
Operating temperature differential for 2-wire on-off models	Fixed at 1 K (1 R) for both cooling and heating modes			
Temperature display range	5-35°C in 0.5 K increments: accuracy ±1	K (41-95°F in 0.5 R increments, accuracy ±1 R)		
Temperature set point range	5-35°C in 0.5 K increments (41-95°F in 0.	5 R increments), initial factory setting at 22°C		
Temperature set point limits	Field adjustable 5-35°C (41-95°F) in 0.5 I	K increments		
Constant display on LCD	Choice of ambient temperature or tempe	rature set point value		
Offset adjustment of temperature indication (field recalibration)	+2, +1, 0, -1 and -2 K (+2, +1, 0, -1 and -	2 R) throughout the range, factory setting 0		
Deadband of dual-output models	Adjustable 1 to 5 K(1 to 5 R) between co	oling mode and heating mode, factory set at 3 K(3 R)		
Valve stroke time for 3-Wire floating models	Accumulatively 10, 60, 90,120, 150,180, setting. Setting = 0 means the output being	210 or 240 s maximum in one direction, depending on ng activated as on-off mode.		
Proportional band for PI control	Adjustable 1 to 10 K (2-10 R) in 1 K (1 R) increments, factory setting 5 K (5 R)			
Integral time for PI control	Adjustable 0 to 30 minutes in 1 minute increments, factory setting 15 minutes. Setting = 0 means integral time being turned off.			
Auto fan temperature differential	At 2 K (4 R) increments. In cooling mode output. Fan status in heating mode dependent	, fan stays at low speed when there is no cooling valve nds on auto fan action selection setting.		
Sensing element	NTC thermistor, 10 kΩ@25°C; accuracy	±0.5 K@25°C		
Unoccupied mode	Input signal from external voltage-free co	ntact		
	Choice of activation of unoccupied mode operating modes.	: in operating mode only or in both standby and		
		" fan when in operation or runs at "low" fan only oling or heating (not applicable to "1M" models).		
Unoccupied temperature set Point range (not applicable to "1M" models)				
Enclosure	Material: Self-extinguishing, molded ABS			
	Finish: Off white housing and dark grey faceplate			
Protective class	IP30			
Electrical ratings		24 V, 0.3 A resistive, 0.3 A inductive, 50/60 Hz		
	Valve output (all other models)	100-230 V, 5 A resistive, 2 A inductive, 50/60 Hz		
	Fan output relays	100-230 V, 5 A resistive, 2 A inductive, 50/60 Hz		
	Total rating	100-230 V, 5 A maximum, 50/60 Hz		
Ambient/Storage temperature limits	0 to 50 °C / -30 to 50 °C, 10% to 90% RH non-condensing			
Connectors	Non-removable screw-type terminal blocks and removable wire plugs			
Power wires	Wire size 1 mm ² or 18 AWG solid copper recommended			
Sensor wires	wires 22 AWG twisted shielded pair double-insulated cable			
PSU/DCU inter-connecting wires	Cat 5e twisted 6-conductor cable (shielded or unshielded)			

The performance specifications above are nominal and subject to tolerances and application variables of generally acceptable industry standards.

The Manufacturer shall not be liable for damages resulting from misapplication or misuse of its products.

See Figure 6: Dimensions in mm and Mounting Details

CE Mark compliant to EMC and Low Voltage Directives pending


Figure 3: Display Control Unit and LCD Layout

Accessories and options

Agency approval

Shipping weight

Dimensions



See Figure 5: Optional Accessories

0.6 kg (1.3 lb)

Figure 4: DCU Mounting Details




Figure 5: Optional Accessories

Description	Part Number
Remote control unit	RCU-1
Probe temperature sensor	TE10-1
Duct temperature sensor	TE10-2
With infra-red receiver Capability	TC1x-xx <u>R</u>
With buzzer capability	TC1x-xx <u>B</u>
With white color faceplate	TC1x-xx <u>W</u>

Mounting of Display Control Unit

The TC10 Series display control unit can be surface mounted or secured to a standard European 75 x 75 x 35 mm electrical box. See Fig. 2: Mounting Details. Two M3.5 mounting screws for Network Control Units only are included.

Thermostat Errors Reporting

When the following errors are reported on the LED display unit, these errors will prevent the thermostat from normal operation:

- E-1 EEPROM read/write error
- E-2* Temperature sensor open-circuited
- E-3 Temperature sensor short-circuited

Trouble-Shooting

Before trouble-shooting starts, ensure that the voltage output from Terminals 1 (GND) and 2 (+5 Vdc) on the power supply unit is between 5 Vdc and 5.25 Vdc and not higher. Higher voltage may damage the internal circuitry and components of the display control unit.

When abnormal power voltages are found, return the thermostat to the manufacturer for repair.

When there is no 5 Vdc power output, check the line voltage power and its 5 A fuse.

Operation Notes

- LCD shows ambient temperature constantly except when set point adjustment is being made.
- Press the system key to enter into the desired operating mode: Cool-Heat-Auto-Fan Only-Off, etc.
- Press the fan key to change the fan speed mode: High-Med-Low-Auto.
- Increase or decrease temperature set point in 0.5 K increments by rotating the adjustment dial clockwise or counterclockwise. During the dial rotation, the LCD shows the existing set point value.
- When the unoccupied contact closes, it will override the operating mode and operate the thermostat in energy saving mode despite the thermostat being in operating or standby mode.
- In unoccupied mode, the factory-set temperature cut-in points are 26 °C for cooling and 16 °C for heating. Meanwhile, the operation of all operation keys are locked out until the unoccupied contact opens.
- During unoccupied mode, the default fan speed is set at "low" when pre-set cut-in temperature is reached, or otherwise the fan output is always "off".
- Unoccupied mode can be activated in the following manner when the unoccupied contact closes: For 2-pipe models with auto seasonal changeover, the unoccupied cooling or heating mode is determined by the status of the SR2 seasonal changeover sensor and the valve output is activated according to the measured temperature.

For 2-pipe models with manual seasonal changeover, while in unoccupied mode, the valve output is never activated. For 4-pipe models, the unoccupied cooling or heating mode is always determined by the measured temperature and valve output is also activated according to the measured temperature.

Unoccupied mode activation in operating mode only or in both standby and operating mode will be determined by activation setting in setup menu. Low fan will run according to fan action setting in setup menu.

When unoccupied mode is activated, all keys are locked out and no settings can be entered.

- When Window contact closes, it will override the operating mode and operate the thermostat in off mode despite the thermostat being in operating or standby mode. Meanwhile, all operating keys are locked out until the window contact opens.
- The thermostat allows authorized service agent to change the following operating parameters in the field:

^{*} If jumper JP1 is cut open and external sensor is used, E-2 means the external sensor may have been disconnected from Terminals SR1 and GND. Check the external sensor's connectivity and resistive value. If E-2 error is still reported, return the thermostat to the manufacturer for repair.

Choice of temperature engineering unit F. E = "C (slotzby setting) F. F = "F F = "F = "F = "F = "F F = "F =	MCU firmware revision level	0	Appears after entering the setup mode
F.F. = F	Choice of temperature engineering unit	1	I-C = °C (factory setting)
resumption 286 = program off 3 3 2 emperature indication (field recalibration of measured temperature) 3 3 2 emperature indication plus 2 degrees 3 1 emperature indication plus 1 degree 3 3 2 emperature indication plus 1 degree 3 3 2 emperature indication minus 2 degrees 3 4 emperature indication minus 2 degrees 4 emperature indication minus 2 degrees 4 emperature indication minus 3 degrees 4 emperature indication minus 2 degre			1
Offset adjustment of temperature indication (field recalibration of measured temperature) 3		2	20 n = program on (factory setting)
(field recalibration of measured temperature) 3	resumption		20F = program off
Adjustable proportional band for PI control Adjustable proportional band for PI control Adjustable integral time for PI control B R I = 1 K		3	∃ ≥ = temperature indication plus 2 degrees
3- 1 stemperature indication minus 2 degrees 3-2 stemperature indication 3-2 stemperature 3-2 stemperature 3-3 stemperature	(field recalibration of measured temperature)		
3-2 + temperature indication minus 2 degrees			, , , , , , , , , , , , , , , , , , , ,
Adjustable proportional band for PI control Agjustable integral time for PI control By By I = 1 K			1
Adjustable integral time for PI control b To set integral time from 0 (0 min) to 30 (30 min) in numeric 1 (1 min) increment factory setting = 15 minutes. Setting = 0 means integral time being turned off. Choice of valve stroke time for 3-wire floating models Choice of valve stroke time for 3-wire floating models Calculated the stroke time is set to 10 seconds (24 = 240 seconds without models) Deadhand value adjustment for dual-output Models Upper occupied set point limit setting E To set deadband value from 1 to 5 K, factory setting 3 K Upper occupied set point limit setting E To set upper occupied set point limit, adjustable between current lower set point limit value and 35°C (factory setting 35°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point limit value and the lower set point limit value and 5°C (footby setting 35°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point limit value and the lower set point limit value and 5°C (footby setting 35°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point limit value and the lower set point limit value and set point value and set point value and set v	Adicatable grant attack hand for Discardal	<u> </u>	·
Choice of valve stroke time for 3-wire floating Choice of activation of unoccupied mode (always in auto fan mode) Choice of activation of unoccupied mode (always in auto fan mode) Choice of operating sequence for dual-output models Choice of operating sequence for dual-output models F I To set upper occupied set point limit, adjustable between current lower set point limit value and 35°C (factory setting 35°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point imit value and 5°C (factory setting 35°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point imit value and 5°C (factory setting 36°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point imit value and the tower set point limit value. Unoccupied cooling set point setting G To set unoccupied cooling set point, adjustable between current unoccupied heating set point value and 35°C (factory setting 26°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied cooling set point value and 5°C (factory setting 26°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied cooling set point value and 5°C (factory setting 36°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied cooling set point value and 5°C (factory setting) D To set unoccupied heating set point, adjustable between current unoccupied cooling set point value and 5°C (factory setting) D To set unoccupied mode (always in unoccupied mode (always in unoccu	· · · ·	1	
Comparison Com	Adjustable integral time for PI control	ь	factory setting = 15 minutes. Setting = 0 means integral time being turned off.
When the stroke time is set to 10 seconds, the output is activated as on-off mode. Deadband value adjustment for dual-output Models Upper occupied set point limit setting £ To set upper occupied set point limit, adjustable between current lower set point limit value and 35°C (factory setting 35°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point limit value and 5°C (factory setting 5°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point limit value and 5°C (factory setting 5°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point limit value and 5°C (factory setting 5°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point limit value and 5°C (factory setting 26°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point limit value and the lower set point limit value and 5°C (factory setting 26°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied ocoling set point value and 5°C (factory setting 26°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied ocoling set point value and 5°C (factory setting) To set unoccupied heating set point, adjustable between current unoccupied ocoling set point value and 5°C (factory setting) To set unoccupied heating set point, adjustable between current unoccupied ocoling set point value and 5°C (factory setting) To set unoccupied heating set point, adjustable between current unoccupied ocoling set point value and 5°C (factory setting) To set unoccupied heating set point adjustable between current unoccupied ocoling set point value and 5°C (factory setting) To set unoccupied		Ε	
Upper occupied set point limit setting E To set upper occupied set point limit, adjustable between current lower set point limit value and 35°C (factory setting 35°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point limit value and the lower set point limit value. F To set lower occupied set point limit, adjustable between current upper set point limit value and the lower set point limit value. F To set two occupied set point limit, adjustable between current upper set point limit value and 5°C (factory setting 5°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point limit value and the lower set point limit value. Unoccupied cooling set point setting G To set unoccupied cooling set point, adjustable between current unoccupied heating set point value and 5°C (factory setting 26°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied cooling set point value and 5°C (factory setting 26°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied cooling set point value and 5°C (factory setting 26°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied cooling set point value and 5°C (factory setting 26°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied cooling set point value and 5°C (factory setting 26°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied cooling set point value and 5°C (factory setting) 2°C = Low fan always runs whenever unoccupied set point calls for cooling set point value and 5°C (factory setting) 2°C = Low fan always runs whenever unoccupied contact is closed while opening and closing of control valve are temperature-dependent. Ch	models		
(factory setting 35°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point limit value and the lower set point limit value. F To set lower occupied set point limit, adjustable between current upper set point limit value and 5°C (factory setting 5°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point limit value and the lower set point limit value. Unoccupied cooling set point setting G To set unoccupied set point, adjustable between current unoccupied heating set point value and 35°C (factory setting 26°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied cooling set point value and the unoccupied heating set point value. Unoccupied heating set point setting To set unoccupied heating set point, adjustable between current unoccupied opint value and the unoccupied heating set point value. To set unoccupied heating set point, adjustable between current unoccupied opint value and the unoccupied heating set point value. To set unoccupied heating set point, adjustable between current unoccupied set point value and the unoccupied heating set point value. To set unoccupied heating set point, adjustable between current unoccupied set point value and the unoccupied heating set point value. To set unoccupied heating set point value and the unoccupied set point value and the unoccupied heating set point value. Choice of fan action in unoccupied mode C (alcory setting) D I I = Low fan will run only when unoccupied set point calls for cooling or heating in unoccupied mode (factory setting) D I = Low fan will run only when unoccupied set point calls for cooling or heating in unoccupied mode (factory setting) D I = Low fan will run only when unoccupied set point value and the unoccupied heating set point value and the unoccupied mode (factory setting) D I = Low fan will run only when unoccupied set		Ь	To set deadband value from 1 to 5 K, factory setting 3 K
(factory setting 5°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point limit value and the lower set point limit value. To set unoccupied cooling set point, adjustable between current unoccupied heating set point value and 35°C (factory setting 26°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied cooling set point value and the unoccupied heating set point value. Unoccupied heating set point setting	Upper occupied set point limit setting	E	(factory setting 35°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point limit value and the lower set point limit
and 35°C (factory setting 26°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied cooling set point value and the unoccupied heating set point value. In To set unoccupied heating set point, adjustable between current unoccupied cooling set point value and 5°C (factory setting 16°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied cooling set point value and 5°C (factory setting 16°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied cooling set point value and the unoccupied heating set point value. Choice of fan action in unoccupied mode (always in auto fan mode) In J I = Low fan will run only when unoccupied set point calls for cooling or heating in unoccupied mode (factory setting) In J = Low fan will run only when unoccupied contact is closed while opening and closing of control valve are temperature-dependent. Choice of activation of unoccupied mode Choice of auto fan action in heating mode (operation of both control valve and fan is temperature-dependent) P I = No fan output when room temperature (Tr) => set point value (Ts). Low speed when -2.0 K <= Tr - Ts <= -0.5 K Med speed when -4.0 K <= Tr - Ts <= -2.5 K High speed when 1 -2.0 K <= Tr - Ts Med speed when -4.0 K <= Tr - Ts <= -2.5 K High speed when Tr - Ts <= -4.5 K P-2 = (factory setting) Choice of operating sequence for dual-output models only Choice of "1" or "1M" model E 1 = 1 = to set operating sequence of Coul-Heat-Pan Only-Off (factory setting) "r 2 = to set operating sequence of Off-Cool Heat-Fan Only (factory setting for "1" models) E 2 = to set operating sequence of Off-Cool-Heat-Fan Only (factory setting for "1M" models) E 2 = to set operating sequence of Off-Cool-Heat-Fan Only (factory setting for "1M" models) E 3 = Restoration of default factory settings	Lower occupied set point limit setting	F	(factory setting 5°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the upper occupied set point limit value and the lower set point limit
and 5°C (factory setting 16°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied cooling set point value and the unoccupied beating set point value. Choice of fan action in unoccupied mode (always in auto fan mode) J J- I = Low fan will run only when unoccupied set point calls for cooling or heating in unoccupied mode (factory setting) J-2 = Low fan always runs whenever unoccupied contact is closed while opening and closing of control valve are temperature-dependent. Choice of activation of unoccupied mode L L- I = Unoccupied mode can only be activated when thermostat is in operating mode (factory setting) L-2 = Unoccupied mode can be activated when thermostat is in either standby mode or operating mode Choice of auto fan action in heating mode (operation of both control valve and fan is temperature-dependent) P - I = No fan output when room temperature (Tr) => set point value (Ts). Low speed when - 2.0 K <= Tr - Ts <= -0.5 K Med speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K High speed when - 1.0 K <= Tr - Ts <= -2.5 K Hi	Unoccupied cooling set point setting	G	and 35°C (factory setting 26°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied cooling set point value and the unoccupied heat-
unoccupied mode (factory setting) J-2 = Low fan always runs whenever unoccupied contact is closed while opening and closing of control valve are temperature-dependent. Choice of activation of unoccupied mode L I = Unoccupied mode can only be activated when thermostat is in operating mode (factory setting) L-2 = Unoccupied mode can be activated when thermostat is in either standby mode or operating mode (factory setting) L-2 = Unoccupied mode can be activated when thermostat is in either standby mode or operating mode (operation of both control valve and fan is temperature-dependent) P I = No fan output when room temperature (Tr) => set point value (Ts). Low speed when - 2.0 K <= Tr - Ts <= -0.5 K Med speed when - 4.0 K <= Tr - Ts <= -2.5 K High speed when Tr - Ts <= -4.5 K P-2 = (factory setting) Low fan output when -2.0 K <= Tr - Ts Med speed when -4.0 K <= Tr - Ts <= -2.5 K High speed when Tr - Ts <= -4.5 K Choice of operating sequence for dual-output models only Choice of "1" or "1M" model E I = to set operating sequence of Off-Cool or Heat-Fan Only (factory setting for "1" models) E-2 = to set operating sequence of Off-Cool-Heat-Fan Only (factory setting for "1M" models) Choice of constant display of ambient temperature or temperature set point value Restoration of default factory settings T5 F5 = Retain current settings (factory setting)	Unoccupied heating set point setting	h	and 5°C (factory setting 16°C). The program is set such that there is always a minimum separation of 4 degrees maintained between the unoccupied cooling set point value and the unoccupied heat-
J-2 = Low fan always runs whenever unoccupied contact is closed while opening and closing of control valve are temperature-dependent. Choice of activation of unoccupied mode		J	
(factory setting) L-2 = Unoccupied mode can be activated when thermostat is in either standby mode or operating mode Choice of auto fan action in heating mode (operation of both control valve and fan is temperature-dependent) P- I = No fan output when room temperature (Tr) => set point value (Ts). Low speed when - 2.0 K <= Tr - Ts <= -0.5 K Med speed when - 4.0 K <= Tr - Ts <= -2.5 K High speed when Tr - Ts <= -4.5 K P-2 = (factory setting) Low fan output when -2.0 K <= Tr - Ts <= -2.5 K High speed when Tr - Ts <= -4.5 K P-2 = (factory setting) Choice of operating sequence for dual-output models only Choice of "1" or "1M" model E-1 = to set operating sequence of Cool-Heat-Auto-Fan Only-Off (factory setting) r-2 = to set operating sequence of Off-Cool or Heat-Fan Only (factory setting for "1" models) E-2 = to set operating sequence of Off-Cool-Heat-Fan Only (factory setting for "1M" models) Choice of constant display of ambient temperature or temperature set point value Restoration of default factory settings F5 I = Retain current settings (factory setting)			☐-2 = Low fan always runs whenever unoccupied contact is closed while opening
Low speed when - 2.0 K <= Tr - Ts <= -0.5 K Med speed when - 4.0 K <= Tr - Ts <= -2.5 K High speed when Tr - Ts <= -4.5 K P-2 = (factory setting) Low fan output when -2.0 K <= Tr - Ts Med speed when - 4.0 K <= Tr - Ts Med speed when Tr - Ts <= -2.5 K High speed when Tr - Ts Med speed when - 4.0 K <= Tr - Ts Med speed when - 4.0 K <= Tr - Ts Med speed when Tr - Ts <= -2.5 K High speed when Tr - Ts <= -2.5 K High speed when Tr - Ts <= -4.5 K Choice of operating sequence for dual-output models only r-1 = to set operating sequence of Cool-Heat-Auto-Fan Only-Off (factory setting) r-2 = to set operating sequence of Auto-Off Choice of "1" or "1M" model bull to set operating sequence of Off-Cool or Heat-Fan Only (factory setting for "1" models) bull to set operating sequence of Off-Cool-Heat-Fan Only (factory setting for "1M" models) bull to set operating sequence of Off-Cool-Heat-Fan Only (factory setting for "1M" models) bull to set operating sequence of Off-Cool-Heat-Fan Only (factory setting) bull to set operating sequence of Off-Cool-Heat-Fan Only (factory setting) bull to set operating sequence of Off-Cool-Heat-Fan Only (factory setting) bull to set operating sequence of Off-Cool-Heat-Fan Only (factory setting) bull to set operating sequence of Off-Cool-Heat-Fan Only (factory setting) bull to set operating sequence of Off-Cool-Heat-Fan Only (factory setting) bull to set operating sequence of Off-Cool-Heat-Fan Only (factory setting) bull to set operating sequence of Off-Cool-Heat-Fan Only (factory setting) bull to set operating sequence of Off-Cool-Heat-Fan Only (factory setting) bull to set operating sequence of Off-Cool-Heat-Fan Only (factory setting) bull to set operating sequence of Off-Cool-Heat-Fan Only (factory setting) bull to set operating sequence of Off-Cool-Heat-Fan Only (factory setting)	Choice of activation of unoccupied mode	L	(factory setting) L-2 = Unoccupied mode can be activated when thermostat is in either standby mode
models only r-2 = to set operating sequence of Auto-Off Choice of "1" or "1M" model L - I = to set operating sequence of Off-Cool or Heat-Fan Only (factory setting for "1" models) L-2 = to set operating sequence of Off-Cool-Heat-Fan Only (factory setting for "1M" models) Choice of constant display of ambient temperature or temperature set point value Restoration of default factory settings r-2 = to set operating sequence of Off-Cool or Heat-Fan Only (factory setting for "1M" models) u-1 = constant display of ambient temperature (factory setting) u-2 = constant display of set point value F5 I = Retain current settings (factory setting)	(operation of both control valve and fan is tem- perature-dependent)	P	Low speed when - 2.0 K <= Tr - Ts <= -0.5 K Med speed when - 4.0 K <= Tr - Ts <= -2.5 K High speed when Tr - Ts <= -4.5 K P-2 = (factory setting) Low fan output when -2.0 K <= Tr - Ts Med speed when - 4.0 K <= Tr - Ts <= -2.5 K High speed when Tr - Ts <= -4.5 K
E-2 = to set operating sequence of Off-Cool-Heat-Fan Only (factory setting for "1M" models) Choice of constant display of ambient temperature or temperature set point value L = to set operating sequence of Off-Cool-Heat-Fan Only (factory setting for "1M" models) L = t = to set operating sequence of Off-Cool-Heat-Fan Only (factory setting for "1M" models) L = t = constant display of ambient temperature (factory setting) L = t = constant display of set point value Restoration of default factory settings T = Retain current settings (factory setting)		٢	, , , , ,
ture or temperature set point value $u-2 = constant display of set point value$ Restoration of default factory settings	Choice of "1" or "1M" model	Ł	1
5 5 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7		נו	1 , 1 , 5
	Restoration of default factory settings	Γ5	

Figure 7: Wiring Diagrams

The thermostats consist of two basic units: the Display Control Unit (DCU) and the Power Supply Unit (PSU). While all line-voltage wiring is terminated at the PSU, all connections between the DCU and PSU are of low-voltage signaling wires

Wiring and Application Notes

- Cut jumper JP1 open if external sensor is wired to SR1 and GND. Run the wiring away from any electrical motors or power wiring. Failure to do so may result in poor thermostat performance due to electrical noise.
- 22 or 24 AWG twisted shielded pair double-insulated cable is recommended as remote sensor wiring and its length must not exceed 25 m.
- Connecting wires between Display Control Unit and Power Supply Unit must not exceed 15 m.
- Do not bundle and run power wiring and remote sensor wiring in the same conduit.
- When an individual TE10-1 sensor is employed in each

- thermostat, the seasonal changeover sensor should be wrapped around the supply water pipe when associated with a water system. When the changeover sensor temperature exceeds 30°C, the thermostat enters into heating mode.
- Seasonal changeover sensor or switch is applicable to cool only or heat only 2-pipe models only.
- Unoccupied contact closure activates unoccupied mode.
- Window contact closure activates thermostat lockout mode.
- Hidden-line wiring for Terminals V2 and 6 are applicable to dual-output models only.
- The thermostat outputs are designed for controlling zone valves. If used for controlling electric heaters, external contactors must be used.

Wiring Diagram for Line-Voltage Fan and Line-Voltage On-Off Valve outputs

WARNINGIncorrect wiring connection may cause permanent equipment damages to the thermostat.

Piping Notes:

- On a single-output unit, V1 can be either a line-voltage cooling or a line-voltage heating 2-wire springreturn valve.
- On a dual-output unit, V1 must be a line-voltage cooling 2-wire spring-return valve and V2 a linevoltage heating 2-wire springreturn valve.


Fan Coil

Unit

Fan Motor

Hi Med Lo

V1



Wiring Diagram for Line-Voltage Fan and 24 VAC 2-Wire On-Off Valve Outputs

WARNING


Incorrect wiring connection may cause permanent equipment damages to the thermostat.

Piping Notes:

- On a single-output unit, V1 can be either a 24 VAC cooling or a 24 VAC heating 2-wire springreturn valve.
- On a dual-output unit, V1 must be a 24 VAC cooling 2-wire springreturn valve and V2 a 24 VAC heating 2-wire spring-return valve.

Fan Coil Unit

Fan Motor



WARNING


Incorrect wiring connection may cause permanent equipment damages to the thermostat.

Piping Notes:

- 1. V must be a line-voltage 3-wire floating valve.
- In cooling mode, V1 output opens valve on temperature rise and V2 output closes valve on temperature drop. The action in heating mode is reversed.

Fan Coil Unit

Fan Motor



Wiring Diagram for Line-Voltage Fan and Single 24 VAC 3-Wire Floating Valve Output

WARNING


Incorrect wiring connection may cause permanent equipment damages to the thermostat.

Piping Notes:

- 1. V must be a 24 VAC 3-wire floating valve.
- In cooling mode, V1 output opens valve on temperature rise and V2 output closes valve.on temperature drop. The action in heating mode is reversed.

Fan Coil Unit

Fan Motor



Wiring Diagram for Line-Voltage Fan and Dual Line-Voltage 3-Wire Floating Valve Outputs

WARNING

Incorrect wiring connection may cause permanent equipment damages to the thermostat.


Piping Notes:

- 1. Both Vc and Vh must be line-voltage 3-wire floating valves.
- 2. Vc must be a cooling valve and Vh a heating valve.

Fan Coil

Unit

Fan Motor




Wiring Diagram for Line-Voltage Fan and Dual 24 VAC 3-Wire Floating Valve Outputs

WARNING

Incorrect wiring connection may cause permanent equipment damages to the thermostat.

Piping Notes:

- 3-wire floating valves.



Wiring Diagram for Line-Voltage Fan and 0-10 VDC Valve Outputs

WARNING

Incorrect wiring connection may cause permanent equipment damages to the thermostat.


Piping Notes:

- On a single-output unit, V1 can be either a cooling or a heating valve.
- On a dual-output unit, V1 must be a cooling valve and V2 a heating valve.

Fan Coil

Unit

Fan Motor Hi Med Lo



Wiring Diagram for Line-Voltage Fan, 0-10 VDC Cooling Valve Output and **Line-Voltage On-Off Heating Output**

WARNING

Incorrect wiring connection may cause permanent equipment damages to the thermostat.

Piping Notes:


- 1. Vc must be a 0-10 VDC cooling
- H must be an electric contactor and connected to line-voltage terminals Vh and N.

Fan Coil Unit

Fan Motor

Hi Med Lo

Vc



Mega Controls Limited

Room 2505, Trend Centre;

29 Cheung Lee Street, Chai Wan, Hong Kong Phone: +852 2896 7277 Fax: +852 2896 7234 E-mail: sales@megacontrols.com Website: www.megacontrols.com