

BNT50 Series

RS-485 Modbus RTU Room Thermostats with LCD for Fan Coil Units

Features

- Ultra slim wall-mount unit to match any décor
- Supports Modbus RTU protocol
- Supports standalone operation on RS -485 communication failure
- Fan coil application database preloaded
- Large easy-to-read Liquid Crystal Display (LCD), with LED backlight
- A stylish bi-directional rotating dial and two compact touch keys to provide ease of operation
- Choice of constant display of ambient temperature or temperature set point value
- Output relays employed for direct connection of valve actuators and 3speed fan
- Configurable operating parameters
- Choice of °C or °F temperature display via parameter setup menu
- 2-wire on-off, 3-wire floating and 0(2)-10 VDC output models available
- Adjustable proportional band and integral time for 3-wire floating and 0 (2)-10 VDC output models
- Choice of valve stroke time for 3-wire floating output models
- Field adjustable high and low occupied set point limit settings
- Field adjustable cooling and heating unoccupied set point values (applicable to some models only)
- Choice to retain last entered settings on power resumption
- Dual-output on-off and 0-10 VDC models with auto cooling/heating changeover (deadband operation) and manual override
- Choice of operating sequence for dual -output models
- Adjustable 1 to 5 K deadband for dual -output models
- Unoccupied mode capability with field adjustable cooling and heating set points, not available to "1M", 1AM" and "1FM" models.
- Choice of unoccupied mode activation in operating mode only or in both standby and operating modes
- Provides one additional digital input for function such as remote night setback, service/filter alarm or motion

detection

- Choice of fan action in unoccupied mode
- Choice of auto fan action in heating mode
- Field recalibration capability of measured temperature
- Continuous or auto fan operation
- External and seasonal changeover temperature sensor capability
- Optional infra-red remote control unit
- Optional special faceplate color available on request

General

The BNT50 Series RS-485 networking room thermostats use the communication technologies of Modbus RTU protocol to monitor and supervise fan coil units in the heating, ventilating and air-conditioning industry, and employ a simple master/slave protocol. All BNT50 Series thermostats are slaves in this protocol, and can be under the control of a Mega Controls BACnet gateway, of either BMG or BMGE Series, called the master. The BMGs and BMGEs are native BACnet devices and communicate using the BACnet MS/TP or BACnet-over-Ethernet protocol.

Net 2 port of the BMG master and all slaves are daisy-chained through a RS-485 Modbus RTU network. The maximum number of NT50 slaves in a Modbus RTU network is 32.

Each BMG has 2 addresses. Net 2 address is always 0 which is the address of the Modbus RTU network. Net 1 address is the MAC address of the BACnet MS/TP network which is also set up for a maximum of 32 devices in a trunk cable length not exceeding 1000 m. The BMG gateway spontaneously detects the presence of slaves that go online in its NET 2 network.

If more than 32 BMGs are needed in the system, an additional BACnet system device is required for the second BACnet MS/TP network.

Each BMGE gateway is available with two RS-485 networks. Each network



can support up to 32 BNT50 Series Modbus RTU devices. The BMGE gateway spontaneously detects the presence of slaves that go online in its NET 1 and NET 2 networks. The BNT50 Series thermostats cover a wide range of fan coil applications, including 2 and 4-pipe fan coils and direct connection to 3-speed fans. Temperature sensing can be from a built-in room sensor or a remote sensor.

A fan-speed control touch key allows control of a 3-speed fan. The speed control key has 4 positions: "Hi-Med-Low-Auto". In the "Hi", "Med" or "low" position, the fan runs continuously at the selected speed. In the "Auto" mode, the fan speed is temperature dependent and controlled automatically at 2 K differential increments from low to high speed.

Mounting

The thermostats can be flush mounted or secured to a standard European 75 x 75 x 47 mm (strongly recommended) electrical box. See Fig. 2: Mounting Details. Two mounting screws are included.

Orderina

To order, specify complete model numbers.

Specifications

Product model numbers	See Fig.1: BNT50 Series Model Nu		
Power requirements	110-230 V, +10% and -15%, 50/60		
Operating temperature differential (for 2-wire on-off models)	Fixed at 1 K for both cooling and heating modes		
0-10 VDC output impedance	Minimum 10,000 Ω		
Temperature display range		cy ±1 K (41-95°F in 0.5 R increments, accuracy ±1 R)	
Temperature setpoint range		ictory setting at 22°C (41-95°F in 0.5 R increments)	
Offset adjustment of temperature indication (field recalibration)	+2, +1, 0, -1 and -2 K (+2, +1, 0, -1	and -2 R) throughout the range, factory setting 0	
Deadband of dual-output models	Adjustable 1 to 5 K(2 to 10 R) between	een cooling Mode and heating Mode, factory set at 3 K(6 R)	
Valve stroke time for 3-wire floating models	Accumulatively 10 to 240 s maximu	m in one direction in steps of 10 s, factory setting 180 s	
Proportional band for PI control	Adjustable 1 to 10 K (1-10 R) in 1 K	(1 R) increments, factory setting 5 K (5 R)	
Integral time for PI control	Adjustable 0 to 30 minutes in 1 min means integral time being turned of	ute increments, factory setting 15 minutes. Setting = 0 ff.	
Auto fan temperature differential	At 2 K (2 R) increments. At >0 K, fa mode depends on choice of auto fa	n is on low speed in cooling mode and fan status in heating an action.	
Sensing element	NTC thermistor, 10 kΩ@25°C; accu		
Unoccupied mode	Input signal from external voltage-fr	ree contact	
	Always runs at "Low" fan when in operation		
Unoccupied temperature set point range (not applicable to "1M" models)	Field adjustable 5-35°C (41-95°F) in 1 K (1 R) increments separately for cooling and heating; Factory settings: 16°C (61°F) for heating and 26°C (79°F) for cooling		
Binary input	1 binary input for external voltage-free contacts		
Digital outputs	For direct connection of valve actuators (110-230 VAC)		
	1 relay output for 2-pipe models		
	2 relay outputs for 4-pi	·	
	For direct connection to 3-speed fans (110-230 VAC)		
	3 relay outputs		
RS-485 communication speed	Baud rate fixed at 19,200 bps		
Device MAC addressing	01-32 via parameter setup menu, factory default setting 255 (displays as FF on thermostat screen)		
Proprietary Modbus RTU network guideline	Maximum 32 devices and maximun	n 1,000 m cable length	
Enclosure	Material: Self-extinguishing, molded	I ABS	
	Finish: Off white housing and dark of	grey faceplate	
Electrical ratings	Valve output relays	110-230 V, 3 A resistive, 1 A inductive, 50/60 Hz	
	Fan output relays		
	For on-off and floating models	110-230 V, 3 A resistive, 1 A inductive, 50/60 Hz	
	For 0-10 VDC models	110-230 V, 5 A resistive, 2 A inductive, 50/60 Hz	
	Total rating	110 -230 V, 5 A maximum, 50/60 Hz	
Ambient/storage temperature limits	0 to 55°C/-30 to 50°C , 10 to 90% RH non-condensing		
Connectors	Non-removable line-voltage terminal blocks and removable low-voltage wire plugs		
Power wires	Wire size 1 mm ² or 18 AWG solid copper recommended		
RS-485 Communication Wires	22 or 24 AWG Twisted Shielded Pair Double-insulated Cable		
Ethernet communication wires	Cat 5e cable (twisted pairs)		
Sensor wires	22 AWG twisted shielded pair double-insulated cable		
Accessories and options	See Figure 8: Optional Accessories		
Agency approval	CE Mark compliant to EMC and Low Voltage Directives		
Shipping weight	0.2 kg (0.44 lb)		
Dimensions	Dimensions See Figure 4: Dimensions in mm		

The performance specifications above are nominal and subject to tolerances and application variables of generally acceptable industry standards.

The manufacturer shall not be liable for damages resulting from misapplication or misuse of its products.

Figure 1: BNT50 Series Model Number Selection Guide


BNT50 Series RS-485 Networking Room Thermostats Model Number Selection Guide (Complete Sets)				
BNT5	0	_	1M	R
Product Type	Power Supply	Separator	Control Type	Options
NT5 = NT50 Series	0 = 110-230 VAC		1 = Single 2-wire on-off output,	R = with infra-
RS-485			cool only or heat only	red receiver
Networking			1M = Single 2-wire on-off output,	for RCU-1
Room			manual cool/heat changeover	B = without
Thermostats			1A = Single 0(2)-10 VDC output,	buzzer for
			cool only or heat only	key touch
			1AM = Single 0(2)-10 VDC output, manual cool/heat changeover	sounding
			1F = Single 3-wire floating output,	
			cool only or heat only	
			1FM = Single 3-wire floating output,	
			manual cool/heat changeover	
			2 = Dual 2-wire on-off outputs,	
			manual or Auto cool/heat	
			changeover	
			2A = Dual 0(2)-10 VDC outputs,	
			manual or Auto cool/heat	
			changeover	

Figure 2: NT50 Series Application Guide

Model Numbers	Outputs	Applications	Cooling/Heating Mode	External Seasonal Changeover	System Modes	Fan Control	Unoccupied Mode
BNT50-1	Single 2-Wire On-Off	Cooling Only or Heating Only (2-Pipe System)	Auto Only	Yes	Cool or Heat-Fan Only-Off	Hi-Med-Low-Auto	Yes
BNT50-1M	Single 2-Wire On-Off	Cooling/Heating (2-Pipe System)	Manual Only	No	Cool or Heat-Fan Only-Off	Hi-Med-Low-Auto	Yes
BNT50-1F	Single 3-Wire Floating	Cooling Only or Heating Only (2-Pipe System)	Auto Only	Yes	Cool or Heat-Fan Only-Off	Hi-Med-Low-Auto	Yes
BNT50-1FM	Single Line-Voltage 3-Wire Floating	Cooling/Heating (2-Pipe System)	Manual Only	No	Cool or Heat-Fan Only-Off	Hi-Med-Low-Auto	Yes
BNT50-1A	Single 0-10 VDC	Cooling Only or Heating Only (2-Pipe System)	Auto Only	Yes	Cool or Heat-Fan Only-Off	Hi-Med-Low-Auto	Yes
BNT50-1AM	Single 0-10 VDC	Cooling/Heating (2-Pipe System)	Manual Only	No	Cool or Heat-Fan Only-Off	Hi-Med-Low-Auto	Yes
BNT50-2	Dual 2-Wire On-Off	Cooling and Heating (4-Pipe System)	Manual or Auto	No	Cool-Heat-Auto- Fan Only-Off Or Auto-Off	Hi-Med-Low-Auto	Yes
BNT50-2A	Dual 0-10 VDC	Cooling and Heating (4-Pipe System)	Manual or Auto	No	Cool-Heat-Auto- Fan Only-Off Or Auto-Off	Hi-Med-Low-Auto	Yes

Figure 3: Dimensions in mm

Figure 4: Mounting Details






Figure 5: Optional Accessories

Remote control unit RCU-1 Probe temperature sensor TE10-1 Duct temperature sensor TE10-2 With infra-red receiver capability BNT50-xxxR Without buzzer capability BNT50-xxxR	Description	Part No.
Duct temperature sensor TE10-2 With infra-red receiver capability BNT50-xxxR	Remote control unit	RCU-1
With infra-red receiver capability BNT50-xxxR	Probe temperature sensor	TE10-1
. , , =	Duct temperature sensor	TE10-2
Without buzzer capability BNT50-xxx <u>B</u>	With infra-red receiver capability	BNT50-xxxR
	Without buzzer capability	BNT50-xxx <u>B</u>

Network, Cabling and Step-down Transformer RequirementsTo ensure network stability and reliable communications, it is imperative that the following network, cabling and step-down transformer requirements are adhered to:

Item	Description	
Network Trunk Cabling	It is recommended to use networking cabling that matches the following specifications:	
	Balanced 100 to 120 ohms nominal impedance, 22 or 24 AWG Twisted Shielded Pair (TSP) Cable	
	Nominal capacitance of 52 pF/m or lower	
	Nominal velocity of propagation of 66% or higher	
	 Terminating the shield to ground at one end only for each isolated segment will prevent ground loops in the shield and drain RF energy to ground. Grounding at the BACnet router or controller is preferred. 	
10Base-T Cabling	Cat 5e cable with twisted pairs are recommended.	
Topology	Ensure the BACnet MS/TP or Modbus RTU network cable is installed as a daisy chain from one device to the next.	
Maximum Nodes	The maximum number of devices per BACnet MS/TP or Modbus RTU network is 32.	
Terminator	A terminator of 120-ohm impedance must be installed at each end of network segment, or two per network. Ensure that this requirement is not overlooked in laying out the network architecture and when ordering product.	
Cable Shielding	Use a shielded, twisted pair cable for communications. Never directly ground wire in more than one point on the shield. Doing so can induce large currents and result in communication problem.	
Repeater	A repeater is not necessary unless the BACnet MS/TP or Modbus RTU network is extended beyond 1,000 m.	
Step-down Transformer	A separate isolated double-wound transformer is recommended for supplying 24 VAC power to each BMG or BMGE. If and when the same transformer is shared with other devices, observe the polarities of the power supply of all devices including the BMG or BMGE.	

Figure 6: Network Configuration

BACnet MS/TP Network Notes:


- 1. Ensure the recommended balanced cable is used.
- Ensure the cable is installed as a daisy chain from one device to the next (1,000 m maximum) and the shield is grounded at one single point of the network only.
- 3. Ensure a MS/TP terminator is installed on each end of each MS/TP network.
- The maximum nodes per MS/TP network is 32 without a repeater.

Modbus RTU Network Notes:

- 1. Ensure the recommended balanced cable is used.
- Ensure the cable is installed as a daisy chain from one device to the next (1,000 m maximum) and the shield is grounded at one single point of the network only.
- 3. Ensure a terminator is installed on each end of each Modbus RTU network.
- 4. The maximum nodes per Modbus RTU network is 32

With BMG BACnet MSTP Gateway

To BACnet MS/TP



With BMGE BACnet-over-Ethernet Gateway




Figure 7: Jumper Settings


The models BNT50-2 and BNT50-2A can be re-configured in the field to other model numbers by a qualified servicing agent, if necessary, by changing the jumper positions of JP2 and JP3. The locations of these jumpers can be found after removing the thermostat cover from its baseplate.

Model Number	Jumper Settings of JP2 and JP3		
	JP2	JP3	
BNT50-1	Cut	Cut	
BNT50-1M	Cut	Cut	
BNT50-2	Uncut	Uncut	
BNT50-1F	Cut	Uncut	
BNT50-1FM	Cut	Uncut	
BNT50-1A	Cut	Cut	
BNT50-1AM	Cut	Cut	
BNT50-2A	Uncut	Uncut	

Jumper Settings of JP1 and JP4			
Jumper	Cut Uncut		
JP1	With Exter- nal Sensor	With Built- in Sensor	
JP4	For 2-10 VDC Output	For 0-10 VDC Output	

Note: JP4 is available in 0-10 VDC/2-10 VDC output models only. Factory setting is 0-10 VDC.

Note: Terminals V1+, GND and V2+ are only available in 0(2)-10 VDC output models.



Operation Notes

Operation

- LCD shows ambient temperature constantly except when set point adjustment is being made.
- Press the system key **Φ** to enter into the desired operating mode: Cool-Heat-Auto-Fan Only-Off, etc.
- Press the fan key ***** to change the fan speed mode: High-Med-Low-Auto.
- Increase or decrease temperature set point by rotating the adjustment dial clockwise or counter-clockwise. When the dial is rotated, the LCD shows the existing setpoint setting.

Unoccupied Mode

- When the unoccupied contact closes, it will override the operating mode and operate the thermostat in energy saving mode despite the thermostat being in operating or standby mode, depending on activation setting of unoccupied mode in setup menu.
- In unoccupied mode, the factory-set temperature cut-in points are 26°C for cooling and 16°C for heating. Meanwhile, all operating keys are locked out until the unoccupied contact opens.
- During unoccupied mode, the default fan speed is set at "low" when pre-set cut-in temperature is reached, or otherwise the fan output is always "off".
- Unoccupied mode can be activated in the following manner when the unoccupied contact closes: For 2-pipe models with auto seasonal changeover, the unoccupied cooling or heating mode is determined by the status of the SR2 seasonal changeover sensor and the valve output is activated according to the measured temperature.

For 2-pipe models with manual seasonal changeover, the unoccupied cooling or heating status is determined by the last status of the occupied mode and the valve output is controlled according to the measured temperature.

For 4-pipe models, the unoccupied cooling or heating mode is always determined by the measured temperature and valve output is also activated according to the measured temperature.

Unoccupied mode activation in operating mode only or in both standby and operating mode will be determined by activation setting in setup menu. Low fan will run according to fan action setting in setup menu.


Parameter Setup Mode

The thermostat allows authorized service agent to change a number of operating parameters in the field. Refer to the parameter setup manual for details.

Error reporting

All valve and fan outputs will be shut down when error is reported.

Figure 8: Network Control Unit and LCD Layout






Figure 9: Wiring Diagrams and Application Notes

Wiring and Application Notes

- Cut jumper JP1 open if an external sensor is wired to SR1 and GND. Run the wiring away from any electrical motors or power wiring. Failure to do so may result in poor thermostat performance due to electrical noise.
- 22 or 24 AWG twisted shielded pair double-insulated cable must be used as RS-485 communication wiring and its length must not exceed 1,000 m without a repeater
- 22 or 24 AWG twisted shielded pair double-insulated cable is recommended as remote sensor wiring and its length must not exceed 25 m.
- Do not bundle and run power wiring and remote sensor wiring in the same conduit.

- The seasonal changeover sensor should be wrapped around the supply water pipe when associated with a water system. When the changeover sensor temperature exceeds 30 °C, the thermostat enters into heating mode.
- External seasonal changeover sensor or switch is applicable to heat only or cool only 2-pipe models only.
- Unoccupied contact closure activates unoccupied mode.
- Hidden-line wiring is applicable to dual-output models only.
- The thermostat outputs of on-off models are designed for controlling zone valves. If used for controlling electric heaters, external contactors must be used.

Figure 10: BNT50 Series RS-485 Networking Room Thermostat Wiring Diagrams


WARNING

Incorrect wiring connection may cause permanent equipment damages to the thermostat.

Piping Notes:


- On a single-output unit, V1 can be either a 2-wire spring-return cooling or heating valve.
- On a dual-output unit, V1 must be a 2-wire springreturn cooling valve and V2 a 2-wire spring-return heating valve.
- V3 must be a 3-wire floating valve. In cooling mode, Terminal 6 output opens valve on temperature rise and Terminal 7 output closes valve on temperature drop. The action in heating mode is reversed.
- On a single-output unit, V4 can be either a 0-10 VDC cooling or heating valve.
- On a dual-output unit, V4 must be a 0-10 VDC cooling valve and V5 a 0-10 VDC heating valve.


Connections of Sensors and Contacts




Wiring Diagram for Single and Dual 2-Wire On-Off Valve Outputs

Wiring Diagram for Single 3-Wire Floating Valve Output





Wiring Diagram for Single and Dual 0(2)-10 VDC Valve Outputs



Mega Controls Limited

Room 1521A, Star House

3 Salisbury Road, Tsimshatsui, Kowloon, Hong Kong

WhatsApp Text & Call +852 5404 4590 E-mail: sales@megacontrols.com Website: www.megacontrols.com