

Wiring Diagram for Multiple-FCU Power Supply Units in Cascade Connections

Sensor wires: 22 or 24 AWG twisted shielded pair double-insulated cable

WARNING

Incorrect wiring connection may cause permanent equipment damages to the thermostat.

Piping Notes:

1. On a single-output unit, V1 can be either a cooling or a heating valve.
2. On a dual-output unit, V1 must be a cooling valve and V2 a heating valve.

