

THIS DOCUMENT IS THE PROPERTY OF ABU DHABI GAS DEVELOPMENT COMPANY LIMITED AND CONTAINS INFORMATION WHICH IS PROPRIETARY. THIS INFORMATION IS TO BE HELD IN CONFIDENCE. NO DISCLOSURE OR OTHER USE OF THIS DOCUMENT IS TO BE MADE WITHOUT THE PRIOR WRITTEN CONSENT OF ABU DHABI GAS DEVELOPMENT COMPANY LIMITED.

PLANT NUMBER

LINE SEQUENCE

SERVICE DESIGNATION (SEE BELOW)

LINE SIZE NOMINAL

PIPING SPECIFICATION

000 - 100 - HCX - 6" -

- S/FG []

50MM (2-3/8") (SR)

(0.500")

INSULATION PURPOSE/TYPE FIRST POSITION

A ACOUSTIC

AC COLD INSULATED WITH ACOUSTIC

AH HEAT CONSERVATION WITH ACOUSTIC

C COLD

CF COLD ANTIFROST

E ELECTRIC TRACED

F FIRE PROOFING

H HEAT CONSERVATION

HVB HOT INSULATED WITH VAPOR BARRIER

J STEAM JACKETED

N NONE

P PERSONNEL PROTECTION

S STEAM TRACE AND INSULATION

SECOND AND THIRD POSITION

FG FOAM GLASS

CS CALCIUM SILICATE

CALCULATED WALL THICKNESS (THICKNESS OR SCHEDULE)

INSULATION THICKNESS

STEAM TRACERS (QUANTITY AND SIZE)

STRESS RELIEVE (IF REQUIRED)

CORROSION ALLOWANCE - WHERE GREATER THAN THAT BUILT INTO APPLICABLE LINE SPECIFICATION

SHOWN ON FLOW SHEET (P&ID) AND ON LINE LIST

SHOW ON LINE LIST ONLY

SEGMENT BREAK

END GROUP

PRESS TEMP

PIPING MATERIAL CLASS-1

PIPING MATERIALS CLASS

INSULATION REQUIREMENTS

HEAT TRACING

SUPPLY BY

MAX OPER. TEMPERATURE (°C)

MAX DESIGN TEMPERATURE (°C)

MIN DESIGN TEMPERATURE (°C)

DESIGN PRESSURE (barg)

MIN DESIGN PRESSURE (barg)

FLUID CODE	SERVICE
AD	AREA DRAIN (SURFACE DRAINAGE)
BD	BLOWDOWN
CD	CLOSED DRAIN
CDC	CLOSED DRAIN CRYOGENIC
CH	CHEMICAL
FD	FIRE DELUGE
FGL	LOW PRESSURE FUEL GAS
FGM	MEDIUM PRESSURE FUEL GAS
FL	FLARE
FLC	COLD FLARE
FW	FIRE WATER
HC	HYDROCARBON
HCX	HYDROCARBON, SOUR
HFL	HIGH PRESSURE FLARE
IA	INSTRUMENT AIR
LFL	LOW PRESSURE FLARE
LS	LEAN SOLVENT
MOH	METHANOL
N2	NITROGEN
OD	OPEN DRAIN
PA	PLANT AIR
PW	POTABLE WATER
RW	RAW WATER
SCL	LOW PRESSURE STEAM CONDENSATE
SE	SEWAGE
STL	LOW PRESSURE STEAM (SATURATED)
STM	MEDIUM PRESSURE STEAM (SATURATED)
STS	SUPERHEATED HIGH PRESSURE STEAM
UW	UTILITY WATER
VE	VENT
VT	VESSEL TRIM

	INLET SCREEN MESH
	INLINE MIXER
	EXPANSION BELLWS
	PULSATION DAMPENR
	CALIBRATION POT
	ACCESS POINT
	VENT, 3/4", GATE VALVE (PLUGGED OR FLANGED)
	VENT, 3/4", GLOBE VALVE (PLUGGED OR FLANGED)
	VENT, 3/4", BALL VALVE (PLUGGED OR FLANGED)
	DRAIN, 3/4", GATE VALVE (PLUGGED OR FLANGED)
	DRAIN, 3/4", GLOBE VALVE (PLUGGED OR FLANGED)
	DRAIN, 3/4", BALL VALVE (PLUGGED OR FLANGED)

	INSULATED FLANGE
	ISOLATING JOINT
	INSULATING KIT
	OFF-DRAWING PIPING / INSTRUMENT CONNECTOR WITH REMARKS
	OFF-UNIT PIPING / INSTRUMENT CONNECTOR WITH REMARKS
	OFF-DRAWING CONNECTION UTILITY LINES BETWEEN PROCESS AND UTILITY P&ID'S
	CONNECTOR NUMBER ALPHABETIC SERVICE DESIGNATION
	ATMOSPHERIC VENT (WITH HOOD)
	ATMOSPHERIC VENT (HOOK TYPE)
	BIRD SCREEN
	FLAME ARRESTOR
	LINE DATA BREAK
	PIPING MATERIAL CHANGE
	VENT SILENCER
	CONDENSATE TRAPPING VENT HEAD

Z1	14/08/2014	IAB	ISSUE FOR AS BUILT	F.T.	N.F.	A.N.
02	30/06/2011	IFC	FINAL ISSUE FOR CONSTRUCTION	F.T.	D.L.	A.N.
01	03/02/2011	IFC	FIRST ISSUE FOR CONSTRUCTION	F.T.	D.L.	A.N.
00	29/11/2010	IFD	ISSUE FOR DESIGN	F.T.	N.F.	A.N.
B2	21/10/2010	IFH	ISSUE FOR HAZOP	F.T.	N.F.	A.N.
REV	DATE	STATUS	STATUS DESCRIPTION	BY	CKD	APP.

COMPANY:

Abu Dhabi Gas Development Co. Ltd.



الحسن للغاز
Al Hosn Gas
شركة أبوظبي للغاز والتنمية
Abu Dhabi Gas Development Company Ltd.

CONTRACTOR:



JOB No. 0320080

PROJECT:

SHAH GAS DEVELOPMENT (SGD) PROJECT

AS BUILT

AGREEMENT No. 13525201

DRAWING TITLE: PIPING & INSTRUMENT DIAGRAM UNIT 0500	
EQUIPMENT DESCRIPTION	PIPING SYMBOLS AND LEGEND - SHEET 2
TAG/ITEM No.	

CONTRACTOR DRG.No.	500-GD-B-08031	REV. Z1
COMPANY DRG.No.	PP05-0500-00-PID-8031	
SCALE: NONE	SIZE: A1	
	DOC CLASS: 1	