



**Water Analysis Report**  
**District Level Water Analysis Laboratory U.P. Jal Nigam (Rural)**  
**Address: Raya Road Sadabad, Hathras U.P. 281306**  
**Email Id: eeupjnrhathras@gmail.com**  
**TelephoneNo- 09151919435**

**Water Test Report**

|            |               |             |            |             |
|------------|---------------|-------------|------------|-------------|
| Report No: | UPJN/HAT/1878 | Issue Date: | 25.06.2026 | Page No.1-2 |
|------------|---------------|-------------|------------|-------------|

**Customer Details**

|                         |                                           |
|-------------------------|-------------------------------------------|
| Office Name and Address | GYAN ACADEMY JALESAR ROAD SASNI (HATHRAS) |
| Ref. Letter No. & Date  | 108/24.06.2026                            |

**Basic Details of Sample**

|                      |                             |                           |                               |
|----------------------|-----------------------------|---------------------------|-------------------------------|
| District             | Hathras                     | Block/Tahseel             | Sasni                         |
| Gram Panchayat       | Bijahari                    | Village                   | Bijahari                      |
| Habitation           | Bijahari                    | Location                  | Bijahari (Jalesar Road Sasni) |
| Water Source         | R.O                         | Sample Code               | HAT/1878                      |
| Quantity of Sample   | 1 litre                     | Sampling date             | 24-06-2026                    |
| Sample Received Date | 24.06.2026                  | S. collected by           | Arjun Singh                   |
| Sampling Method Used | As per IS 17614:Part-I 2021 | Sample Depositor          | Rohit Kumar                   |
| Analysis Start Date  | 24-06-2026                  | Analysis Completion date: | 25.06.2026                    |
| Temperature          | 25±3°C (26.7°C)             | Humidity %                | 50±15% (54%)                  |

| S. No. | Analysed Parameters (Unit of Measuremnet)      | Observed Value | Specification as per IS 10500:2012(SecondRevision) |                   | Ref. Methods of Analysis                                                      |
|--------|------------------------------------------------|----------------|----------------------------------------------------|-------------------|-------------------------------------------------------------------------------|
|        |                                                |                | Acceptable Limit                                   | Permissible Limit |                                                                               |
| 1      | 2                                              | 3              | 4                                                  | 5                 | 6                                                                             |
| 1      | Taste                                          | Agreeable      | Agreeable                                          | Agreeable         | IS 3025 (Part 8): 2023 (Qualitative Method)                                   |
| 2      | Odour                                          | Agreeable      | Agreeable                                          | Agreeable         | IS 3025 (Part 5): 2018 (Qualitative Method)                                   |
| 3      | pH (at 25°C)                                   | 7.39           | 6.5-8.5                                            | 6.5-8.5           | IS 3025 (Part 11): 2022, (Electrometric Method)                               |
| 4      | Colour (Hazen units)                           | 1              | 5                                                  | 15                | IS 3025 (Part 4): 2021 (Visual Comparison Method)                             |
| 5      | Turbidity (NTU)                                | 0.79           | 1                                                  | 5                 | IS 3025 (Part 10): 2023 (Nephelometric method)                                |
| 6      | Total Dissolved Solids, (at 180°C) Mg/l        | 615            | 500                                                | 2000              | IS 3025 (Part 16): 2023 (Gravimetric method)                                  |
| 7      | Chloride (as Cl), mg/l                         | 147.5          | 250                                                | 1000              | IS 3025 (Part 32): 2025 Argentometric method                                  |
| 8      | Total Alkalinity, (as CaCO <sub>3</sub> ) mg/l | 155            | 200                                                | 600               | IS 3025 (Part 23): 2023 (Potentiometric and indicator method)                 |
| 9      | Total Hardness, (as CaCO <sub>3</sub> ) mg/l   | 185            | 200                                                | 600               | IS 3025 (Part 23): 2019 (EDTA method)                                         |
| 10     | Calcium (as Ca), mg/l                          | 32.06          | 75                                                 | 200               | IS 3025 (Part 40): 2024 EDTA Titrimetric method                               |
| 11     | Sulphate (as SO <sub>4</sub> ), mg/l           | 38.41          | 200                                                | 400               | APHA 24rd Edition -4500-SO <sub>4</sub> Method E (Turbidimetric Method): 2023 |

|    |                                     |       |     |     |                                                                                |
|----|-------------------------------------|-------|-----|-----|--------------------------------------------------------------------------------|
| 12 | Nitrate (as NO <sub>3</sub> ), mg/l | 17.68 | 45  | 45  | APHA 24rd Edition -4500- NO <sub>3</sub> (Method B) (UV Screening method) 2023 |
| 13 | Iron (as Fe), mg/l                  | 0.37  | 1.0 | 1.0 | APHA 24rd Edition -3500-Fe Method B (Phenanthroline Method) 2023               |
| 14 | Fluoride (as F), mg/l               | 0.46  | 1.0 | 1.5 | APHA 24rd Edition -4500-F Method C (Electrode Method) 2023                     |
| 15 | Magnesium (as Mg) mg/l              | 35.23 | 30  | 100 | IS 3025 (Part 46)- 2023 (Volumetric method)                                    |

All These parameters are under NABL Scope, BDL-Below Detection Limit, NA- Not Analysed

Note 1. This certificate refers only to the particular sample(s) submitted for analysis.

2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.


3. The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.

4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.

5. Parameters above Permissible Limit are written in bold.

6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.

7. Sample is not Collected by Lab.

  
Munendra Kumar  
(Report prepared by)



Laboratory Details:

waterdistrictlab@gmail.com

\*\*\*\*\*END OF THE ANALYSIS REPORT\*\*\*\*\*