Kirchhoff calc report - Konkan Cloud - Pune Edge Phase 1

After fixes: 140 checks pass, 0 fail.

Item	Value
Revision	r2 - hash 187be57dab13b7fa
Topology	DR
Checks	pass 140, fail 0, warn 0, n/a 2
Fixes	R05:FA-01: Replace FA-01 with a parallel cable feeder (Cable feeder 8 x 1C 240 mm2 Cu per ph
Approved by	Priya Raman (Lead Electrical Engineer (Reviewer))

IEC-based, illustrative values, not for construction
Demo workspace - all companies, people and data are fictional