Addendum 1 to DC-HA-TS-001 Rev 0: Deccan AI Campus, Hall B

A1.1 The technical requirements DC-HA-TS-001 Rev 0, issued for Hall A, apply to Hall B without change.

A1.2 Hall B IT load: 6.336 MW in 48 racks of 132 kW.

A1.3 Bids are due by 13 November 2026, 17:00 IST.

A1.4 Clause §2.3 is unchanged: equipment on site no later than 26 weeks from contract award.

Issued by Deccan Compute, Procurement.

IEC-based, illustrative values, not for construction
Demo workspace - all companies, people and data are fictional