

Project:			
Serial No.:		Brand:	Richford
Product Model:	RF19601	Place of Origin:	PRC
Product Description:	Basin Mixer		
Color:	Chrome	Size:	35mm (G3/8")





AG49401



Construction Material

建築物料



Note: All recommended installation dimension are for reference only

Address: Shop B, G/F, Sing Kong Building, 233 Lockhart Road, Wan Chai, Hong Kong.

Tel: +852-2559 8008 Fax: +852-2559 9008



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓48樓

48/F, Immigration Tower, 7 Gloucester Road, Wai Chai, Hong Kong

本署收悉 : (6) in WSD 3331/2022 T/J(1253/2022)
Our ref :
外函編號 :
Your ref :

電話 :
Tel :
傳真 : 2824 0578
Fax :

8 February 2023

Richford Group Limited
Shop B, G/F Sing Kong Building,
233 Lockhart Road,
Wanchai, Hong Kong

(Attn.: Mr Steven FU)

Dear Sir,

**Approval of "RICHFORD" Basin Mixer
(General Acceptance No. C20230054)**

Your letters dated 25 October 2022, 12 December 2022 and 6 January 2023 refer.

Having considered the test report ref. RRGIL008 issued on 5 October 2022 by Ideal Test Consultants Ltd, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Richford Group Limited
Country of Origin: the Mainland of China
Brand: Richford
Details of Fitting: 3/8" Single lever basin mixer
Model: RF19601
Body Markings: Richford
Expiry Date: 14 September 2027



2. 1/2" Bath/Shower mixer
Model: RF19604A

3. 3/8" Kitchen mixer
Model: RF19605A

Body Markings:

Richford

Expiry Date:	31 August 2022	(for model RF19601)
	25 July 2022	(for model RF19604A)
	24 July 2022	(for model RF19605A)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,

A handwritten signature in black ink, appearing to read 'm h' or similar, written in a cursive style.

(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only

用水效益標籤 Water Efficiency Label



用水效益級別
Water Efficiency Grade

1

水點愈少，用水效益愈高。
The fewer droplets, the more
water efficient.

牌子
Brand

Richford

型號
Model

RF19601

種類
Type

Mixing

耗水量 (公升 / 分鐘)

Water Consumption (litres / min)

4.6

登記號碼

Registration No.

TM 19-0302



水務署
Water Supplies Department

如需詳細資料，請登入 www.wsd.gov.hk 或致電 2824 5000
For more information, please refer to www.wsd.gov.hk or call 2824 5000