

Project:			
Serial No.:		Brand:	Richford
Product Model:	R202	Place of Origin:	PRC
Product Description:	Washdown Wall Hung Toilet		
Color:	White	Size:	(L)480mm x (W)365mm x (H)370mm




Washdown Wall Hung Toilet



P-trap 180mm Roughing-in

3/6 Litres Flush, Rimless


Soft close UF seat cover



WSD GA NO. C20210427F

WSD GA NO. C20210400F

MODEL NO. : JT118
CISTEN & BUTTON



JT38
Hanger for Wall Mounted Toilet



AG49401



Construction Material
建築物料

Note: All recommended installation dimension are for reference only

Address: Shop B, G/F, Sing Kong Building, 233 Lockhart Road, Wan Chai, Hong Kong.

Tel: +852-2559 8008 Fax: +852-2559 9008



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2021 T/J(554/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

23 April 2021

Asian Building Material Company
G/F., 184 Shanghai Street,
Yau Ma Tei, Kowloon,
Hong Kong

(Attn.: Mr Eric LEE)

Dear Sir,

**Approval of "OTTER" Float Operated Valve
(General Acceptance No. C20210427F)**

Your letter ref. WRC/21003 dated 7 April 2021 refers.

Having considered the test report ref. J26439 issued on 7 April 2021 by Nutek Systems (HK) Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Zhongshan Meitu Plastic Ind Co Ltd

Country of Origin: the Mainland of China

Brand: Otter

Details of Fitting: 1/2" Plastic float operated valve

Model: J43-X

Body Markings: **MEITU**

Expiry Date: 29 March 2026

Proviso: As the fitting has not been tested for use in contact with water intended for human consumption, the fitting can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fitting in flushing water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The flushing volume of the flushing valve should be adjusted to suit the design of the toilet bowl so that wastes can be cleared effectively by a single flush."

"The fitting should be used within the range of working pressures specified by the manufacturer." AND

"The installed fitting should not result in backflow of water that will contaminate the flushing water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in flushing water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(471/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

19 April 2021

Asian Building Material Company
G/F., 184 Shanghai Street,
Yau Ma Tei, Kowloon,
Hong Kong

(Attn.: Mr Eric LEE)

Dear Sir,

**Approval of "OTTER" Flush Valve
(General Acceptance No. C20210400F)**

Your letters both ref. WRC/21002 dated 16 March 2021 and 29 March 2021 refer.

Having considered the test report ref. J25843 issued on 16 March 2021 by Nutek Systems (HK) Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Zhongshan Meitu Plastic Ind Co Ltd

Country of Origin: the Mainland of China

Brand: Otter

Details of Fitting: 2" Plastic dual flush valve

Model: P61

Body Markings: **MEITU**

Expiry Date: 6 January 2026

Proviso: As the fitting has not been tested for use in contact with water intended for human consumption, the fitting can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fitting in flushing water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The flushing volume of the flushing valve should be adjusted to suit the design of the toilet bowl so that wastes can be cleared effectively by a single flush."

"The fitting should be used within the range of working pressures specified by the manufacturer." AND

"The installed fitting should not result in backflow of water that will contaminate the flushing water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in flushing water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only

Product Code : JT118




Plastic pneumatic dual flush
concealed cistern with internal
tank fitting, support hanger &
push button control

Capacity : 7.5/3 litres
6/3 litres
4.5/3 litres




Dimension : 345 x 320 x 139mm



J43X . 1/2" Side inlet float
operated valve
WSD Ref No : C20160600F



P61 2" Plastic dual flush
discharge valve
WSD Ref No : C20160812F




List of components

Cistern lid
Cistern body
Inlet valve (fitted)
Outlet valve
Pneumatic control (fitted)
Wall fixing bracket
Gasket

flush pipe
flush pipe coupling back nut
flush pipe sealing ring
pan flush inlet connector
screws (2)
wall plugs (2)

PROJECT	Item Code

PRODUCT SPECIFICATIONS

Description:	Hanger for Wall Mounted Toilet	Brand / Series:	MEITU
Origin:	P.R.C	Finish/Colour:	
Model No:	JT38	Dimension (mm):	
Specification:	- Bracket for wall hung toilet with fitting		
Supplier:			
Address:			
Contact Person:		Email:	
Tel:		Fax:	
Picture:	Drawing:		
 <p>厕缸螺丝及六角扳手</p> <p>底座A及框架螺丝配件</p>		<p>24-M12通牙</p> <p>螺孔倒角1.5X45°</p>	

Note: All recommended installation dimension are for reference only

用水效益標籤 Water Efficiency Label



用水效益級別 Water Efficiency Grade

1

水點愈少，用水效益愈高。
The fewer droplets, the more water efficient.

牌子

Brand

Richford

型號

Model

R202

種類

Type

Water Closet Pan

全沖水量 (公升/沖廁)

Water Flush Volume (Full) (litres/flush)

4.8

低沖水量 (公升/沖廁)

Water Flush Volume (Reduced) (litres/flush)

3.0

登記號碼

Registration No.

WC 21-0188



水務署

Water Supplies Department

如需詳細資料，請登入 www.wsd.gov.hk 或致電 2824 5000
For more information, please refer to www.wsd.gov.hk or call 2824 5000