

Scaffold GA3

Report of Results of Inspections of Scaffolds

Scaffold Owner:	Kingscroft Development Ltd	Signature:	
Scaffold Inspector:	Eamon Kelly	Signature:	
Site Address:	Bailey HI, Moathill, Navan, Co. Meath, Ireland	Location / Description of Scaffold:	No 4-9
Date & Time of Inspection:	2026-01-28 11:23:57		

Item Inspected	Condition (Include any defected found)	Corrections taken / required
Fondations	Good	None
Sole Boards	Good	None
Base plates & Base Jacks	Good	None
Standards	Good	None
Ledgers	Good	None
Transoms	Good	None
Tie Spacing & Capacity	None needed	None
Anchorage test results	None needed	None
Facade bracing	Good	None
Pian bracing	Good	None
Cross bracing	Good	None
Guard rails	Missing some in places	Replaced
Toe Boards	Missing some	Replaced
Decking / scaffold boards	Good	None
Scaffolding signs and tags	None on site	None
Loading in line with design / Manufacturer's instructions	Fair	None
Access / egress	Good	None
User behaviour / housekeeping	Fair	None

Item Inspected	Condition (Include any defected found)	Corrections taken / required
Unauthorised alterations	Some handrails took out and brackets missing on the bk of 4 house's	Replaced
Anticipated hazards (next 7 days)	None	None
Other (traffic, public, electriaty)	None	None

Other outcomes of inspection / Observation: None