


Scaffold GA3

Report of Results of Inspections of Scaffolds

Scaffold Owner:	Kingscroft Development Ltd	Signature:	
Scaffold Inspector:	Aidan Anthony Odwyer	Signature:	
Site Address:	KILCARN WOOD 2 , Kilcarn, Navan, Co. Meath, C15D2E7 , Ireland	Location / Description of Scaffold:	85-86
Date & Time of Inspection:	2026-07-17 07:16:13		

Item Inspected	Condition (Include any defected found)	Corrections taken / required
Fondations	All in good condition/no defects found	None needed
Sole Boards	All in good condition/no defects found	None needed
Base plates & Base Jacks	All in good condition/no defects found	None needed
Standards	All in good condition/no defects found	None needed
Ledgers	All in good condition/No defects found	None needed
Transoms	All in good condition/No defects found	None needed
Tie Spacing & Capacity	None fitted	None needed
Anchorage test results	No fitted	None needed
Facade bracing	None fitted	None needed
Pian bracing	Bracing all in good condition	None needed
Cross bracing	All in good condition	None needed
Guard rails	None fitted	None needed
Toe Boards	5 toe boards missing	Scaffolder to replace
Decking / scaffold boards	15 scaffolding boards not in good condition..	Scaffolder replaced the 15 boards
Scaffolding signs and tags	All in place and in good condition	None needed
Loading in line with design / Manufacturer's instructions	Yes	None needed

Item Inspected	Condition (Include any defected found)	Corrections taken/ required
Access / egress	All ladders and handrails in good condition/no defects found	None needed
User behaviour / housekeeping	Housekeeping not up to standard/block/brick/rubbish/rubble on work platforms	Needs general clean up
Unauthorised alterations	None found at present time	None needed
Anticipated hazards (next 7 days)	General clean up needed..	Work in progress
Other (traffic, public, electriaty)	All in good order	None at present time

Other outcomes of inspection / Observation: General clean up needed/some trip up hazards noted