

Certificate: Handover of Scaffolding to User

Use this certificate to record the particulars of the scaffolding that you have erected and communicate the capacity of the scaffolding to the User.

Site: Baileyhill / Moathill
Location: Block A
Date: 12/11/2025

Reference: - - - - - - - - - 1
Erected By: Ek scaff
Copies to: Ekscaff@gmail.com

Description of section of scaffolding to be handed over (use grid line and/or references to identify section)

Scaffolding around bottom of duplex and balconies

Maximum loading capacity of Working Platforms (in kg/bay, or for non-standard bays in kg/m²)

2.0kn m²

Maximum number of Working Platforms provided (do not exceed this number)

2

Number and loading capacity of Loading Platforms (include details of location & use restrictions - if any)

None

Identify the person responsible for making periodic inspections (to be agreed with the User / Client)

Ek scaff

Identify the person responsible for authorising modifications (to be agreed with the User / Client)

Ek scaff

Results of pull-out tests undertaken on ring bolt anchors (where used)

None

Detail the design information necessary to enable other competent people to make a full inspection of the scaffold during use (i.e. type and spacing of ties; plan bracing; ledger bracing; facade bracing)

None needed Scaffolding to k stage manual

We have: (tick when done)

- Erected the scaffolding in accordance with the details above and our quotation: ☒
- Inspected the scaffolding in accordance with our scaffolding inspection ☒
- Inspected the scaffolding and completed GA3 Form, or similar (attached) ☒

Signed:
Scaffolding Erector; or
Scaffolding Company

Ek

You must: (tick to confirm you understand)

- Make sure that the scaffolding is used in accordance with the details above ☒
- Not alter the scaffolding or overload the scaffolding during use ☒
- Make arrangements to have the scaffolding inspected at least every 7 days (see GA3 form) ☒

Signed:
Scaffolding User; or
Contractor

Ek