AP/AL: Allocation Project Type: Life / Health / Safety Category: Public Protection Location: Dillingham House District: Bristol Bay/Aleutians/Kuspuk (HD 37) Impact House District: Bristol Contact: Bob Ernisse Bay/Aleutians/Kuspuk (HD 37) **Appropriation:** Pre-Disaster Mitigation - Congressionally Directed Spending Projects **Brief Summary and Statement of Need:** The City of Dillingham relies on an aerated wastewater treatment lagoon system, constructed in 1989, which discharges an average of 150,000 gallons a day of treated domestic wastewater into the Nushagak River. According to the 2018 City Shoreline Emergency Bank Stabilization Environmental Assessment by the Army Corps, the Nushagak estuary shoreline is "highly erosive," with an erosion rate of 11-12 feet per year. The City of Dillingham is requesting funds to construct the necessary shoreline protection to avert the impending failure of the City of Dillingham's sewage lagoon. Funding: FY2024 FY2025 FY2026 FY2027 FY2028 Total 1002 Fed \$5,016,000 \$5.016.000 Rcpts Total: \$5,016,000 \$0 \$0 \$0 \$0 \$0 \$5,016,000 ☐ State Match Required ☐ One-Time Project Phased - new Phased - underway Ongoing 0% = Minimum State Match % Required ✓ Amendment Mental Health Bill **Operating & Maintenance Costs:** Amount Staff

Project Development:

Ongoing Operating:

One-Time Startup:

Totals:

FY2024 Request:

Reference No:

\$5,016,000

AMD 65035

Prior Funding History / Additional Information:

Project Description/Justification:

Snag Point Erosion Mitigation

A failure of the lagoon could have serious, long-term consequences, putting the community's health at risk from untreated sewage, as well as the salmon fisheries that the Bristol Bay Region relies on for subsistence and economic activity. This also threatens Grandma's House, an assisted living facility located just behind the lagoon on the bluff.

0

0

0

0

0

0