

Kind Attn: Ms. Tara Gearing E-Mail: taragearing@hotmail.co.uk	QREF 09/12/2025-10 SUBJECT: Supply and installation of ROOF EX. FAN PARTS Location: Main Majlis (Roof Top)
DATE: 09/12/2025	E-Mail: mes@mes.qa

Dear Ms. Tara,

Kindly find below scope of works:

Sr.	
1	Supply and installation of ROOF EX. FAN PARTS as per attached Motor For EX-1 & EX-3 burn-out & 1- Contactor defective
PRICE FOR ABOVE Q.R. 1,870 + 7%= <u>2,000 Q.R.</u>	

Delivery Period: 1 day to arrange material.

Payment Terms: 100% Advance payment

Validity of offer: 7 days

Metri Engineering Services W.L.L



DEFECTIVE PART DISCRIPTION

Equipment:-	EXHAUST FAN	Location:-	Main Majilis (Roof Top)
Part Name:-	Motor	Date:-	24/11/2025

DISCRIPTION OF ISSUE OBSERVED: - Received Complaint for smell at first floor , inspected and found that ,Motor For EX-1 & EX-3 burn-out & 1-Contactor defective , need to be replaced by new one.

PICTURE OF DEFECTIVE PART:-

PIC-1



PIC-2



PIC-3





TEL: +974 44685844, 44694917 | FAX: 44513270 | CR No.: 44356 | P.O. Box: 45657 | DOHA - QATAR
Email: arctic@accqatar.com, www.accqatar.com

Email: arctic@accqatar.com, www.accqatar.com

Dear Sir,

Thank you very much for your valued enquiry. We are happy to submit our best offer for supply of the items given below.

TOTAL

QR. ONE THOUSAND EIGHT HUNDRED SEVENTY ONLY

1,870.00

PAYMENT TERMS

CASH

✓

CDC

✓

PDC

OP

VALIDITY:

7-15 DAYS

DELIVERY

EX-STOCK SUBJECTED TO PRIOR SALE

PREPERED BY

MRS.NAHALA P F MOB - 77452563

CONTACT BY

MRS.FABINA MOB - 77736006

THIS DOCUMENT IS COMPUTER-GENERATED AND DOES NOT REQUIRE A SIGNATURE.

REV NO.00.F/AC/TRD/01