



METRI ENGINEERING SERVICES W.L.L.
مترى للخدمات الهندسية ذ.م.م

Kind Attn: Ms. Tara Gearing E-Mail: taragearing@hotmail.co.uk DATE: 13/12/2025	QREF 13/12/2025-2 SUBJECT: Fresh Air Duct Repair Location: Main Majlis (Dehumidifier Unit) E-Mail: mes@mes.qa
---	---

Dear Ms. Tara,

Kindly find below scope of works:

Sr.	
1	Fresh Air Duct Repair
PRICE FOR ABOVE Q.R. 374 + 7%= <u>400 Q.R.</u>	

Delivery Period: 1 day to arrange material.

Payment Terms: 100% Advance payment

Validity of offer: 7 days

Metri Engineering Services W.L.L



QUOTATION

Revision :
Offer No. : ETC/QT/28162
Customer : METRI ENGINEERING SERVICES

Date : 13-12-2025
Enquiry No. :
Mobile No. :

Address :
Attn :
Project Name :

Phone No. :
Fax No. :

Dear Sir,

Thank you for your enquiry, we are pleased to submit our offer as under:-

SI NO.	Part Number	Description	Qty	Unit	Rate	Amount
1	INS0202	ASAWA SMART PIR PANEL 20MMX1.2X3.95MTR-INDIA	2.00	Sheet	120.00	240.00
2	GEN1440	C PROFILE ALUMINIUM 1X4MTR	4.00	Nos	15.00	60.00
3	GEN3826	CONTACT ADHESIVE 600ML- POLYFIX	2.00	Nos	12.00	24.00
4	GEN10012	PAINT BRUSH 2"	2.00	Nos	4.00	8.00
5	TAP00361	ALUMINIUM PLAIN TAPE 3" -MAXCEL-	4.00	Roll	4.50	18.00
6	DCT0303	C-COAT 32-17 DUCT SEALANT GREY	6.00	TUBE	4.00	24.00

Revision :

Date : 13-12-2025

Offer No. : ETC/QT/28162

Enquiry No. :

Customer : METRI ENGINEERING SERVICES

Mobile No. :

		Total :	374.00
		Discount :	0.00
Amt In Words :	Qatar Riyal One Hundred Eighty-Seven Only	Net Amount in Qrs :	374.00
Payment Terms :	CASH		
Delivery Period :	Ex-Stock		
Validity :	3 Days [Upon expiration of the Validity Period, The Company is fully entitled to revise the given price		
Remarks :	1		
Notes :	Partial Orders Are Not Acceptable. Delivery schedule Has To Be Provided With P.O. To Avoid Delay in Delivery.		

Yours faithfully,



AZIZIA SHOWROOM
Showroom Incharge

Email: Salesaziziyah@etcdoha.com

Mohamed Anwar
(Managing Director)

























DEFECTIVE PART DISCRIPTION

Equipment:-	DE-Humidifier	Location:-	Main Majilis (Outdoor Machine Area)
Part Name:-	PIR DUCT	Date:-	12/13/2025

DISCRIPTION OF ISSUE OBSERVED: - During Service of condensing units noticed that **FRESH AIR DUCT** appears to be broken or fractured near its midpoint, this damage creates a direct & exposed opening, significantly increasing the risk of rainwater infiltration directly into Main Majilis basement mechanical room.

PICTURE OF DEFECTIVE DUCT: -

