



METRI ENGINEERING SERVICES W.L.L.
متري للخدمات الهندسية ذ.م.م

INVOICE

BILL TO
M/s Aamal Medical W.L.L.
Mr. Jiffri Nihmathulla
nihmath_mohd@aamalmed.com,aamalmed@aamalmed.com
Doha-Qatar
00974-44039550
PROJECT/SITE
AAMAL MEDICAL COLD ROOM

DATE
02/04/2025
INVOICE NO.
29002
PO NO.
POAM25000008



#	DESCRIPTION الوصف	QTY الكمية	UNIT PRICE سعر الوحدة	TOTAL PRICE السعر الإجمالي
1	Design, Supply, installation, Testing & Commissioning of 1 no Walk in Chiller Room to maintain temperature(+2°C) at all times.(Temp can be adjusted from the Control Panel), As per MES Quote -Ref # 9810-1-rev 2 20% Upon Completion as per PO	1	19400.00	19400.00
2				0.00
3				0.00
4				0.00
5				0.00
6				0.00
7				0.00
8				0.00
9				0.00
10				0.00
11				0.00

Remarks / Payment Instructions:

Beneficiary Details:

Mitri Engineering Services

Tel/Fax: +974 44459207

Doha - Qatar

Bank Details:

Bank Name: Commercial Bank of Qatar (Q.S.C.)

IBAN: QA64CBQA000000004580580187001

Account No.: 4580-580187-001

Swift code: CBQAQAQA

Branch: GRAND HAMAD STREET



SUBTOTAL	19400.00
DISCOUNT	0.00
Balance Due	QR19,400.00

Tel: 44459207 - Fax: 44780499 - P.O.Box: 23107

E-mail: mes@mes.qa - Web: www.mes.qa

Purchase Order

Supplier Name	METRI ENGINEERING SERVICES WLL
Attention	Fayez Metri
CC	MR. Fayez Metri

Ship to	Aamal Medical WH Location
	GWC WH, Bu-Salba, QA

AM PO Reference	POAM25000008
PO Date	
Tender Reference	Ref. #: 9810-1-rev2
Sales Quotation Reference	Ref. #: 9810-1-rev2
Supplier Quotation Number	SIC of Walk In Chiller Room
Customer PO Number	
Inco Terms	DDP
Payment Terms	30 Days
Shipping Marks	
Mode of Shipping	Road
PO Currency	QAR = Qatari Rial

Line	Item Code Number	Item Description	UOM	Delivery Date	Quantity	Unit Price	Total Price
1		Design, Supply, installation, Testing & Commissioning of 1 no Walk in Chiller Room to maintain temperature(+2°C) at all times.(Temp can be adjusted from the Control Panel), As per MES Quote -Ref # 9810-1-rev 2 Note- Provision to add a back-up refrigerator in future (modification of Control & Power Control Panel to suit the function of (1 Running System +1 Backup System) whenever a backup refrigeration system is added in the future Warranty: 1 year on all materials supplied and installed by MES + free preventive maintenance for the 1st year (PPM 4 Visit). Servicing other than MES authorized technician voids warranty. Sandwich Panels 5 years warranty.	Each		1	115,000.00	115,000.00
Total							115,000.00
Discount							18,000.00
Grand Total							97,000.00
Total Amount in Words		Ninety Seven Thousand Qatari Riyals And Zero Dirhams Only					



Note:

1. Payment Terms: 60% advance, 20% upon delivery of cooling units ,20% upon Completion
2. Delivery- 3 to 4 months from the date of your firm order along with the receipt of down payment provided the site is ready for installation
3. The Temp. can be adjusted from 0 to 20C deg as per the requirements.
4. 1 year on all materials supplied and installed including Condensing+Evaporator. Sandwich Panels 5 years warranty.

M
E
S

METRI ENGINEERING SERVICES W.L.L.
مترى للخدمات الهندسية ذ.م.م

Unit Commissioning Report

Customer's Name	Aamal Medical	Contract	POAM25000008	Date	27-03-2025
Address (Area)	Aamal Medical NEW WAREHOUSE	Commissioning Team.	Mohd Ashraf (HVAC/R Supervisor)		
Street			Ashok Rawat (Technician)		
Block			Md kaium (Technician)		
Unit Details	COLD ROOM -A (Refrigerantion Unit/Walk-In Chiller)				
Compressor Model (OUTDOOR):-	BITZER/ 4FES-5Y-40S	S.No:	1606705347		
Evaporator Model (INDDOR):-	THERMOWAY/TEC035.A13D580	S.No:	2312-0338		
PRE START CHECKS:		Yes CHC	No CHC	No (Explain)	
1. Condensate Drain Pipe Installed/insulated.		✓			
2. MCB /CONTACTOR/OL are of correct Size.		✓			
3. Filter Drier/sight glass/LP HP Installed		✓			
4. Suction Oil Trap Installed		✓			
5. Refrigeration pipe insulated/insulated		✓			
6. Vibration Isolators Installed		✓			
7. Room Cleared of all unwanted Materials		✓			
8. Sandwict panel/door installed/sealed properly		✓			
8. Sensors installaed at correct places.		✓			
POST START CHECKS:					
1. Record and check the following data against name Plate					
Unit Running Voltage (V) (P-N)	L1- 235 V		L2- 234 V		L3-235 V
Unit Running Voltage (V) (P-P)	L1-L2- 407 V		L2-L3- 408 V		L3-L1- 407 V
1) Compressor Amps.	7.50 AMPs				
Suction Pressure:-	45 psi		Discharge Pressure:-		280 Psi
2) .Evaporator Amps	E-1:- 1.85 Amps		E-2:-1.95 Amps		E-3:- 1.80 Amps
3) Defrost Heater.	Phase-1:- 5.0 Amps		Phase-2 :- 5.20 Amps		Phase-3 :- 5.30 Amps.
Temperature Set points :-	Cut-In		4 °C		Cut-out 2 °C
1. Evaporator fan motor Rotation Verified.	✓				
2. Condenser fan motor rotation Verified.	✓				
3. Recorded Cold room temperature : 2 °C					
Duration Of Comissioning :- 1 day.					
Supervisor Name & Signature:- Mohd Ashraf			Remarks		
 					

WORK COMPLETION CERTIFICATE

(This certificate is filled up by Maintenance team upon completion of the project)

Part 1. Project Information Sheet

Contractor Name : METRI ENGINEERING SERVICES WLL

Contract No./ LPO No. : POAM25000008

Contract Date : 09-01-2025

Scope of Work : Design, Supply, Installation, testing & commissioning of 1 no walk in chiller room to maintain temperature (+2°C) at all times. (As per MESQUOTE-REF#9810-1-rev02)

Project Address and Location : AAMAL MEDICAL NEW WAREHOUSE

Date of LPO:

09-01-2025

Actual date of Completion

27-03-2025

Part-2. Pre-Commissioning Check.

1. Debris are cleared up?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>
2. Works have been completed according to specification/contract?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>
3. Inspection/Functionality test has been done?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>
4. Leak test has been done for all joints.?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>
5. Inspection /functionality test has been done.?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>
6. All sensors installed properly ?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>
7. Additional Unit Provision has been provided As per contract ?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>

Part 3. (Attach photo of completed task)



Part 4. Warranty Terms

*1-year on all materials supplied & installed by MES + Free Preventative Maintenance for 1-year from date of commissioning.

*5-years warranty of Sandwich panels.

repair other than MES Authorized technician , Voids warranty.

NOTE:- Service or

Part 5. Sign Off

WORK COMPLETION AUTHORITY

I HEREBY CONFIRM THAT THE ABOVE PROJECT AS DEFINED, HAS BEEN PERFORMED AND COMPLETED IN FULL ACCORDANCE WITH PROCEDURES AND RECOMMENDATIONS.

AAMAL MEDICAL (Representative)	MES (Representative)
Name & Signature:	Name & Signature: Md. Ashraf

(AAMAL MEDICAL. Seal)

(MES Seal)

