



StormSewer Analysis Report

Project: Demo Trunk Line


IDF: $i = 60.0 / (t + 10.0)^{0.80}$ in/hr Design storm: 10-yr

Nodes: 4 Pipes: 3

Summary

All pipes flow open-channel; no surface flooding.

Profile Schematic (main stem)



Hydraulic Tables — Demo Trunk Line

=== STORM SEWER ANALYSIS ===

Pipe	From	To	Slope	Tc	i	Q	Cap	%Full	V	yn	HGLup	HGLdn	Status
			ft/ft	min	in/hr	cfs	cfs	%	ft/s	ft	ft	ft	
P1	N1	N2	0.0050	12.0	5.06	3.54	4.58	77.3	4.12	0.83	105.60	103.97	ok
P2	N2	N3	0.0052	13.2	4.85	6.79	7.60	89.4	4.86	1.11	103.97	102.49	ok
P3	N3	OUT	0.0067	14.1	4.71	8.48	12.97	65.3	5.75	1.03	102.49	100.50	ok

Node	Tc(min)	Rim(ft)	HGL(ft)	Freeboard	Status
N1	12.0	110.00	105.60	4.40	ok
N2	13.2	108.50	103.97	4.53	ok
N3	14.1	107.00	102.49	4.51	ok
OUT	14.6	106.00	100.50	5.50	ok

All pipes flow open-channel; no surface flooding.