


# TOP OF MEZZANINE



**A** 480VAC, 3P, 22 FLA, 30A TOTAL SERVICE, BG SUPPLIED LOCKABLE FUSED DISCONNECT AT CABINET ENTRY, CONDUIT TO CABINET

**B** 120VAC, 1P, 15A TOTAL SERVICE, L5-15R, EQUIPMENT USE

**E** 120VAC, 1P, 15A TOTAL SERVICE, QUAD BOX 5-15R, MIXED USE

**F** 120VAC, QUAD BOX, 2 CIRCUITS  
(2X) 1P, 15A TOTAL SERVICE, 5-15R, CONVENIENCE  
(2X) 1P, 15A TOTAL SERVICE, 5-15R, ORANGE, EQUIPMENT USE

**H** 480VAC, 3P, 2FLA, L16-20R

**1** (2X) CAT 6A, 1GIG CONNECTION REQUIRED, FOR OVER 100M MUST BE FIBER.  
TERMINATED AT INDICATED PANEL AND CONNECTED TO BG IDF CABINET.

SYMBOL LOCATIONS ARE FOR ELECTRICAL ROUGH IN. DROP LADDERS OR FLOOR HOLES  
SHALL BE INSTALLED AFTER OFFICIAL PLACEMENT OF EQUIPMENT.