



A 480VAC, 3P, 22 FLA, 30A TOTAL SERVICE, BG SUPPLIED LOCKABLE FUSED DISCONNECT AT CABINET ENTRY, CONDUIT TO CABINET

B 120VAC, 1P, 15A TOTAL SERVICE, L5-15R, EQUIPMENT USE

C 480VAC, 3P, 400A TOTAL SERVICE - TREW CONVEYOR POWER CABINET.

D 480VAC, 3P, 200A TOTAL SERVICE - TREW CONVEYOR POWER CABINET.

E 480VAC, 3P, 40FLA, 50A TOTAL SERVICE, BG SUPPLIED LOCKABLE FUSED DISCONNECT AT CABINET ENTRY, CONDUIT TO CABINET

E 120VAC, 1P, 15A TOTAL SERVICE, QUAD BOX 5-15R, MIXED USE

F 120VAC, QUAD BOX, 2 CIRCUITS
(2X) 1P, 15A TOTAL SERVICE, 5-15R, CONVENIENCE
(2X) 1P, 15A TOTAL SERVICE, 5-15R, ORANGE, EQUIPMENT USE

G 480VAC, 3P, 2FLA, L16-20R

1 (2X) RJ45 CAT 6A, 10G CONNECTION REQUIRED, FOR OVER 100M MUST BE FIBER.
CONNECTED AT INDICATED PANEL AND BG IDF CABINET.

2 (2X) RJ45 CAT 6A, CONNECTED FROM INDICATED TREW PANEL AND BG IDF CABINET.

* REFER TO BG/TJX SOW FOR IDF & MDF POWER AND DATA REQUIREMENTS.

** FUTURE STATION DROPS SHOWN FOR REFERENCE, RUN CABLES AT TJX DISCRETION.

*** SYMBOL LOCATIONS ARE FOR ELECTRICAL ROUGH IN. DROP LADDERS OR FLOOR HOLES SHALL BE INSTALLED AFTER OFFICIAL PLACEMENT OF EQUIPMENT.



**BERKSHIRE
GREY**

HEADQUARTERS – BEDFORD, MA
140 SOUTH ROAD, BEDFORD, MA
01730
(833) 848-9900

DATE 4/9/2025
DRAWN JD
APPROVED ECO-12510

SYSTEM POWER AND DATA DROPS, INCL FUTURE
4000 Oldfield Blvd, Pittston, PA 18640
RSPS/RPS - FACILITY DRAWING, PITTSSTON PROD

DWG 123045
SCALE DO NOT SCALE DRAWING

REV F
SECT. As Built
PREV. 3
SHEET 4
NEXT 5

THIS DRAWING IS THE PROPERTY OF
BERKSHIRE GREY INC. NEITHER THE
DRAWING NOR INFORMATION DERIVED FROM
IT IS TO BE GIVEN TO OTHERS. NO USE IS
TO BE MADE OF IT WHICH IS OR MAY BE
INJURIOUS TO BERKSHIRE GREY.