



(A) 480VAC, 3P, 30A TOTAL SERVICE, BG SUPPLIED LOCKABLE FUSED DISCONNECT AT CABINET ENTRY, CONDUIT TO CABINET

(B) 120VAC, 1P, 15A TOTAL SERVICE, L5-15R, EQUIPMENT USE

(C) 480VAC, 3P, 100A TOTAL SERVICE

(D) 480VAC, 3P, 200A TOTAL SERVICE

(E) *120VAC, 1P, 15A TOTAL SERVICE, QUAD BOX 5-15R, MIXED USE

(F) 120VAC, 1P, 15A TOTAL SERVICE, QUAD BOX 5-15R, EQUIPMENT USE

(G) *120VAC 1P, 15A TOTAL SERVICE, QUAD BOX 5-15R, CONVENIENCE

(H) 480VAC, 3P, 2FLA, L16-20R, EQUIPMENT USE

(1) DUAL CAT 6A, 1GIG CONNECTION REQUIRED, FOR OVER 100M MUST BE FIBER

(2) (2x) CAT 5E, CABLE TERMINATED AT PANEL

*CONVENIENCE OUTLETS TBD

DIMENSIONS TO CABINET CENTERS FOR ELECTRICAL ROUGH IN.
DROP LADDERS OR FLOOR HOLES SHALL BE INSTALLED AFTER
OFFICIAL PLACEMENT.