

FUSE REPLACEMENT CHART- REV G				
FUSE	PART NUMBER	VOLTAGE RATING	MAX AMPS	GOING TO
DISC110	LPCC-25	600VAC	25	Whole Cabinet
FU406	LPCC-6	600VAC	6	Field Conveyor A 480V Power
FU414	LPCC-6	600VAC	6	Field Conveyor B 480V Power
FU441	LPCC-8	600VAC	8	Slide Motor A 480V Power
FU448	LPCC-8	600VAC	8	Slide Motor B 480V Power
FU601	AGC-2-R	250VAC	2	PLC 24V Power
FU603	AGC-3-R	250VAC	3	PLC Output 24V Power
FU605	AGC-1-R	250VAC	1	Overfill Light Curtain Receivers, Place Light Curtains, and Job Complete Buttons
FU609	AGC-7-R	250VAC	7	Aisle HMI and Pick Station HMI
FU612	AGC-10-R	250VAC	10	Field Conveyor A and B Logic Power, Cleated Conveyors A and B Logic Power, Slide Motor A and B Logic Power
FU614	AGC-2-R	250VAC	2	Overfill Light Curtain Receivers A1, A2, B1, and B2
FU616	AGC-2-R	250VAC	2	Donor Barcode Scanner, Donor Retroreflective Sensor, Barcode Scanners A1, A2, B1, and B2
FU618	AGC-1-R	250VAC	1	PLC Safety Card Input 24V Power
FU620	AGC-1-R	250VAC	1	PLC Safety Card Output 24V Power
FU622	AGC-1/2-R	250VAC	0.5	Filter, Fan 24V Power
FU624	AGC-1/2-R	250VAC	0.5	Unmanaged Network Switch 24V Power
FU632	AGC-2-R	250VAC	2	Shuttle A and B 24V Power
FU634	AGC-3-R	250VAC	3	PLC I/O 24V Power
FU1403	LPCC-20	600VAC	20	Cleated Conveyors A and B 48V Power
FU1650	LPCC-7	600VAC	7	Shuttle A 72V Power
FU1660	LPCC-7	600VAC	7	Shuttle B 72V Power
Caution: Replace fuses with the equivalent <i>Type</i> and <i>Rating</i> as the fuses listed in the chart above				