



A 480VAC, 3P, 22 FLA, 30A TOTAL SERVICE, BG SUPPLIED LOCKABLE FUSED DISCONNECT AT CABINET ENTRY, CONDUIT TO CABINET

B 120VAC, 1P, 15A TOTAL SERVICE, L5-15R, EQUIPMENT USE

C 480VAC, 3P, 89.8 FLA, 200A TOTAL SERVICE

E 120VAC, 1P, 15A TOTAL SERVICE, QUAD BOX 5-15R, MIXED USE

F 120VAC, QUAD BOX, 2 CIRCUITS
(2X) 1P, 15A TOTAL SERVICE, 5-15R, CONVENIENCE
(2X) 1P, 15A TOTAL SERVICE, 5-15R, ORANGE, EQUIPMENT USE

H 480VAC, 3P, 2FLA, L16-20R

1 (2X) CAT 6A, 1GIG CONNECTION REQUIRED, FOR OVER 100M MUST BE FIBER.
TERMINATED AT INDICATED PANEL AND CONNECTED TO BG IDF CABINET.

2 (2X) CAT 6A, TERMINATED AT INDICATED PANEL AND CONNECTED TO BG IDF CABINET.

SYMBOL LOCATIONS ARE FOR ELECTRICAL ROUGH IN. DROP LADDERS OR FLOOR HOLES
SHALL BE INSTALLED AFTER OFFICIAL PLACEMENT OF EQUIPMENT.



**BERKSHIRE
GREY**

HEADQUARTERS - BEDFORD, MA
140 SOUTH ROAD, BEDFORD, MA
01730
(833) 848-9900

DATE 5/30/2025
DRAWN JD
APPROVED ECO-12375

ELECTRICAL POWER AND NETWORK DROPS
SAN PEDRO, CA
Berkshire Grey, Inc / HomeGoods

DWG 117960
SCALE 3/16" = 1'

REV **D**
SECT. As Built
PREV. 1
SHEET NEXT

THIS DRAWING IS THE PROPERTY OF
BERKSHIRE GREY INC. NEITHER THE
DRAWING, NOR INFORMATION DERIVED FROM
IT IS TO BE GIVEN TO OTHERS. NO USE IS
TO BE MADE OF IT WHICH IS OR MAY BE
INJURIOUS TO BERKSHIRE GREY.