



**Address: 1**

**Number of Units: 1**

Fixture Type	Count	Extended
Showers	1	1.2
Bathroom Sinks	0	0.0
Kitchen Sinks	0	0.0
Dish Washers	0	0.0
In-Unit Clothes Washer	0	0.0
Commercial Clothes Washer	0	0
Slop Sink	0	0

Total FU	GPM	Cv Required	Suggested Selection
1.20	9.68	3.66	Unable to calculate selection, please contact Paxton

This software is for apartment houses only. Please contact us for other applications.

To select a system, pick a valve with the closest Cv to the calculated required Cv. If the required Cv is between two options, it is generally suggested to go with the smaller size

Please feel free to reach out with any sizing questions or for selection help. We can be reached at:

By email: [paxton@paxtoncorp.com](mailto:paxton@paxtoncorp.com)

By phone: 718-650-5510

Model	Size	Cv	Selected for Calculated range of
TVS43-020	3/4"	7.3	5-9
TVS43-025	1"	11.6	10-15
TVS43-032	1 1/4"	18.5	16-25
TVS43-040	1 1/2"	29.0	26-37
TVS43-050	2"	46.3	38-54
TVS43-065	2 1/2"	65.0	55-75