



**Document Identifier: RearDoorHeatExchanger**

**Date: 2024-10-20**

**Version: 1.0.0**

# OCP Rear Door Heat Exchanger

**Supersedes: None**

**Document Class: Informational**

**Document Status: Published**

**Document Language: en-US**

**Copyright Notice**

Copyright © 2023-2024 OCP. All rights reserved.

NOTWITHSTANDING THE ENCLOSED LICENSES, THIS SPECIFICATION IS PROVIDED BY OCP "AS IS" AND OCP EXPRESSLY DISCLAIMS ANY WARRANTIES (EXPRESS, IMPLIED, OR OTHERWISE), INCLUDING IMPLIED WARRANTIES OF MERCHANTABILITY, NON-INFRINGEMENT, FITNESS FOR A PARTICULAR PURPOSE, OR TITLE, RELATED TO THE SPECIFICATION. NOTICE IS HEREBY GIVEN, THAT OTHER RIGHTS NOT GRANTED AS SET FORTH ABOVE, INCLUDING WITHOUT LIMITATION, RIGHTS OF THIRD PARTIES WHO DID NOT EXECUTE THE ABOVE LICENSES, MAY BE IMPLICATED BY THE IMPLEMENTATION OF OR COMPLIANCE WITH THIS SPECIFICATION.

OCP IS NOT RESPONSIBLE FOR IDENTIFYING RIGHTS FOR WHICH A LICENSE MAY BE REQUIRED IN ORDER TO IMPLEMENT THIS SPECIFICATION. THE ENTIRE RISK AS TO IMPLEMENTING OR OTHERWISE USING THE SPECIFICATION IS ASSUMED BY YOU.

IN NO EVENT WILL OCP BE LIABLE TO YOU FOR ANY MONETARY DAMAGES WITH RESPECT TO ANY CLAIMS RELATED TO, OR ARISING OUT OF YOUR USE OF THIS SPECIFICATION, INCLUDING BUT NOT LIMITED TO ANY LIABILITY FOR LOST PROFITS OR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT, SPECIAL OR PUNITIVE DAMAGES OF ANY CHARACTER FROM ANY CAUSES OF ACTION OF ANY KIND WITH RESPECT TO THIS SPECIFICATION, WHETHER BASED ON BREACH OF CONTRACT, TORT (INCLUDING NEGLIGENCE), OR OTHERWISE, AND EVEN IF OCP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGE.

CONTENTS

1 Scope . . . . . 4

2 Requirements . . . . . 5

3 Capabilities . . . . . 6

4 Use Cases . . . . . 7

    4.1 Get rear door heat exchanger info . . . . . 7

    4.2 Get primary connector info . . . . . 8

5 References . . . . . 10

6 Revision . . . . . 11

# 1 Scope

---

This document references requirements and provide the usage examples for the OCP Read Door Heat Exchanger API v1.0.0.

## 2 Requirements

---

As a Redfish-based interface, the required Redfish interface model elements are specified in a profile document. For the OCP Read Door Heat Exchanger API v1.0.0, the profile is located at:

The Redfish Interop Validator is an open-source conformance test that reads the profile, executes the tests against an implementation, and generates a test report in text or HTML format.

```
> python3 RedfishInteropValidator.py -u user -p password -r host:port profileName
```

The Redfish Interop Validator is located at <https://github.com/DMTF/Redfish-Interop-Validator>.

The OCP Read Door Heat Exchanger v1.0.0 profile extends from the OCP Liquid Cooling Baseline v1.0.0 profile. This extension is specified directly in the profile. This means that the specification requires conformance to the OCP Liquid Cooling Baseline profile in addition to any requirements specified in the OCP Read Door Heat Exchanger profile.

```
"RequiredProfiles": {  
  "OCPLiquidCoolingBaseline": {  
    "MinVersion": "1.0.0"  
  }  
},
```

## 3 Capabilities

---

The following use cases are enabled by conformance to this OCP Read Door Heat Exchanger profile. The OCP Read Door Heat Exchanger profile is extended from the OCP Liquid Cooling Baseline profile. For capabilities specified in the the OCP Liquid Cooling Baseline profile, see the "OCP Liquid Cooling Baseline Specification".

The following table lists the capabilities prescribed in the OCP Read Door Heat Exchanger profile.

Use Case	Management Task	Requirement
Inventory	<a href="#">Get rear door heat exchanger info</a>	Mandatory
Component Status	<a href="#">Get primary connector info</a>	Mandatory

## 4 Use Cases

This section describes how each capability is accomplished by interacting with the Redfish service.

### 4.1 Get rear door heat exchanger info

The `CoolingUnit` resource represents the functional view of the liquid cooling unit. For the full schema definition, see the `CoolingUnit` section of the reference guide in the [Redfish Data Model Specification](#).

```
GET /redfish/v1/ThermalEquipment/HeatExchangers/1

{
  "@odata.id": "/redfish/v1/ThermalEquipment/HeatExchangers/1",
  "@odata.type": "#CoolingUnit.v1_1_2.CoolingUnit",
  "Id": "1",
  "EquipmentType": "HeatExchanger",
  "Name": "Example Rear Door Heat Exchanger",
  "FirmwareVersion": "1.0.0",
  "Version": "0A",
  "ProductionDate": "2024-04-30T00:00:00Z",
  "Manufacturer": "Contoso",
  "Model": "RDHX6000",
  "SerialNumber": "489609023",
  "PartNumber": "329-23489-3498-0A",
  "UUID": "5ee175f7-7d0a-4775-a616-c5afd324dc55",
  "Status": {
    "State": "Enabled",
    "Health": "OK"
  },
  "Coolant": {
    "CoolantType": "Water",
    "SpecificHeatkJoulesPerKgK": 3.974,
    "DensityKgPerCubicMeter": 1030
  },
  "CoolingCapacityWatts": 50000,
  "EnvironmentMetrics": {
    "@odata.id": "/redfish/v1/ThermalEquipment/HeatExchangers/1/EnvironmentMetrics"
  },
  "PrimaryCoolantConnectors": {
    "@odata.id": "/redfish/v1/ThermalEquipment/HeatExchangers/1/PrimaryCoolantConnectors"
  },
  "LeakDetection": {
    "@odata.id": "/redfish/v1/ThermalEquipment/HeatExchangers/1/LeakDetection"
  },
  "Links": {
    "Chassis": [
```

```

    {
      "@odata.id": "/redfish/v1/Chassis/1"
    }
  ]
}

```

## 4.2 Get primary connector info

The `CoolantConnector` resource represents a coolant connector in a cooling unit. When subordinate to the `PrimaryCoolantConnectors` collection, it specifically represents a primary side connector. For the full schema definition, see the `CoolantConnector` section of the reference guide in the [Redfish Data Model Specification](#).

```

GET /redfish/v1/ThermalEquipment/HeatExchangers/1/PrimaryCoolantConnectors/1

{
  "@odata.id": "/redfish/v1/ThermalEquipment/HeatExchangers/1/PrimaryCoolantConnectors/1",
  "@odata.type": "#CoolantConnector.v1_0_2.CoolantConnector",
  "Id": "1",
  "Name": "Primary Side Connector 1",
  "Status": {
    "State": "Enabled",
    "Health": "OK"
  },
  "CoolantConnectorType": "Pair",
  "Coolant": {
    "CoolantType": "Water",
    "SpecificHeatkJoulesPerKgK": 3.974,
    "DensityKgPerCubicMeter": 1030
  },
  "RatedFlowLitersPerMinute": 35,
  "FlowLitersPerMinute": {
    "Reading": 41,
    "DataSourceUri": "/redfish/v1/Chassis/1/Sensors/PrimaryFlow"
  },
  "SupplyTemperatureCelsius": {
    "Reading": 28,
    "DataSourceUri": "/redfish/v1/Chassis/1/Sensors/PrimarySupplyTemp"
  },
  "ReturnTemperatureCelsius": {
    "Reading": 42,
    "DataSourceUri": "/redfish/v1/Chassis/1/Sensors/PrimaryReturnTemp"
  },
  "DeltaTemperatureCelsius": {
    "Reading": 14,

```



```
    "DataSourceUri": "/redfish/v1/Chassis/1/Sensors/PrimaryDeltaTemp"
  },
  "SupplyPressurekPa": {
    "Reading": 803,
    "DataSourceUri": "/redfish/v1/Chassis/1/Sensors/PrimarySupplyPressure"
  },
  "ReturnPressurekPa": {
    "Reading": 936,
    "DataSourceUri": "/redfish/v1/Chassis/1/Sensors/PrimaryReturnPressure"
  },
  "DeltaPressurekPa": {
    "Reading": 133,
    "DataSourceUri": "/redfish/v1/Chassis/1/Sensors/PrimaryDeltaPressure"
  },
  "HeatRemovedkW": {
    "Reading": 21.03,
    "DataSourceUri": "/redfish/v1/Chassis/1/Sensors/PrimaryHeatLoad"
  }
}
```

## 5 References

---

- [1] OCP Liquid Cooling Baseline Profile v1.0.0
- [2] "Redfish Specification" - [\*<https://www.dmtf.org/dsp/DSP0266>](<https://www.dmtf.org/dsp/DSP0266>)
- [3] "Redfish Data Model Specification" - [\*<https://www.dmtf.org/dsp/DSP0268>](<https://www.dmtf.org/dsp/DSP0268>)
- [4] "Redfish Interoperability Profiles Specification" - [\*<https://www.dmtf.org/dsp/DSP0270>](<https://www.dmtf.org/dsp/DSP0270>)

## 6 Revision

---

Revision	Date	Description
1.0.0	TBD	Initial release.