

Syntax : Code(Data)	
/ISk5\2ME382-1004  0-0:96.1.1(4B414C37303035313338323936303133) 1-0:1.8.1(00128.981*kWh) 1-0:1.8.2(00049.851*kWh) 1-0:2.8.1(00018.127*kWh) 1-0:2.8.2(00018.038*kWh) 0-0:96.14.0(0001) 1-0:1.7.0(0000.81*kW) 1-0:2.7.0(0000.00*kW) 0-0:17.0.0(0999.00*kW) 0-0:96.3.10(1) 0-0:96.13.1() 0-0:96.13.0() 0-1:24.1.0(3) 0-1:96.1.0(3238303131303031333038323834393133) 0-1:24.3.0(130505210000)(00)(60)(1)(0-1:24.2.1)(m3) (00023.536) 0-1:24.4.0(1) !	# meter type, begin of batch from port p1 # empty line # equipment identifier # total electric energy consumption tariff code "low" # total electric energy consumption tariff code "high" # total electric energy delivery tariff code "low" # total electric energy delivery tariff code "high" # tariff code 0=high, 1=low # current electric energy consumption in kW # current electric energy delivery in kW # max current/phase # switch # text message numeric 8 characters numeric # text message (max 1024 characters) # other devices on the M-bus # gasmeter identification # datetime of last gas reading # total gas consumption in m3 # gas throttle 0=closed, 1=open # "!" marks of batch