



DRAWN BY	CHECKED	CLIENT APPROVAL	DATE
SJM	ZW		
PROJECTION	SCALE	DRAWING NUMBER	PAGE
	A3 NTS	OPTI-0100-SP	1 OF 1
MODEL	QUANTITY	PROJECT	REVISION
OPTI 1500 LR	1		00



DIMENSIONS	MM	AIRFLOWS	L/S	CLEAN PA	ELECTRICAL REQUIREMENTS	POWER SUPPLY	WATT	PROPRIETARY FEATURES	QUANTITY	FILTRATION AND ADVANCED SYSTEMS	QUANTITY
LENGTH	1700	OPTIMUM EXHAUST	715	125	1. LIGHTING	240V1PH5A	48	7. SAFETY GLASS LIGHT DIFFUSER	1	15. VENTURI BAFFLE FILTER	4
WIDTH	1500	OPTIMUM SUPPLY	570	50	2. FILTRATION			8. REMOVABLE SUPPLY DIFFUSER	3	16. MICROCYCLONIC FILTER	3
HEIGHT	550	MAXIMUM EXHAUST	990	135	3. FANS			9. ACCURATE DAMPER SYSTEM	2	17. ULTRAVIOLET	
CLEAR HEIGHT	605	MAXIMUM SUPPLY	990	60	4. OTHER			10. GREASE COLLECTION CUP	1	18. OZONE INJECTION	
WEIGHTS	KG	SPECIFIC EXHAUST			LIGHTING	TEMPERATURE	LUMEN	11. ADJUSTABLE AIR KNIFE	1	19. ELECTROSTATIC	
PACKED	200	SPECIFIC SUPPLY			5. DIFFUSE LED SPOT	3000K	4080	12. PERIMETER AIR CURTAIN	3	20. HEAT RECOVERY CONDENSATOR	
FRAME LIFT	131	FILTERED EXHAUST EQUIVALENT			FIXING	TYPE	QUANTITY	13. PERSONAL COMFORT NOZZLE	6	21. COLD MISTING	
MAX IN USE	162	ADDITIONAL ROOM SUPPLY		BY OTHERS	6. FROM ABOVE	12MM DIA T304SS	4	14. ACCESS PANEL	1	22. WATER WASH	