

ELLIS & WATTS
BATAVIA, OH 45103

DOCUMENT NO. ENG-457 REVISION 9 (September 20, 2007)
~~8 (February 28, 2007)~~
~~7 (February 10, 2005)~~

ISSUE NO. _____

TITLE: INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4
GRADIENT WATER HEAT EXCHANGER

PREPARED BY:

Cathy A. Roundtree
CATHY A. ROUNDTREE

2/10/05

ENGINEERING
APPROVAL:

Troy J. Hall
TROY J. HALL

2/10/05

Q.A. APPROVAL:

Roger R. Schertler
ROGER R. SCHERTLER

2/10/05

DATE

THIS DOCUMENT/DRAWING IS THE PROPERTY OF ELLIS & WATTS INTERNATIONAL, INC. AND IS PROPRIETARY. IT SHALL NOT BE DUPLICATED OR REPRODUCED WITHOUT THE WRITTEN CONSENT OF E&W OR USED IN ANY MANNER DETRIMENTAL TO THE INTERESTS OF E&W AND THAT IT SHALL BE RETURNED TO ELLIS WATTS INTERNATIONAL, INC. UPON DEMAND

DOCUMENT NO. ENG-457

PAGE 1

REV.	PAGE	CHANGE RECORD	PREP. BY	ENG. APPVL.	Q.A. APPVL.
0	All	Original document released. (See cover sheet)			
1	5,7 6-12	Add information on power cable Add French and Spanish translations of warnings	BAA 01/26/99	KDD 01/26/99	RRS 01/26/99
2	5,7 9 10 11	Add GEMS PDU as exclusive power source Add reset procedure for time-delay relay Add low flow and cabinet access interlocks Add over-ride of cabinet access interlock	BAA 02/09/99	KDD 02/09/99	RJR 02/09/99
3	1 3 4,5,7, 8,9,11 12,14,19 4 5 6 7 8 8,11 11 11,12,13 13 14 15	Add G.E. part number. Revise Table of Contents. Add SI Units. Revise cooling capacity (Paragraph I). Add factory set-point temperature. (Para. I). Add pump dead-head pressure (Paragraph I). Add wet and shipping weights (Paragraph I). Revise maximum power requirement (Para. I). Add features (Paragraph I). Add min. facility supply pressure (Para. I). Revise input voltage (Paragraph I). Add electrical connector (Paragraph I). Add statement on installation of cabinet top (Paragraph 2-1). Add warning about magnetic field (Para. 2-1). Add installation requirements (Para. 2-2). Add warning about ethylene glycol (Paragraph 2-3). Add regulations compliance statement (Paragraph 2-3). Revise fluid connection labels (Para. 2-3). Add statement on switches (Para. 2-4 & 3-2). Revise flow capacity, thermal capacity, maximum ambient temperature (Para. 3-3). Add description to electrical and control design and components (Para. 3-3). Revise schedule for coolant level preventative maintenance (Para. 4-2). Add schedule for strainer preventative maintenance (Para. 4-2). Add setpoints for controls and interlocks (Paragraph 4-4). Expand troubleshooting guidelines (Para 4-5). Revise replacement parts list (Para. 4-6).	BAA 05/26/99	KDD 05/26/99	TJK 05/26/99
ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103			SIZE A	CAGE CODE 98437	
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER			DOCUMENT NO. ENG-457		PAGE 2 REV. 9

REV.	PAGE	CHANGE RECORD	PREP. BY	ENG. APPVL.	Q.A. APPVL.	
4	4,7,9 17,23 6 9 10 15 16 21 22	Add reference to Unit Assembly Drawing, T2583-0201. Add specifications for fuse for control transformer. Add to description of removal of cabinet top. Add location of air purge hose assembly. Add procedure for setting temperature controller and control valve. Correct temperature controller output voltage. Correct transformer part number. Add fuse block and fuse.	BAA 6/8/99	KDD 6/8/99	SEC 6/8/99	
5	4,7,9 17,23 4,9 11,12,13 15,18,19 20,22,23 16 22	Change drawing number of Unit Assembly Drawing. Change drawing number of Wiring Schematic. Correct control voltage for temperature controller and flow control valve. Change part numbers and quantites of quick disconnect assemblies.	BAA 11/16/99	KDD 11/16/99	RRS 11/16/99	
6	App.	Added drawings to the document	CAR 12/17/03	GAZ 12/17/03	RRS 2/17/03	
7	1	Added Proprietary Statement to cover page	CAR 2/10/05	TJH 2/10/05	ERS 2/10/05	
8	5 4-22 9, 12	Added power cord length requirement Corrected mis-numbered pages Added power switch to procedure	CAR 3/9/07	JKS 3/9/07	RRS 3/9/07	
9	17,18	Added 4-7 Removal Process for Mobiles	JAD 9/20/07	TJB 9/20/07	KAT 9/20/07	
ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103			SIZE A	CAGE CODE 98437		
			DOCUMENT NO.		PAGE	REV.
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER			ENG-457		3	9

TABLE OF CONTENTS

	<u>PAGE</u>
I. TABLE OF PARTICULARS	5
II. INSTALLATION.....	7
2-1 PREOPERATIONAL CHECK.....	7
2-2 INSTALLATION.....	8
2-3 CONNECTIONS.....	8
2-4 INITIAL FILLING	9
III. OPERATION	12
3-1 STARTING	12
3-2 STOPPING.....	12
3-3 THEORY OF OPERATION.....	12
IV. MAINTENANCE	14
4-1 GENERAL.....	14
4-2 PREVENTATIVE MAINTENANCE.....	15
4-3 SPECIAL TOOLS.....	15
4-4 CONTROL AND INTERLOCK SETPOINTS.....	15
4-5 TROUBLESHOOTING.....	17
4-6 REPAIR AND REPLACEMENT PARTS	17
4-7 REMOVAL PROCESS FOR MOBILES	17
 TABLES	
IV-1 CONTROL AND INTERLOCK SETPOINTS.....	16
IV-2 TROUBLESHOOTING.....	19
IV-3 REPLACEMENT PARTS	21
APPENDIX DRAWINGS	23
T2583-0101 INTERFACE CONTROL DRAWING, LTL-4	
T2583-0201-01 UNIT ASSEMBLY, LTL-4	
T2583-1201 PIPING SCHEMATIC, LTL-4	
T2583-1202-01 WIRING SCHEMATIC, LTL-4	

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437		
	DOCUMENT NO. ENG-457	PAGE 4	REV. 9	
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER				

I.
TABLE OF PARTICULARS

PERFORMANCE	
COOLING CAPACITY	4.5 KW, MAX.
GRADIENT COIL COOLANT SUPPLY TEMPERATURE	55-77°F (13-25°C)
FACTORY SETPOINT	64°F (18°C)
FREQUENCY	50-60 HZ
COIL COOLANT FLOW RATE	3.0 GPM (11 L/MIN.) MAX. @ 50 HZ, 3.5 GPM (13L/MIN.) MAX. @ 60 HZ MAX.
COIL COOLANT OUTLET PRESSURE	20-60 PSIG (140-410 KPA) NORMAL OPERATION 75 PSIG (520 KPA), MAX., PUMP DEAD-HEAD
RESERVOIR CAPACITY	1 GALLON (3.8 L)
OPERATING AMBIENT	50-113°F (10-45°C)
COIL COOLANT	35% ETHYLENE GLYCOL/65% DEIONIZED WATER BY VOLUME
CHILLED FACILITY COOLANT	50% ETHYLENE GLYCOL/50% DEIONIZED WATER BY WEIGHT
TEMPERATURE CONTROL	FACILITY COOLANT THROTTLING

MECHANICAL	
PUMP	CENTRIFUGAL, SINGLE STAGE, PLASTIC
COIL COOLANT/CHILLED FACILITY COOLANT HEAT EXCHANGER	STAINLESS STEEL, BRAZED PLATE
COIL COOLANT CIRCUIT MATERIAL	PLASTIC, STAINLESS STEEL, COPPER
CHILLED FACILITY COOLANT CIRCUIT MATERIAL	PLASTIC, STAINLESS STEEL, COPPER
PUMP INLET STRAINER	STAINLESS STEEL, 40 MESH
RESERVOIR MATERIAL	POLYETHYLENE
HOUSING AND BRACKETS	ALUMINUM
METAL FINISH	POWDER COAT
TEMPERATURE CONTROL VALVE	2-WAY BALL
WEIGHT	86 LBS (39 KGS) (DRY, NET SHIPPING) 98 LBS. (44 KGS) (WET) 140 LBS (64 KGS) (ESTIMATED GROSS SHIPPING)
SIZE	15" (380 MM) W X 17" (430 MM) L X 19" (480 MM) H WITH ISOLATOR FEET

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437		
	DOCUMENT NO. ENG-457		PAGE 5	REV. 9
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER				

ELECTRICAL	
POWER SOURCE (EXCLUSIVE)	PDU IN GEMS MRI SYSTEM, DEDICATED CIRCUIT BREAKER - 110/115VAC, 15A, 1PH, 50-60Hz
MAXIMUM POWER	1000 VA
PUMP MOTOR	1.0 HP (750 W)
MOTOR PROTECTION	THERMAL, 250°F (120°C) MAX. TRIP
POWER CABLE (BY OTHERS)	3 CONDUCTOR, 12 AWG, TYPE SO, FT4 FLAMMABILITY, WITH A 3-PIN, TWIST-LOCK, SOCKET CONNECTOR, MINIMUM LENGTH OF 4 FT., MAXIMUM LENGTH OF 10 FT.
FUSE, CONTROL TRANSFORMER, PRIMARY SIDE, "HIGH" LEAD	1 AMP, 125 VAC OR GREATER, "SLOW-BLOW"-APPROX. 1 SECOND AT 3.5 AMPS

FEATURES
COOLANT SUPPLY TEMPERATURE CONTROL
COOLANT SUPPLY TEMPERATURE READOUT
LOW COOLANT LEVEL INTERLOCK
LOW FLOW COOLANT INTERLOCK
HIGH-TEMPERATURE COOLANT INTERLOCK
CABINET SAFETY INTERLOCK
POWER INDICATOR LIGHT

SYSTEM REQUIREMENTS SUPPLIED TO THE LTL-4	
FACILITY CHILLED COOLANT:	
COMPOSITION	50±5% ETHYLENE GLYCOL/50±5% WATER BY WEIGHT
FLOW RATE	3.3 ± 0.3 GPM (12 ± 1 L/MIN.)
PRESSURE DROP INTERNAL TO LTL-4	8 PSID @ 3.0 GPM (55 KPA @ 11 L/MIN.)
INLET TEMPERATURE	52°F (11°C) , MAX.
INLET PRESSURE	20 PSIG (140 KPA), MIN., 50 PSIG (340 KPA), MAX.
FLUID CONNECTIONS	BARBS FOR 1/2" (13 MM) ID HOSE
POWER:	
VOLTAGE	110 VAC ± 10%

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437		
	DOCUMENT NO. ENG-457		PAGE 6	REV. 9
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER				

SYSTEM REQUIREMENTS SUPPLIED TO THE LTL-4	
CURRENT	12.5 A STEADY STATE AT 110 VAC, 60 HZ 75 A, IN-RUSH AT 110 VAC, 60 HZ
FREQUENCY	50 OR 60 HZ
PHASE	1
CONNECTION ON CABINET	HUBBELL 4716 C

II. INSTALLATION

2-1 PREOPERATIONAL CHECK

No special unpacking or handling procedures are required. Normal careful handling will prevent marring of the finish or damage to the electrical and fluid connections. Remove cabinet top and inspect system for dirt and loose wires. Inspect all components for dirt and loose packing materials. Refer to Ellis & Watts (E&W) Unit Assembly Drawing, T2583-0201-01. Check particularly the temperature controller and the pump/motor mount. Dirt and foreign matter can cause electrical shorting in the controller.

Check all electrical connections for loose wires. All wires shall be inspected for frayed or worn insulation. If any wires are found defective, they shall be replaced.

The cabinet top must be installed on the Model LTL-4 Gradient Water Heat Exchanger before it is delivered to the customer.

WARNING

RISK OF ELECTRIC SHOCK. CAN CAUSE INJURY OR DEATH. DISCONNECT ALL REMOTE ELECTRIC POWER SUPPLIES BEFORE SERVICING.

AVERTISSEMENT

RISQUE DE CHOC ELECTRIQUE POUVANT PROVOQUER DES BLESSURES OU LA MORT. DEBRANCHER TOUTES LES ALIMENTATIONS ELECTRIQUES EXTERNES AVANT L'ENTRETIEN.

ADVERTENCIA

RIESGO DE CHOQUE ELECTRICO. PUEDE CAUSAR LESIONES O LA MUERTE; DESCONECTAR TODO SUMINISTRO REMOTO DE ENERGIA ELECTRICA ANTES DE REALIZAR LABORES DE MANTENIMIENTO.

WARNING

CONTAINS FERROUS MATERIAL. PERSONAL INJURY COULD RESULT DUE TO STRONG ATTRACTION TO MAGNET.

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437		
	DOCUMENT NO. ENG-457		PAGE 7	REV. 9
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER				

AVERTISSEMENT

CONTIENT UNE MATIÈRE FERREUSE. UNE BLESSURE CORPORELLE POURRAIT ÊTRE PROVOQUÉE PAR LA FORTE ATTRACTION MAGNÉTIQUE.

ADVERTENCIA

CONTIENE MATERIAL FERROSO. LA FUERTO ATRACCIÓN AL IMÁN PODRÍA CAUSAR LESIONES PERSONALES.

2-2 INSTALLATION

The Model LTL-4 Gradient Water Heat Exchanger (GWHX) is designed to sit on its four, vibration-dampening, support feet. It should not be suspended by its top cover on vertical sides. The GWHX must be prevented from moving or tipping; one method is to band it to a vertical wall.

Ventilation air flow must not be restricted from passing through the cabinet louvers. One set of louvers on one side of the cabinet must be completely unblocked with no obstructions within 18 inches (460 mm) from the louvered side. The opposite set of louvers may be positioned against a SOLID vertical wall; however the louvers should not be placed against a soft (e.g., carpeted) vertical wall that might conform to the shape of the louvers and totally block air flow.

2-3 CONNECTIONS

WARNING

CHILLED COOLANT MUST BE SUPPLIED TO THE LTL-4 AT ALL TIMES THE GRADIENT COOLING WATER COIL PUMP IS OPERATING TO INSURE THAT THE PLASTIC HOSES ARE NOT OVER-HEATED BY PUMP HEAT OR HEAT FROM THE GRADIENT COIL.

AVERTISSEMENT

DU LIQUIDE DE REFROIDISSEMENT REFROIDI DOIT ÊTRE FOURNI A LT-4 EN TOUT TEMPS LORSQUE LA POMPE A BOBINE DE GRADATION D'EAU DE REFOIDISSEMENT FONCTIONNE, AFIN D'ASSURER QUE LES TUYAUX DE PLASTIQUE NE SOIENT PAS

SURCHAUFFES PAR LA CHALEUR DE LA POMPE OU PAR LA CHALEUR PROVENANT DE LA BOBINE DE GRADATION.

ADVERTENCIA

SE DEBERA SUMINISTRAR REFRIGERANTE ENFRIADO AL LTL-4 SIEMPRE QUE LA BOMBA DEL SERPENTIN DE AGUA PARA ENFRIAMIENTO ESCALONADO ESTE FUNCIONANDO PARA ASEGURARSE QUE LAS MANGUERAS PLASTICAS NO SE SOBRECALIENTEN DEBIDO AL CALOR DE LA BOMBA O AL CALOR DEL SERPENTIN DE GRADIENTE.

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437		
	DOCUMENT NO.		PAGE	REV.
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER	ENG-457		8	9

WARNING

CONTAINS ETHYLENE GLYCOL. HARMFUL OR FATAL IF SWALLOWED. CAUSES EYE IRRITATION. PROLONGED OR REPEATED BREATHING OF MIST OR VAPOR HARMFUL.

AVERTISSEMENT

CONTIENT DE L'ÉTHYLÉNEGLYCOL. NOCIF OU FATAL EN CAS D'ABSORPTION. PROVOQUE L'IRRITATION OCULAIRE. UNE INHALATION PROLONGÉE OU RÉPÉTÉE DE LA BUÉE OU VAPEUR EST DOMMAGEABLE.

ADVERTENCIA

CONTIENE ETILENGLICOL. NOCIVO O FATAL SI SE INGIERE. PRODUCE IRRITACIÓN DE LOS OJOS. LA INHALACIÓN PROLONGADA O REPETIDA DE VAHO O VAPOR ES NOCIVA.

Position the GWHX in its permanent location. The Model LTL-4 GWHX shall be used only as part of the General Electric Medical Systems (GEMS) Magnetic Resonance Imaging System. The unit shall be powered through the GEMS Power Distribution Unit (PDU). It is powered from a transformer secondary side; a dedicated, 15A, circuit breaker is used for the GWHX. All electrical connections must comply with all regulations in force at the location of operation.

Fluid line connections must be made to the GWHX inlet and outlet ports before the unit is filled. The chilled facility coolant inlet and outlet ports are 1/2" (13 mm) hose barb connections, labeled as "FACILITY CHILLED WATER RETURN" and "SUPPLY", respectively. Facility coolant is provided to the GWHX through the "RETURN" connection. The gradient cooling water coil (GCWC) connections are 1/2" (13 mm) hose barb connections, labelled as "COIL SUPPLY" and "RETURN". (See Ellis & Watts [E&W] Interface Control Drawing T2583-0101.) Check that all fluid lines in the complete system are tight. Any leakage will cause loss of pressure which will lower effectiveness of the system and cause failure.

Electrical power is supplied through the three-pin, twist-lock, socket connector. The power cable is a three-conductor, 12 AWG, Type SO cable with a FT4 flammability rating. The cable is supplied by others and must comply with all regulations in force at the location of operation and as listed in Electrical Requirements Table on page 6. Use the grounding stud to properly ground the GWHX. ON/OFF switching of the unit must be provided by the user external to the GWHX. (Refer to the Interface Control Drawing and the Wiring Schematic, E&W Drawings T2583-0101 and T2583-1202-01, respectively.)

2-4 INITIAL FILLING

This procedure outlines the steps for initially filling the Gradient Cooling Water Coil (GCWC) loop of the Gradient Water Heat Exchanger (GWHX). The procedure applies regardless of whether or not the gradient coil already contains coolant. Refer to Section 3-3 regarding the operation of the level switch, high-temperature limit thermostat, cabinet interlock switch and flow-switch. These interlock switches must be closed to operate the pump. Refer to E&W Unit Assembly Drawing, T2583-0201-01, for location of components. Note particularly that removing the cabinet top interrupts operation by opening the cabinet interlock switch. During filling and other maintenance,

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437		
	DOCUMENT NO. ENG-457		PAGE 9	REV. 9
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER				

the switch may be overridden by depressing the switch plunger. This may be accomplished using a weight, c-clamp, etc.

1. Remove the entire cabinet top, by removing four Phillips-head screws in each of two sides of the unit (eight screws, total).

Refer to Drawing T2583-0201-01.

2. Insure that the GCWC loop and the chilled facility coolant supply loop external to the GWHX contain no leaks or open vents.
3. Supply chilled coolant to the GCWC, insuring all air is purged from the lines.

WARNING

CHILLED COOLANT MUST BE SUPPLIED TO THE LTL-4 AT ALL TIMES THAT THE GCWC PUMP IS OPERATING TO INSURE THAT THE PLASTIC HOSES ARE NOT OVER-HEATED BY PUMP HEAT OR HEAT FROM THE GRADIENT COIL.

AVERTISSEMENT

DU LIQUIDE DE REFROIDISSEMENT REFROIDI DOIT ETRE FOURNI A LT-4 EN TOUT TEMPS LORSQUE LA POMPE A BOBINE DE GRADATION D'EAU DE REFOIDISSEMENT FONCTIONNE, AFIN D'ASSURER QUE LES TUYAUX DE PLASTIQUE NE SOIENT PAS

SURCHAUFFES PAR LA CHALEUR DE LA POMPE OU PAR LA CHALEUR PROVENANT DE LA BOBINE DE GRADATION.

ADVERTENCIA

SE DEBERA SUMINISTRAR REFRIGERANTE ENFRIADO AL LTL-4 SIEMPRE QUE LA BOMBA DEL SERPENTIN DE AGUA PARA ENFRIAMIENTO ESCALONADO ESTE FUNCIONANDO PARA ASEGURARSE QUE LAS MANGUERAS PLASTICAS NO SE SOBRECALIENTEN DEBIDO AL CALOR DE LA BOMBA O AL CALOR DEL SERPENTIN DE GRADIENTE.

4. Fill the GWHX reservoir to within 1.5 to 2 inches (38 to 51 mm) from its top, so that the level in the reservoir is above the pump discharge connection.
5. Connect the air purge hose assembly supplied with the GWHX to the access valve at the pump discharge. Secure the opposite end of the purge hose in the reservoir. The air purge hose assembly is stored inside the cabinet, attached using a Velcro strap.
6. Start the GCWC pump by applying power to the unit.
7. Observe the pump suction hose between the reservoir connection and the pump suction connection. If a large air slug(s) is observed in the hose and the coolant does not appear to be flowing, disconnect power to the GWHX (pump), immediately.

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437		
	DOCUMENT NO. ENG-457		PAGE 10	REV. 9
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER				

WARNING

EXTENDED OPERATION OF THE PUMP WITHOUT PROPER COOLANT FLOW TO THE PUMP MAY DAMAGE THE PUMP.

AVERTISSEMENT

LE FONCTIONNEMENT PROLONGE DE LA POMPE SANS CIRCULATION ADEQUATE DE LIQUIDE DE REFROIDISSEMENT EN DIRECTION DE LA POMPE PEUT ENDOMMAGER LA POMPE.

ADVERTENCIA

LA OPERACION PROLONGADA DE LA BOMBA SIN EL FLUJO ADECUADO DE REFRIGERANTE HACIA LA BOMBA PODRIA DANAR LA BOMBA.

8. Observe the coolant level in the reservoir. If necessary, add coolant to maintain the level above the pump discharge connection. However, do not fill the reservoir above 1.5 to 2 inches (38 to 51 mm) below the top of the reservoir.
9. Allow time for any air slugs in the suction hose to migrate into the pump, so the suction hose is completely filled with coolant.
10. After an additional 10 seconds, re-apply power to operate the pump.
11. Repeat Steps 7 through 10 to purge the air from the GCWC loop through the air purge hose. Depending on the volume of the loop, ten to fifty iterations may be required. Some coolant will be pumped through the air purge hose along with the air slugs into the reservoir. Note that the coolant level in the reservoir drops as air is purged from the loop.
12. After noticeable air slugs have been purged from the loop, operate the pump for an additional 10 minutes with the air purge hose connected.
13. Shut-off power to the GWHX.
14. Remove the air purge hose assembly. Install the access valve cap and the reservoir cap.
15. Install the cabinet top.
16. Re-start the GWHX and observe the coolant level in the reservoir. If necessary, add or remove coolant through the access panel in the housing top until the final coolant level is approximately at the midpoint between the "ADD" and "FULL" lines.

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437		
	DOCUMENT NO. ENG-457		PAGE 11	REV. 9
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER				

III. OPERATION

3-1 **STARTING**

To start the GWHX, simply make the proper power connection to the power socket and turn the power switch on. Refer to E&W Drawing T2583-1202-01, Wiring Schematic.

If the GWHX is automatically stopped by the built-in interlock for coil coolant low-flow, a time-delay relay must be reset before the unit can be re-started. The reset is accomplished by: 1) removing and re-installing the cabinet top to exercise the cabinet access interlock switch, or 2) unplugging and plugging-in the electrical inlet plug.

Upon initial start-up, use a properly calibrated flow meter to check the fluid flow rate of the GCWC coolant and the chilled facility coolant. Note that the flow-rate of the chilled coolant will be restricted by the two-way control valve if full capacity is not being called-for.

WARNING

THE PUMP IS A CENTRIFUGAL PUMP. IF THE OUTLET IS EXCESSIVELY RESTRICTED, THE OUTLET PRESSURE CAN RISE TO DAMAGING PRESSURE.

AVERTISSEMENT

CETTE UNITE EST UNE POMPE CENTRIFUGE. SI LA SORTIE EST EXCESSIVEMENT OBSTRUEE, LA PRESSION DE SORTIE PEUT S'ELEVER A UN NIVEAU DOMMAGEABLE.

ADVERTENCIA

LA BOMBA ES UNA BOMBA CENTRIFUGA. SI SE RESTRINGE LA DESCARGA DE MANERA EXCESIVA, LA PRESION DE DESCARGA PUEDE ELEVARSE HASTA UN NIVEL DANINO.

3-2 **STOPPING**

The GWHX is stopped by either disconnecting the power cable at the socket connector or by shutting-off the power remotely. If the cabinet top is removed, the safety interlock switch will also stop the unit.

3-3 **THEORY OF OPERATION**

The GWHX is a system designed as a liquid-to-liquid heat transfer system. The system consists of a supply system for ethylene glycol coolant to the GCWC, reservoir and a heat exchanger cooled by a chilled ethylene glycol/water mixture. The system circulates a minimum of 3 GPM (11 l/min) of GCWC coolant at a maximum system outlet pressure of 60 PSIG (410 KPa) at 60 Hz and at a minimum outlet temperature of 55°F (13°C) while operating in an ambient temperature up to 113°F (45°C). The GCWC coolant is circulated through a gradient coil, where it absorbs a maximum of 15,400 Btu/hr (4.5 kw), generated by the equipment. The fluid then returns to the heat exchanger, where heat is transferred to the chilled facility coolant.

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437		
	DOCUMENT NO. ENG-457		PAGE 12	REV. 9
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER				

The fluid circuits are shown schematically in the E&W Piping Schematic, Drawing T2583-1201. Coolant returning from the gradient coil enters the GWHX through the "COIL RETURN" connection. A standpipe-type reservoir is included to accommodate thermal expansion, provide a readily-accessible fill port and enable purging of air from the system. The pump takes coolant, by suction, from the "RETURN" connection and discharges into the heat exchanger through a 40-mesh strainer. Hot gradient coolant is therefore supplied from the pump to the heat exchanger and cold gradient water is returned from the heat exchanger. Heat is transferred in the heat exchanger to the chilled facility coolant flowing through the heat exchanger.

The electrical design is shown in the E&W Wiring Schematic, Drawing T2583-1202-01. Power (110 VAC $\pm$ 10%/1 phase/50-60 Hz/12.5 A) is supplied via a three-pin, twist-lock, socket connector. Power is distributed through a terminal block. Full voltage is supplied to the pump motor, through a contactor (closed when the coil is energized). The contactor coil is wired in series with a level switch, located in the reservoir, a high-temperature limit thermostat, a cabinet access interlock and a coil coolant flow switch. Thus, the pump stops if the pump or pump motor overheats, a low-level or low flow condition occurs or the cabinet top is removed. A 110 VAC/24 VAC transformer supplies power to the control circuit for the temperature controller, temperature display and two-way ball valve actuator.

The temperature of the coolant supplied to the GCWC is controlled by modulating the chilled facility coolant flow rate. A positive temperature coefficient, silicon sensor senses the actual coolant supply temperature. The operator dials-in the desired coolant supply temperature. The temperature control module compares the set-point and actual coolant supply temperatures. Using proportional plus integral logic, the controller supplies a 2-10 VDC signal to the actuator on the two-way, control, ball valve. The two-way valve adjusts to pass more chilled coolant through the heat exchanger if the actual temperature is greater than the set-point temperature and less chilled coolant through the heat exchanger if the actual temperature is less than the set-point temperature. The actual temperature is shown continuously on the temperature display module. A push button enables the set-point temperature to be displayed. Voltage and power requirements for the controller, display and actuator are shown on the Wiring Schematic, Drawing T2583-1202-01.

The green neon, power indicator lamp (IL) on the side of the cabinet is lighted when voltage is applied to the line-side contacts of the motor contactor (K1), to the primary side of the control transformer (T1) and across the following components which are wired in series: reservoir level switch (LS), high-temperature limit thermostat (TH), cabinet interlock switch (IS), flow switch (FS) and coil of the motor contactor (K1).

The level switch (LS) is located in the reservoir (R) for the coil coolant. It is positioned at approximately the one-third full level. If the coolant level drops below this level (for example, due to a leak in the coil coolant circuit), the level switch opens. This interrupts power to the coil of the motor contactor (K1), opens the contacts and stops the pump motor (P/M) to prevent the pump from overheating.

The high-temperature limit thermostat (TH) is fastened to the copper tee at the outlet of the brazed-plate heat exchanger (HX) for the coil coolant. The thermostat protects the pump (P/M) from overheating by opening if the coil coolant temperature rises above 100°F (38°C). This would occur if facility coolant flow is interrupted or its temperature increases significantly from approximately 52°F (11°C) to 85°F (29°C). The thermostat closes when cooled below 80°F (27°C) to enable the unit to again operate.

The cabinet interlock switch (IS) is a safety feature for personnel. When the cabinet top is removed, the switch opens and interrupts power to the coil of the pump motor contactor (K1). This causes the

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437		
	DOCUMENT NO. ENG-457		PAGE 13	REV. 9
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER				

pumps (P/M) to stop until the cabinet top is replaced. During servicing, the switch may be overridden by depressing the switch plunger using a weight, c-clamp, etc.

The flow switch (FS) is located in the coil coolant circuit, upstream of the pump (P/M) and reservoir (R). Its purpose is to protect the pump from overheating if coil coolant is interrupted (for example, by a leak in the coil coolant circuit). If coolant flow decreases below one gpm (3.8 l/min), the switch opens to interrupt power to the coil of the motor contactor (K1). This opens the contacts and stops the pump motor (P/M). To enable the pump to operate at initial start-up when no coil coolant is flowing, a time delay relay (TDR) is wired in parallel with the flow switch. It provides a closed electrical circuit "around" the flow switch until the pump can operate for a sufficient time to establish coolant flow greater than one gpm (3.8 l/min.). The relay is adjustable and is factory-set to remain closed for about 30 seconds. After 30 seconds, coolant flow is established through the flow switch to close it, the time delay relay opens and the pump continues to operate. If the flow switch opens at any time and stops operation of the unit, the time delay relay must be reset by cycling power to it, before operation can be resumed. Power to the relay can be cycled by any one of the following methods:

- 1) Dis-connect and re-connect the main power plug (P/S).
- 2) Removing and installing the cabinet top, i.e., cycle the cabinet interlock switch (IS).

IV. MAINTENANCE

WARNING

RISK OF ELECTRIC SHOCK. CAN CAUSE INJURY OR DEATH. DISCONNECT ALL REMOTE ELECTRIC POWER SUPPLIES BEFORE SERVICING.

AVERTISSEMENT

RISQUE DE CHOC ELECTRIQUE POUVANT PROVOQUER DES BLESSURES OU LA MORT. DEBRANCHER TOUTES LES ALIMENTATIONS ELECTRIQUES EXTERNES AVANT L'ENTRETIEN.

ADVERTENCIA

RIESGO DE CHOQUE ELECTRICO. PUEDE CAUSAR LESIONES O LA MUERTE; DESCONECTAR TODO SUMINISTRO REMOTO DE ENERGIA ELECTRICA ANTES DE REALIZAR LABORES DE MANTENIMIENTO.

4-1 **GENERAL**

The GWHX is designed to require a minimum amount of maintenance. To insure that the system is ready for operation at all times, it should be inspected periodically and systematically so that potential problems may be discovered and corrected before they cause serious damage or failure. Problems discovered during operation of the system shall be noted for future correction, to be made as soon as operation is ceased. Stop operation immediately if a deficiency is noted which would damage the equipment if operation were continued.

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437		
	DOCUMENT NO.		PAGE	REV.
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER	ENG-457		14	9

During maintenance, with the cabinet top removed, the cabinet access interlock switch may be overridden to enable the equipment to operate. Operation is achieved by depressing the switch plunger using a weight, c-clamp, etc.

4-2 PREVENTATIVE MAINTENANCE

The frequency of preventative, periodic checks may be determined based on actual experience in the operating environment.

The coolant level in the reservoir should be checked at three-month intervals. The strainer for the coil coolant should be checked for cleanliness at three-month intervals during normal operation. If the coolant loop is opened or the possibility of coolant contamination exists, the unit should be operated for one hour and the strainer should then be checked. No lubrication is required on this system.

4-3 SPECIAL TOOLS

No special tools are required. Normal tools kept by experienced heat exchanger equipment mechanics are sufficient.

4-4 CONTROL AND INTERLOCK SETPOINTS

The setpoints given in Table IV-1 are provided for the control components and interlocks to aid in troubleshooting the unit. In addition, test point voltages are shown on the Ellis & Watts Wiring Schematic, Drawing T2583-1202-01.

For the temperature controller, the temperature setpoint is adjusted via the labeled rotary knob located on the outside face of the controller. The throttle range, operation mode jumpers, integral control DIP switches and minimum output voltage are set inside the controller. The inside can be accessed by removing the front of the controller, by removing one Phillips-head screw in each of the four corners of the controller front face.

The throttle range is set using the rotary knob labelled "THROT RANGE." The operation mode jumpers are set at Position J1 on the circuit board. For direct action, each of the two jumpers should be oriented horizontally (across the circuit board). If necessary, pull the jumpers directly out of the circuit board, rotate 90° in either direction and re-insert into the circuit board. The DIP switches are four labeled slide switches, clustered together on the circuit board. The minimum output voltage is set using the rotary knob labeled "MIN OUTPUT." At the main terminal board (see E&W Drawing T2583-1202-01), connect a voltmeter across "V" and "C". Then, rotate the knob until 2 VDC is displayed at the voltmeter.

For the control valve for facility water, rotation position and range are set on the outside face of the actuator cover, using a flat-head screw driver. Rotation position refers to the direction of valve rotation with increasing control voltage supplied to the actuator by the temperature controller. Its setting should be "L". Rotation range limits the amount of valve travel and should be set at "100%".

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437		
	DOCUMENT NO.		PAGE	REV.
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER	ENG-457		15	9

TABLE IV-1
CONTROL AND INTERLOCK SETPOINTS

COMPONENT AND PARAMETER	SETPOINT
Temperature Controller	
Temperature Setpoint	18°C (64°F)
Throttle Range	13°F (7°C)
Operation Mode Jumpers	Direct Action
Integral Control DIP Switches	
1	Off
2	Off
3	Off
4	On
Minimum Output Voltage	0 VDC
Flow Control Valve (Facility Water)	
Range	
Closed (0% Cooling)	0 VDC
Open (100% Cooling)	10 VDC
Rotation	
Position	L
Range	100%
Time Delay Relay	
Delay Time	30 sec.
Flow Switch	
Flow Required For Closed Switch	> 1 gpm (3.8 l/min.)
Thermostat, High-Temperature Limit	
Open On Temperature Rise	100±7°F (38±4°C)
Close on Temperature Fall	80±7°F (27±4°C)
Cabinet Interlock Switch	
Closed	Plunger Depressed
Reservoir Level Switch	
Closed	Float Horizontal
Pump Motor	
Thermal Overload Trip Temperature	250°F (120°C), Max.
Pump	
Capacity	3 gpm @ 60 psig @60 Hz (11 l/min. @ 410 KPa @ 60 Hz), 2.5 gpm @ 40 psig @ 50 Hz (9.5 l/min. @ 280 KPa @ 50 Hz)
Dead-head Pressure	75 psig (520 KPa)

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE	CAGE CODE		
	A	98437		
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER	DOCUMENT NO.		PAGE	REV.
	ENG-457		16	9

4-5 TROUBLESHOOTING

A troubleshooting guide is provided in Table IV-2 to aid in identifying and correcting problems.

4-6 REPAIR AND REPLACEMENT PARTS


Due to the simplicity of construction of the GWHX, all of the major components are considered replaceable rather than repairable. Refer to Table IV-3 for the major components of the heat exchanger which may require replacement. Refer to the Unit Assembly Drawing, T2583-0201-01, for the location of these components. Ordinarily, replacement of a component shall take place only when found faulty through the use of the troubleshooting procedures found in Table IV-2.

4-7 REMOVAL PROCESS FOR MOBILES

The LTL4 chiller weighs 84 lbs (40kgs). The Hi-Jack Lifting Fixture must be used if one person is to replace the LTL4 chiller. The Hi-Jack Lifting Fixture is available from the GE Tools Depot. There is no part number for this device, it is known as the Hi-Jack, model A1. Alternative method to using the Hi-Jack is to use 2 persons to remove the LTL4 chiller from the mobile belly compartment.

- 1) Turn off power to the LTL4 chiller at the PDU.
- 2) Turn off power to the Main Mobile Chiller.
- 3) There are two shut-off valves that are in series with the LTL4 chiller Input and Output from the Main Mobile Chiller. Turn the two valves to the "closed" position.
- 4) Remove the power cord from the LTL4 Chiller
- 5) Remove four waterlines from the LTL4 Chiller.
- 6) With the LTL4 chiller free, position the chiller to be removed. See Picture 1.


PICTURE 1: CHILLER POSITION FOR REMOVAL



- 7) If the Hi-Jack Lifting Tool is not available, use 2 persons to remove the LTL4 Chiller from the Mobile belly compartment.
- 8) Position the Hi-Jack lifting fixture near the LTL4 Chiller. See Picture 2.

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437		
	DOCUMENT NO. ENG-457		PAGE 17	REV. 9
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER				

PICTURE 2: POSITIONING OF HI-JACK



- 9) Carefully move the LTL4 Chiller from the Belly compartment of the Mobile onto the Hi-Jack.
- 10) When the LTL4 Chiller is completely removed from the Belly compartment, lower the Hi-Jack as this will increase stability when moving the Hi-Jack.
- 11) Remove failed LTL4 Chiller from the Hi-Jack, and place the new LTL4 Chiller onto the Hi-Jack.
- 12) Re-install the replacement LTL4 chiller into the mobile by reversing the steps in the mentioned procedure.

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437	
	DOCUMENT NO. ENG-457	PAGE 18	REV. 9
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER			

TABLE IV-2
TROUBLESHOOTING

TROUBLE	PROBABLE CAUSE	REMEDY
1. Low GCWC coolant flow	a. Low coolant supply	a. Check coolant level in reservoir. Refill, if necessary. Check Probable Cause c.
	b. Constriction in system	b. Check all coolant lines and heat exchanger for blockage and remove.
	c. Leak in system	c. Check all coolant lines for leaks and repair.
	d. Pump/motor malfunction	d. Check pump and motor and replace, if necessary.
	e. Low voltage or frequency f. No power to pump motor	e. Check power and wiring and repair. f. Check operation of contacts in motor contactor. Replace contactor, if necessary. Check for power to coil in motor contactor. If no voltage, check operation of reservoir level switch, high-temperature thermostat, cabinet access switch, flow switch and time delay relay. Electrically isolate each component and verify its open/close operation. Refer to Wiring Schematic, E&W Drawing T2583-1202-01. Replace, if necessary.
2. High GCWC coolant temperature	a. Low coolant flow	a. See Trouble Item 1.
	b. Low chilled facility coolant flow	b. Check and repair lines for leaks, lines for blockage, operation of two-way control valve, operation of chilled coolant pump.
	c. High facility coolant temperature d. Temperature control system malfunction	c. Check facility coolant return temperature. Repair chiller, if necessary. d. Check controller, sensor and valve actuator for correct settings. Refer to Table IV-1. Check components for correct input voltage. Refer to Wiring Schematic E&W Drawing T2583-1202-01. Vary temperature setpoint at controller while monitoring control signal at actuator and observing motion of valve. If control signal does not change or is

ELLIS & WATTS INTERNATIONAL, INC.
BATAVIA, OHIO 45103

SIZE
A

CAGE CODE
98437

DOCUMENT NO.

PAGE

REV.

INSTALLATION, OPERATION AND MAINTENANCE MANUAL
FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER

ENG-457

19

9

TROUBLE	PROBABLE CAUSE	REMEDY
		erratic, replace controller. If actuator does not respond to correct control signal, replace actuator.
3. No flow from pump	a. No power to unit	a. Check power and wiring; repair or replace.
	b. No power to pump motor	b. Check operation of contacts in motor contactor. Replace contactor, if necessary. Check for power to coil in motor contactor. If no voltage, check operation of reservoir level switch, high-temperature thermostat, cabinet access switch, flow switch and time delay relay. Electrically isolate each component and verify its open/close operation. Refer to Wiring Schematic, E&W Drawing T2583-1202-01. Replace, if necessary.
	c. Pump/motor malfunction	c. Check motor and pump, and replace, if necessary.
4. Excessive power draw	a. Short in wiring	a. Check wiring; repair or replace. Refer to Wiring Schematic, E&W Drawing T2583-1202-01.
5. Low GCWC coolant pressure	a. Pump/motor malfunction	a. Check motor and pump, and replace, if necessary.
	b. Low power to system	b. Check power and wiring; repair or replace.

ELLIS & WATTS INTERNATIONAL, INC.
BATAVIA, OHIO 45103

SIZE
A

CAGE CODE
98437

DOCUMENT NO.

PAGE

REV.

INSTALLATION, OPERATION AND MAINTENANCE MANUAL
FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER

ENG-457

20

9

**TABLE IV-3
REPLACEMENT PARTS**

PART DESCRIPTION	REFERENCE DESIGNATOR(1)	E&W PART NUMBER	QTY. PER GWHX
Contactora	K1	T2590-216	1
Controller with sensor, temperature	TC,TS	T2517-64	1
Pump/Motor set	P/M	T2583-101	1
Heat Exchanger	HX	T2590-105	1
Reservoir	R	T2590-104	1
Valve with actuator	BV,VA	T2583-120	1
Strainer	SI	T2583-124	1
Inlet, electrical, twist-lock	P/S	T2583-201	1
Display, temperature	TD	T2583-202	1
Transformer	T1	J1476-201	1
Switch, level	LS	T2583-205	1
Terminal block	TB1	29-28-182	6
Access valve	V1	T2583-122	1
Tubing, 1/2-inch (13-mm) inside diameter	--	T2583-103	10 ft. (3050 mm)
Tubing, 3/4-inch (19-mm) inside diameter	--	T2583-125	2.5 ft. (760 mm)
Thermostat, high-temp. limit	TH	T2590-106	1
Switch, interlock	IS	T2590-214	1
Switch, flow	FS	T2590-201	1
Relay, time delay	TDR	T2590-202,203	1
Light, power indicator	IL	T2590-215	1
Sensor, temperature	TS	T2517-64-01	1
Actuator, valve	VA	T2583-120-01	1
Cap, reservoir	CR	T2590-104-01	1
Assembly, hose, air purge	--	T2583-141	1
Cap, access valve	CA	T2583-122-01	1
Fuse block	F1	J1476-202	1
Fuse	F1	J1476-203	1
Assembly, quick-disconnect			
Facility chilled water			
Plug with hose barb	--	T2590-111	2
Socket with bulkhead and hose barb	--	T2590-112	2
Coil coolant			
Supply: Plug with bulkhead and	--	T2590-114	1

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437		
	DOCUMENT NO. ENG-457		PAGE 21	REV. 9
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER				

PART DESCRIPTION	REFERENCE DESIGNATOR(1)	E&W PART NUMBER	QTY. PER GWHX
hose barb	--		
Return: Plug with bulkhead and hose barb	--	T2590-121	1
Socket with hose barb		T2590-113	2
(1) Refer to E&W Drawings T2583-1201 and T2583-1202-01.			

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437	
	DOCUMENT NO. ENG-457	PAGE 22	REV. 9
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER			

APPENDIX DRAWINGS

T2583-0101: INTERFACE CONTROL DRAWING, LTL-4
T2583-0201-01: UNIT ASSEMBLY, LTL-4
T2583-1201: PIPING SCHEMATIC, LTL-4
T2583-1202-01: WIRING SCHEMATIC, LTL-4

ELLIS & WATTS INTERNATIONAL, INC. BATAVIA, OHIO 45103	SIZE A	CAGE CODE 98437	
	DOCUMENT NO. ENG-457	PAGE 23	REV. 9
INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR MODEL LTL-4 GRADIENT WATER HEAT EXCHANGER			


NOTES:

1. ALL HOSES ARE BRAID-REINFORCED PVC.

REVISIONS				REVISED			
ZONE	LTR	DESCRIPTION	DATE (YR-MO-DA)	BY	APPROVED	ENGINEERING	O.A.
A		REVISED PER ECN #T2583-01	98-10-15	MJS	BAA	KDD	RRS
B		REVISED PER ECN #T2583-12	99-02-08	CMJ	BAA	KDD	RJR
C		REVISED PER ECN #T2583-15	99-02-17	MJS	BAA	KDD	TJK
D		REVISED PER ECN #T2590-03	99-05-25	MJS	BAA	KDD	TJK

LEGEND











- BU
BV
F
FS
HB
HX
LS
P/M
QD
R
SI
SW
TC
TD
TH
TS
V1
- UNION, BULKHEAD
BALL VALVE, 2-WAY
FILL CAP
SWITCH, FLOW, COIL COOLANT
HOSE BARB
HEAT EXCHANGER, BRAZED PLATE
SWITCH, LEVEL
PUMP/MOTOR SET
QUICK DISCONNECT
(WITH AUTOMATIC SHUT-OFF BOTH DIRECTIONS)
RESERVOIR
STRAINER
SIGHT WINDOW
CONTROLLER, COIL SUPPLY TEMPERATURE
DISPLAY, COIL SUPPLY TEMPERATURE
THERMOSTAT, HIGH-TEMPERATURE LIMIT
SENSOR, COIL SUPPLY TEMPERATURE
VALVE, SCHRADER, VENT



SYM	NOMENCLATURE	CAGE CODE	IDENTIFYING NO.	MATERIAL / SPECIFICATION	UNIT WT.	ZONE	FIND NO.
PARTS LIST							

PMIC		UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ARE FRACTIONS DECIMALS ANGLES ± N/A .XX = N/A ± N/A DO NOT SCALE DRAWING		CONTRACT NO.		TITLE ELLIS & WATTS CHICINNATI, OHIO PIPING SCHEMATIC LTL-4	
		DRAWN BY	DATE	CAGE CODE	DWG. NO.	REV.	
		MJS	98-09-30				
		CHECKER	ENGINEER				
		MJS 98-10-05	BAA 98-10-05				
		QUALITY ASSURANCE APPROVAL					
		RRS 98-10-05					
		ENGINEERING APPROVAL					
		KDD 98-10-05					
		MATL ENGR					
		USED ON					
		APPLICATION					
		12583-0201-01	LTL-4				
		NEXT ASSY					
		1					

THIS DRAWING IS CONFIDENTIAL AND IS THE PROPERTY OF ELLIS & WATTS. IT CONTAINS INFORMATION WHICH IS PROPRIETARY. IT SHALL NOT BE USED, DISCLOSED, DUPLICATED, REPRODUCED OR TRANSFERRED WITHOUT PRIOR WRITTEN PERMISSION OF ELLIS & WATTS.






VIEW "E-E"
HOSE AND HOSE BARBS
REMOVED FOR CLARITY

HOSE AND HOSE BARBS
REMOVED FOR CLARITY

REMOVED FOR CLARITY

THIS DRAWING IS CONFIDENTIAL AND IS THE PROPERTY OF
ELLIS & WATTS INTERNATIONAL. IT CONTAINS INFORMATION
WHICH IS PROPRIETARY. IT SHALL NOT BE USED, DISCLOSED,
DUPLICATED, REPRODUCED, OR TRANSFERRED WITHOUT PRIOR
WRITTEN PERMISSION OF ELLIS & WATTS INTERNATIONAL.



UNIT ASSEMBLY

HEAT EXCHANGER

LTL SERIES

PERFORMANCE

COOLING CAPACITY: 4.5 KW, MAX.
COOLANT SUPPLY TEMPERATURE: 55° F TO 77° F
FREQUENCY: 50 HZ TO 60 HZ
ALTITUDE: 100 FT BELOW TO 8000 FT ABOVE SEA LEVEL
FLOW RATE: 2.5 GPM TO 30 GPM AT 50 HZ, 3.0 GPM TO 3.5 GPM AT 60 HZ
OUTLET PRESSURE: 20 PSIG TO 60 PSIG

MECHANICAL

PUMP: CENTRIFUGAL, SINGLE STAGE, CPVC PLASTIC
COOLANT/COOLING FLUID EXCHANGER: BRAZED PLATE, SST
COOLANT CIRCUIT MATERIAL: PLASTIC, SST, COPPER
COOLING FLUID CIRCUIT MATERIAL: PLASTIC, SST, COPPER
PUMP INLET STRAINER: 40 MESH
RESERVOIR TYPE: POLYETHYLENE

MAXIMUM OUTLET PRESSURE: 60 PSIG
TEMPERATURE CONTROL VALVE: 2-WAY BALL
CABINET: ALUMINUM
METAL FINISHES: POWDER COAT
WEIGHT: 86 LBS. (DRY)

ELECTRICAL

POWER SOURCE: 110VAC, 1PH, 50 TO 60 HZ
MAXIMUM POWER: 1000 VA APPROX.
PUMP MOTOR: 1.0 HP

MOTOR PROTECTION: THERMAL


FEATURES

COOLANT SUPPLY TEMPERATURE CONTROL
COOLANT SUPPLY TEMPERATURE READOUT
QUICK-DISCONNECT FLUID COUPLERS WITH
AUTOMATIC SHUT-OFF BOTH DIRECTIONS,
POLARIZED COIL VS. CHILLER FLOW LOOPS


LOW COOLANT LEVEL INTERLOCK
LOW FLOW INTERLOCK
CABINET ACCESS SAFETY INTERLOCK
POWER INDICATOR LIGHT
HIGH-TEMPERATURE INTERLOCK

REVISIONS


ZONE	LTR	DESCRIPTION	DATE (YY-MM-DD)	BY	APPROVED	ENGINEERING APPROVED	O.A.
A		REVISED PER ECN #T2583-12	99-02-08	CMJ	BAA	KOD	RJR
B		REVISED PER ECN #T2583-13	99-02-10	CMJ	BAA	KOD	RRS
C		REVISED PER ECN #T2583-16	99-02-19	MS	BAA	KOD	RRS
D		REVISED PER ECN #T2590-04	99-04-29	CRJ	BAA	KOD	TK
E		REVISED PER ECN #T2590-53	07-03-05	MAF	CAR	JKS	KDA
F		REVISED PER ECN #T2590-54	07-03-21	MAF	MS	TJH	RRS



TOP



LEFT SIDE



FRONT

PARTS LIST

SYM	NOMENCLATURE	CAGE CODE	IDENTIFYING NO.	MATERIAL / SPECIFICATION	UNIT WT.	ZONE	FIND NO.
-----	--------------	-----------	-----------------	--------------------------	----------	------	----------

ELLIS & WATTS

CINCINNATI, OHIO

CONTRACT NO.


UNLESS OTHERWISE SPECIFIED
DIMENSIONS ARE IN INCHES
TOLERANCES ARE
FRACTIONS DECIMALS ANGLES
± N/A .XX = ±.13 ± N/A
DO NOT SCALE DRAWING

INTERFACE CONTROL DRAWING

(LTL-4)

THIS DRAWING IS CONFIDENTIAL AND IS THE PROPERTY OF ELLIS & WATTS. IT CONTAINS INFORMATION WHICH IS PROPRIETARY. IT SHALL NOT BE USED, DISCLOSED, DUPLICATED, REPRODUCED, OR TRANSFERRED WITHOUT PRIOR WRITTEN PERMISSION OF ELLIS & WATTS.

DWG NO. T2583-1202-01		SH 1	REV 1	1	
REVISIONS					
ZONE	LTR	DESCRIPTION	DATE (YY-MM-DD)	BY	APPROVED
A		SEE EON-T2590-55 FOR CHANGES	07-03-22	MAF	JKS 07-03-22
				RS	07-03-22



LEGEND

- F1 FUSE, 1A, 250V, SLO-BLO
FS SWITCH, FLOW, COIL COOLANT, CLOSED FOR FLOW > 1 GPM
IL LIGHT, INDICATOR, POWER (GREEN)
IS SWITCH, INTERLOCK, CABINET ACCESS
K1 CONTACTOR, PUMP MOTOR, 20A
LS SWITCH, LEVEL
OL1 OVERLOAD, MOTOR, THERMAL
P/M PUMP/MOTOR SET, 1HP
P/S PLUG/SOCKET, 3-POLE, 3-WIRE
SI SWITCH, ON/OFF
T1 TRANSFORMER, 110 VAC/24 VAC, 43 VA
TB1 TERMINAL BLOCK
TC CONTROLLER, COIL SUPPLY TEMPERATURE, 3.2 VA CONSUMPTION
TD DISPLAY, COIL SUPPLY TEMPERATURE
TDR RELAY, TIME DELAY (30 SEC)
TH THERMOSTAT, HIGH TEMPERATURE LIMIT, 100 ±7°F OPEN 80±7°F CLOSE
TS SENSOR, COIL SUPPLY TEMPERATURE, SILICON
VA ACTUATOR, 2-WAY BALL VALVE, 2VA CONSUMPTION

CONTROL LOGIC

1. TRANSDUCER (TS) SENSES ACTUAL COOLANT SUPPLY TEMPERATURE.
2. CONTROLLER (TC) COMPARES SET-POINT AND ACTUAL COOLANT SUPPLY TEMPERATURES.
3. USING PROPORTIONAL PLUS INTEGRAL LOGIC, CONTROLLER SUPPLIES 2-10 VDC SIGNAL TO ACTUATOR (VA) ON 2-WAY BALL VALVE.
4. TWO-WAY VALVE ADJUSTS TO PASS MORE CHILLED WATER THROUGH HEAT EXCHANGER, IF ACTUAL TEMPERATURE IS GREATER THAN SET-POINT TEMPERATURE AND LESS CHILLED WATER THROUGH HEAT EXCHANGER, IF ACTUAL TEMPERATURE IS LESS THAN SET-POINT TEMPERATURE.

NOTES:

- △ KNOB TO DIAL-IN SET-POINT TEMPERATURE.
△ DISPLAY OF ACTUAL TEMPERATURE.
△ PRESS AND HOLD TO DISPLAY SET-POINT TEMPERATURE.
△ MAIN TERMINAL BOARD LOCATED INSIDE CONTROLLER.
△ ELECTRICAL PIN CONNECTIONS TO DISPLAY LOCATED INSIDE CONTROLLER.
△ THIS WIRING SCHEMATIC APPLIES TO UNITS WITH S/N'S 16806 AND GREATER. SEE DRAWING T2583-1202 FOR UNITS WITH S/N'S 16805 AND LESS.

WIRE DESIGNATION

- △ 101-125 = AWG #18
△ 300-310 = AWG #12

PARTS LIST

SYM		NOMENCLATURE		CAGE CODE	IDENTIFYING NO.		MATERIAL / SPECIFICATION		UNIT	WT.	ZONE	FIND NO.
PARTS LIST												
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ARE FRACTIONS DECIMALS ANGLES .XX = N/A ± N/A .XXX = N/A ± N/A				CONTRACT NO.								
DO NOT SCALE DRAWING				DRAWN BY CMJ		DATE 99-07-13						
				CHECKER MIS 99-07-13		ENGINEER BAH 99-07-13						
				QUALITY ASSURANCE APPROVAL RGS 99-07-13								
				ENGINEERING APPROVAL KDD 99-07-13								
MATERIAL ENGR												
NEXT ASSY				LTL-4								
APPLICATION												
ELLIS & WATTS CHIONNATL, OHIO												
TITLE WIRING SCHEMATIC LTL-4												
SIZE		CAGE CODE		DWG. NO.		REV.						
B		98437		T2583-1202-01		A						
SCALE		NONE		UNIT WT.		SHEET 1 OF 1						