

VectorLab - second synthetic logsheet

SYNTHETIC TRAINING FORM - not laboratory evidence

Customer: SYNTHETIC SECOND FORM - Example Grid Labs

Sample: SYN-UNSEEN-002 Series: SYN-SERIES-002 Source page: 1

Measurement	Value	Unit
Sample code	SYN-UNSEEN-002	
Test series	SYN-SERIES-002	
HV-earth insulation resistance - before	1.27	GΩ
HV-earth insulation resistance - after	1.25	GΩ
LV-earth insulation resistance - before	1.33	GΩ
LV-earth insulation resistance - after	1.24	GΩ
HV-LV insulation resistance - before	1.31	GΩ
HV-LV insulation resistance - after	1.29	GΩ
Principal tap label	N	
Principal tap ratio - before, phase A	44.02	
Principal tap ratio - before, phase B	43.98	
Principal tap ratio - before, phase C	44.03	
Principal tap ratio - after, phase A	44.10	
Principal tap ratio - after, phase B	44.06	
Principal tap ratio - after, phase C	44.11	
Applied HV voltage - before	28	kV
Applied HV voltage - after	28	kV
Induced voltage - before	866	V
Induced voltage - after	866	V
Applied HV observation - before	No disruptive discharge, withstood	
Applied HV observation - after	No disruptive discharge, withstood	

The CSV export contains all schema fields, including this page. Values require human review in VectorLab.

This fictional form is for import and report stress testing only.