

Data acquisition system for the Glass RPC Semi Digital HCAL

Guillaume Baulieu
Christophe Combaret
Laurent Mirabito

1 The SDHCAL data acquisition software

The data acquisition software is splitted in three parts: the low level hardware access that hides effective hardware implementations, the configuration data base software handling devices description and Slow Control parameters and finally the data collection and monitoring. All packages are written in C++ with interactive scripting in python. Low level and database C++ libraries are all parsed to python object with the Swig tool. It allows an interactive instantiation and debug of single code pieces.

1.1 The low level hardware access

1.1.1 USB readout

DIF and SDCC FPGA are interfaced with the same USB chip. As mentioned before this is an FTDI chip. The DIF is thus uniquely identified by its FTDI device identifier (id) stored in an EEPROM and access to a specific device id is done using either the proprietary library FTD2XX or the free version library libFTDI. A base class called `UsbDeviceDriver` (or `FtdiDeviceDriver` if `ftdi` library is used) implements a set of low level access: bytes read or write , DIF and SDCC registers access and finally predefined commands.

1.1.2 DIF and SDCC readout

An upper layer software is dedicated to DIF configuration and DIF readout. The class called `BasicUsbDataHandler` aggregates a pointer to a `UsbDeviceDriver` and to a configuration buffer handling all DIF and the slow control parameters. Specific methods are used to implement the DIF configuration, the ASIC configurations and a single event readout to an internal buffer. Similarly, an `SDCCDataHandler` implements commands associated to the SDCC.




Figure 1: Low level software architecture

1.1.3 DIF Manager

Eventually one DIF manager class per PC is responsible of the data taking of the DIF through the USB connected to it. It handles the DIF and ASIC configuration parameters via an interface called DIFManager. This scans and detects all connected DIF, instantiates one DIFDataHandler class per detected device and distributes configuration parameters. When data taking starts, it starts a polling thread continuously reading events on all connected DIFs. Events can be directly dumped to disk in LCIO format or transfer to the central data acquisition. Figure ?? summarizes this architecture.

1.2 The configuration database

The configuration database gives the possibility to store and retrieve all parameters needed by the DAQ system. The database itself is hosted on an Oracle server at CC IN2P3 (Villeurbanne, France). To interface this SQL database with the DAQ software and to allow users to insert and query data without knowledge of SQL, a C++ library has been written. Part of the DAQ system being written in Python, we used Swig to generate a Python version of the C++ library. The system has been designed to easily allow the addition or modification of existing object parameters. It is built on 2 levels: the database itself and the C++ library.

1.2.1 Database model

The database model is conceived to deal with extendable number of ASIC. It can also handle different kinds of ASIC using different settings of parameters to take into account addition of other sub-detectors. In this model, each ASIC has a unique entry in the ASIC table, containing its type. The actual configuration parameters are contained in 2 tables : the first is ASIC_CONFIG for the parameters common to all ASIC types and the second <ASIC_TYPE>_CONFIG for the parameters specific to a given type. For instance the configuration parameters for a HARDROC ASIC will be stored in the ASIC_CONFIG table for the common part and in the HR2_CONFIG table for the HARDROC specific parameters¹. As a consequence, supporting a new type of ASIC requires only to create a new table containing the specific configuration parameters. When downloading the parameters, the system will automatically choose the accurate tables associated to the type of the concerned ASIC.

1.2.2 C++ Library

All access to the database are done through the C++ library. There are no mention of the actual configuration parameters in the library : all names of parameters are retrieved from the database itself at runtime. The methods used to set or to get parameters value in the application (API) use the parameters name as an argument (ex : setInt("B0",5) and getInt("B0")) to respectively set and retrieve the integer value of the B0 parameter). As a consequence, there is no need to modify the C++ library when modifying parameters or adding new types of objects. This will be done dynamically from the database itself. Each stored configuration is associated with a version number having the form "MajorID.MinorID". A configuration with version number 1.0 will contain all the parameters for all the DAQ objects, whereas a configuration with version number 1.1 will only contain the modifications from version 1.0. This allows a reduction in the amount of data to transfer and to store.

1.2.3 Tools

The C++ library gives a high level access to the database, providing the possibility to manipulate the concepts of ASIC, DIF or Configuration without any SQL knowledge. It allows to create/modify/upload or download a complete setup defined as follows:

1. Setup : a set of "states" (one per sub-detector)
2. State : a coherent set of "configurations"
3. Configuration : a list of basic objects
4. Basic object : a unique object with all its parameters (ASIC, DIF, DCC, ...)

¹Here label HR2 is to indicate that we are using the version 2 of the HARDROC ASIC.




Figure 2:

Figure ?? illustrates the structure of such a setup.

In the case of the SDHCAL prototype with 50 active layers, a typical setup contains a single state with 150 DIF, each having 48 ASICs connected. This corresponds to roughly 550 000 parameters. The download of such a setup takes around 5-7 seconds. In addition, the library allows to store information about a run (time, date, type, XDAQ configuration, setup used, ...). Using Swig, a Python version of the C++ library is provided. It is in fact a collection of python wrappers to the C++ functions. It gives the possibility to access the database from Python scripts and allows the usage of the python interpreter as a command line tool to manage configurations. Finally, configuration setups can be imported/exported to/from the database using XML files. These files can be used to run an acquisition without access to the database which could be useful when access to database is interrupted for some reason. Figure ?? summarizes the structure of database access using the different tools.

1.2.4 Data acquisition access

In order to minimize database access during data acquisition, a class called the DIFDBManager is responsible of the download of all the DIF and ASIC configuration parameters of a given setup and to cache it for fast access. Data are stored in indexed maps that provide an instantaneous access to the data needed by one specific DIF. Each separate DIFManager instantiates one instance of DIFDBManager and uses it as a configuration cache.




Figure 3: Scheme of the database software.

1.3 The data collection

1.3.1 Local data acquisition and coherence

In order to keep the coherence of collected data, DIF readout outputs are synchronized using the absolute Bunch Crossing ID identifier defined in section ???. This is a 48 bits 5 MHz counter that is reset when the first acquisition starts after the DIFs are powered on.

Data from different DIF may be read out at different times but will have the same absolute BCID for a given Trigger (or Ramfull) signal. The logical way to keep synchronicity is to store in a BCID indexed map the buffers of all read DIF but this requires to manage memory allocation, access and cleaning. Recent Linux kernels offer the ability to use shared memory based file, ie, /dev/shm. This special file system is directly mapped in the system memory and data can be written, listed and read with extremely fast access. Each DIF data block is written as a single file named Event_BCID_DIFID in /dev/shm and an empty file /dev/shm/closed/Event_BCID_DIFID is created once the event file is closed. Standard C functions are used to list events available, to read, write and delete data. This method allows to separate the process reading data from those making data collection, writing, debugging and monitoring in a single computer without special protocol or API to be used.

1.3.2 Global data acquisition with XDAQ

Whenever several computers are involved in the data taking, a communication framework is needed. We choose to use the CMS data acquisition XDAQ framework [?]. It provides:

- A communication with both binary and XML messages.
- An XML description of the computer and software architecture.
- A web-server implementation of all data acquisition application.
- A scalable Event builder.

Each PC handling DIFs hold a DIF manager XDAQ application obeying to a message driven state machine responsible for initialization (USB scan (section ??) and DB download), configuration (DIF and ASIC settings) and running (DIF readout and /dev/shm storage). A second application (ShmSupervisor) scans the shared memory and push completed events to the local event builder application (Readout Unit). The main advantage of the CMS event builder is the scalability. It is possible to add any number of collecting application (Builder Unit) that will merge data from all Readout Units for a given trigger. Those Builder Units distribute merged events to any analysis and data writing application (Filter Unit) declared to them. In the SDHCAL case, the computing capability is handled by the PC's reading the DIF so one Readout Unit, one Builder Unit and one Filter Unit application are created on each PC as described on Figure ?? and each Filter Unit writes the associated data in a separate stream.

1.3.3 Implementation on raspberry pi micro computers




Figure 4: SDHCAL DAQ structure