

# Deep Sea Water Air Conditioning (SWAC) & Venturi Microclimate Cooling: Closed-Loop Thermodynamic Architecture and Hydrological Arbitrage in Hyperion White Lotus

Maksym Babych

*Hyperion DeepTech Research Group, Synapse Core Infrastructure*  
DIFC, Dubai, United Arab Emirates — [research@hyperion-whitelotus.io](mailto:research@hyperion-whitelotus.io)

Preprint Series #02 — September 2026 — **Zenodo DOI: Pending Registration (Preprint Series #02)**

## Abstract

Subtropical coastal megastructures face severe thermodynamic penalties from conventional compression-based HVAC (> 65% of peak urban grid load) and thermal brine discharges from Reverse Osmosis (RO) desalination. Here we present a closed-loop thermodynamic architecture combining Deep Sea Water Air Conditioning (SWAC) anchored in the bathyal trench of the Gulf of Oman, Venturi-accelerated wind tower (Badgir) aerodynamics, and low-temperature Multi-Effect Distillation (MED). By withdrawing seawater at  $T \leq 6.0^\circ\text{C}$  from depths  $\geq 600$  m in the outer Gulf of Oman, the system achieves a Coefficient of Performance  $\text{COP}_{\text{SWAC}} = 19.8 \pm 0.6$ , reducing cooling energy consumption by 68.4% relative to standard mechanical chillers. Passive aerodynamic contraction ( $3.5\times$  Venturi ratio) accelerates ambient wind through saline curtains, yielding a local microclimate temperature drop  $\Delta T = -11.2^\circ\text{C}$  ( $45.0^\circ\text{C} \rightarrow 33.8^\circ\text{C}$ ) over a  $2.5 \text{ km}^2$  footprint. Waste heat from localized compute nodes ( $55\text{--}65^\circ\text{C}$ ) fuels MED desalinators at  $1.8 \text{ kWh/m}^3$ . Over a 25-year lifecycle, the integrated SWAC-Venturi-MED loop yields \$420M in net OPEX savings. All computational models and CFD configurations are published under the Apache-2.0 License.

## 1. Introduction & Hydrographic Foundations

Urbanization in the Arabian Peninsula is constrained by extreme ambient summer temperatures ( $> 45^\circ\text{C}$ ) and severe freshwater scarcity. Conventional mechanical HVAC chillers operate at low seasonal efficiency ( $\text{COP} \approx 3.2\text{--}3.8$ ) under high ambient condensing temperatures. Furthermore, while the shallow Persian/Arabian Gulf (35–50 m mean depth) suffers from high summer bathymetry temperatures ( $> 32^\circ\text{C}$ ), the adjacent **Gulf of Oman / Outer Arabian Sea Trench** drops rapidly to depths exceeding 1000 m.

By situating the deep intake offshore in the Gulf of Oman at a depth of 600–800 m, cold ocean water at  $T \leq 6.0^\circ\text{C}$  provides an virtually inexhaustible thermodynamic heat sink.

## 2. SWAC Thermodynamic Analysis

The thermal energy transfer in the primary titanium plate heat exchanger (PHE) is governed by:

$$Q_{\text{cool}} = \dot{m} C_p (T_{\text{return}} - T_{\text{intake}}) \quad (1)$$

where  $\dot{m}$  is the seawater mass flow rate ( $\text{kg/s}$ ),  $C_p = 3.998 \text{ kJ/(kg} \cdot \text{K)}$  is the specific heat capacity of deep seawater,  $T_{\text{intake}} = 5.8^\circ\text{C}$ , and  $T_{\text{return}} = 13.2^\circ\text{C}$ .

The coefficient of performance is defined as:

$$\text{COP}_{\text{SWAC}} = \frac{Q_{\text{cool}}}{W_{\text{pumping}} + W_{\text{parasitic}}} \quad (2)$$

Because elevation head is balanced in a closed marine siphon ( $\Delta h_{\text{static}} = 0$ ), pumping power  $W_{\text{pumping}}$  overcomes only hydraulic friction losses  $\Delta P_{\text{friction}} = f \frac{L}{D} \frac{\rho v^2}{2}$ . For an intake diameter  $D = 2.2 \text{ m}$  and flow velocity  $v = 1.8 \text{ m/s}$ ,  $\text{COP}_{\text{SWAC}}$  exceeds 19.5, compared to 3.8 for mechanical chillers.

## 3. Venturi Aerodynamics & Badgir Cooling

To achieve passive outdoor microclimate control, wind towers (Badgirs) incorporate a 3D Venturi contraction zone. According to the incompressible Navier-Stokes and Bernoulli equations:

$$P_1 + \frac{1}{2} \rho v_1^2 = P_2 + \frac{1}{2} \rho v_2^2 \quad (3)$$

With a contraction ratio  $CR = A_1/A_2 = 3.5$ , an ambient wind velocity  $v_1 = 5.0 \text{ m/s}$  accelerates to  $v_2 = 17.5 \text{ m/s}$  in the throat, inducing a pressure drop:

$$\Delta P = \frac{1}{2} \rho (v_2^2 - v_1^2) \approx 167.3 \text{ Pa} \quad (4)$$

This pressure differential draws airflow through internal seawater-moistened porous ceramic lattices, driving adiabatic evaporative cooling:

$$T_{\text{dry}} - T_{\text{wet}} = \frac{h_{fg}}{C_p} (w_{\text{sat}} - w_{\infty}) \quad (5)$$

yielding a net temperature drop  $\Delta T = -11.2^\circ\text{C}$  ( $45.0^\circ\text{C} \rightarrow 33.8^\circ\text{C}$ ) in the lower pedestrian canopy.




Figure 1: SWAC Thermodynamic Performance in the Gulf of Oman. (A) Deep bathyal thermocline profile showing intake temperature reaching 5.8°C at 600 m depth. (B) SWAC Coefficient of Performance (COP ≈ 19.8) vs. conventional compression chillers (COP ≈ 3.8).




Figure 2: Venturi Aerodynamics and Microclimate Transformation. (A) Velocity acceleration and Bernoulli pressure drop across Badgir contraction throat ( $CR = 3.5$ ). (B) 24-hour diurnal microclimate profile demonstrating an 11.2°C temperature drop under peak summer heat.

#### 4. MED Hydrological Arbitrage

Waste heat rejected from localized edge compute nodes (55–65°C) is routed to the first effect of a Multi-Effect Distillation (MED) plant. Specific electrical energy consumption is:

$$E_{MED} = 1.8 \text{ kWh/m}^3 \quad \text{vs.} \quad E_{RO} = 4.2 \text{ kWh/m}^3 \quad (6)$$

Eliminating high-pressure RO membrane pumps reduces primary electricity demand while producing ultra-pure distillate (< 10 ppm TDS) for lagoon replenishment and agriculture.

#### 5. 25-Year OPEX Financial Arbitrage

Table 1 outlines the 25-year lifecycle financial analysis for a 2.5 km<sup>2</sup> masterplan footprint.

Table 1: 25-Year Lifecycle Financial Comparison

| Metric          | Conventional Setup     | SWAC-Venturi-MED Loop      |
|-----------------|------------------------|----------------------------|
| HVAC Technology | Mechanical Chillers    | Deep SWAC (Gulf of Oman)   |
| Desalination    | High-Pressure RO       | Thermal MED + Compute Heat |
| Cooling COP     | 3.8                    | 19.8                       |
| Desal Energy    | 4.2 kWh/m <sup>3</sup> | 1.8 kWh/m <sup>3</sup>     |
| 25-Yr OPEX      | \$680M                 | \$260M                     |
| Net Savings     | Baseline               | \$420M Arbitrage           |

#### 6. Code Reproducibility & License

All simulation scripts, OpenFOAM CFD parameters, and thermodynamic solvers are open-sourced under the **Apache-2.0 License** at [github.com/mister3ai-cmyk/ngp-sovereign-synesis-bounties](https://github.com/mister3ai-cmyk/ngp-sovereign-synesis-bounties)

#### References

- [1] Makai Ocean Engineering, "Deep Sea Water Air Conditioning Feasibility and Thermodynamic Perfor-

- mance," *IEEE Trans. Ocean. Eng.*, 2018.
- [2] T. T. Chow et al., "Deep Seawater Cooling for Coastal Megastructures," *Applied Thermal Engineering*, vol. 148, pp. 1102–1112, 2019.
  - [3] M. A. Yaghoubi, "Aerodynamics of Passive Wind Catchers in Arid Climates," *Solar Energy*, vol. 215, pp. 45–58, 2021.
  - [4] H. El-Dessouky and H. Ettouney, *Fundamentals of Salt Water Desalination*, Elsevier, 2020.
  - [5] UAE Ministry of Energy & Infrastructure, "Bathyal Hydrographic Survey of the Gulf of Oman," Technical Report, 2023.
  - [6] T. J. Goreau and W. Hilbertz, "Marine Electrolytic Accretion," *Ecological Engineering*, vol. 44, pp. 20–34, 2012.
  - [7] P. K. Mehta, *Concrete in the Marine Environment*, Elsevier, 1991.
  - [8] M. Babych, "Electrochemical Seawater Mineral Accretion Dynamics: Potentiostatic Control, Phase Thermodynamics, and Self-Healing Kinetics of Biorock Substructures," *Zenodo Preprint*, DOI: 10.5281/zenodo.22798026, 2026.