


PLAN VIEW



VIEW A-A

[illegible]

"*" SUPPORT HEIGHT TO BE ADJUSTED AS PER SITE CONDITION.

NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETER.
2. FULLY INSULATED TRUNION (SUPPORT) INSULATION SHALL COVER THE ENTIRE TRUNION UP TO THE BASE PLATE A PER THE DRAWING. TRUNION AND CLOSURE PLATE SHALL HAVE THE SAME INSULATION MATERIAL AND THICKNESS OF THE RUN PIPE.
3. ALL FILLET WELDS SHALL BE GROUND TO SMOOTH CONCAVE CONTOUR.
4. SUPPORT WELDING SHALL BE IN ACCORDANCE WITH DOC. 4274-XH-SW-00000001
5. WELDED JOINTS USED FOR FABRICATION OF SUPPORT SHALL HAVE CONTINUOUS SEAM EXAMINED BY LIQUID PENETRANT TEST ON 100% OF JOINTS.
6. PIPING LONGITUDINAL WELD SHALL BE ORIENTED TO AVOID INTERFERENCE WITH SUPPORT WELDINGS.
7. THE DRAWING REVISION INDEX SHOWN IN TITLE BLOCK IS REFERRED TO THIS SUPPORTS ONLY. FOR THIS WHOLE DOCUMENT REVISION REFER TO THE COVER PAGES.

APPROVED FOR CONSTRUCTION		
Date	Initials	Signature
28-Nov-23	E.Simonito	

UNIT : 2120	LINE NO.: 12"-PE-41A01-1E64 (P)-1	
CWA : 2121	SP NO.: SP-013	SUPPORT NO.: 4249

ATTACHMENT SP-013 OF BELOW DOCUMENT

							REALIZADO <i>PREPARED</i>	28–Nov–23	M.AZHAR	ESCALA: <i>SCALE</i>	CONTRATISTA: <i>CONTRACTOR</i>
							COMPROB. <i>CHECKED</i>	28–Nov–23	H.JADHAV	1:25	4274–XH–DC–21210001
01	ISSUED FOR CONSTRUCTION	28–Nov–23	M.AZHAR	H.JADHAV	G.PAGANONI		APROBADO <i>APPROVED</i>	28–Nov–23	G.PAGANONI	TAMAÑO: <i>SIZE</i>	PROYECTO: <i>PROJECT</i>
00	ISSUED FOR CONSTRUCTION	25–May–23	M.AZHAR	H.JADHAV	G.PAGANONI					DIN–A3	4001008
REV. <i>REV.</i>	DESCRIPCIÓN <i>DESCRIPTION</i>	FECHA <i>DATE</i>	REALIZ. <i>PREP.</i>	COMPR. <i>CHCK.</i>	APROB. <i>APPROV.</i>	V'B' CLIENTE <i>CLIENT APPROVAL</i>	V'B' CLIENTE <i>CLIENT APPROVAL</i>				

TÍTULO:
TITLE:

PIPE SPECIAL SUPPORT DRAWING



NEGOCIO:
BUSINESS: REPSOL POLYMEROS

CENTRO:
FACILITY: SINES INDUSTRIAL COMPLEX

ÁREA/ANEXO: AREA/ANNEX:	CLASIF.: CLASIF.:	PLANO N°: DRAWING NUMBER:	REV.:
19	L	19-000-2-03-85121	01