
SUPPORTS LEGEND:

REV.

ISSUED FOR CONSTRUCTION

DENOTES PARTS LIST NO PIPE SUPPORT —

DESCRIPTION



A=RESTING SUPPORT G=GUIDE F=AXIAL STOP B=AXCHOR M=SPRING S=TEFLON PAD WHERE \overline{A} WITHOUT NUMBERING IS INDICATED, THIS MEANS THAT THERE IS A REST DIRECTLY ON STEEL STRUCTURE.

P.VAZE

CHECK BY

U.CHAVAN

G.PAGANONI

APPR. BY

16-DEC-22

STRESS CALC. Nº

19-A-19-000-1-01-00001 sheet 40

19-L-19-000-2-00-86196 sheet 4

19-L-19-000-2-00-80602 PIPE LAYOUT Nº

	BILL OF MATERIAL							
	PT NO COMPONENT DESCRIPTIO)N			N.S. (IN)	ITEM CODE	QTY	HOLD STATUS
	PIPE 1 PIPE - A106-B BE SMLS T01AC03V02 S-STD <pipa010b12std> (L-7806) FITTINGS 2 45 LR ELBOW ASME B16.9 A234-WPB BE SMLS C02DC04V01 S-STD <45LA200F32STD> (L-7956) 3 90 LR ELBOW ASME B16.9 A234-WPB BE SMLS C01DC04V01 S-STD <90LA200F32STD> (L-7955) PIPE SUPPORTS 4 U BOLT (FOR GUIDE)-P02D</pipa010b12std>				2	I117862	7.8 M	
					2	I210283	1	
					2	I128529	2	
						450		
	5 STOP HORIZ VERT FOR NOT INS. PIPING-N1F1				2	453 453	1 1	
	6 STANDARD GUIDE FOR NOT INS. PIPING-N1G1				2	281	1	
T								
573								
773								
			_		_			_
APPROVED FOR	PIPE MATERIAL	NOTES: 1. FOR TECHNICAL DETAILS SEE LINE LIST. 2. FOR VENT, DRAIN OR INSTRUMENT CONNECTION DET			AILS SEE 45-L-	45-000-2-00-80102.		
CONSTRUCTION	CS 3. WELDING ACCORDING TO 45-L-45-000-2-00-80021. HEAT TREATMENT (PWHT) 4. PAINTING ACCORDING TO 45-A-45-000-1-00-20160.							
	N PAINTING SCHEME (3)	5. CODE SHOWN IN BOM BETWEEN "<" & ">" DENOTES REI					VAILABLE".	
Signature for construction is shown on Iso list of relevant CWA	1 PIPING CLASS	CONTRACTO	CONTRACTOR: CONTRACTOR DRAW				400100	10
	1E21	Tecnimont 4274-XH-DL-2121E					400100	J8
ISOMETRIC DRAWING	WELDING CLASS (4)		LOW LINEAL DENSITY POLYETHILENE (PEL) AND POLYPROPYLENE (PP) PLANTS CLIENT / COMPLEX PERCOL POLYMEROS					
LINE	PED CATEGORY II	FOR PROJECT - ALBA F				-	REPSOL POLY SES INDUSTRIA	
	INSULATION CODE / THK. (mm)		SPEC.	DRAWING NUMBER 19-000-2-02-00001 s	.h 4 0 1 0)1ET40104	1	REV. 00
2"-ET-40J06-1E21	N 0	19	L	19-000-2-02-00001 s	sneet 212	ZIE140J06-	I	