SUPPORTS LEGEND:

REMARKS FOR MECHANICAL SUBCONTRACTOR:

1) LINES 1.1/2" AND SMALLER SHALL BE SUPPORTED IN FIELD IF NOT OTHERWISE INDICATED.

DESCRIPTION

6) CROSSING BETWEEN WELDS ON PIPELINE SHALL NOT BE ADMITTED.

2) ALL DIMENSION AND PROPER CONFIGURATION FOR LINES NPS 1.1/2" AND SMALLER SHALL BE CHECKED IN FIELD BEFORE CONSTRUCTION.

3) FOR THE COMPONENTS MARKED AS FIELD WELDED WITH THIS SYMBOL ✗, ONE WELD FOR ADJUSTMENT OF IN LINE COMPONENT MUST BE LEFT

9) WHERE EARTHING BONDING IS REQUIRED, MECHANICAL SUBCONTRACTOR TO PERFORM IT BASED ON DOC. 45-P-000-7-06-00902/ 4274 -NN-DW-00000002 AND ASSEMBLY NO FEA005 AND FE019.

A=RESTING SUPPORT G=GUIDE F=AYAL STOP B=ANCHOR M=SPRING S=TEFLON PAD WHERE  $\Delta$  WITHOUT NUMBERING IS INDICATED, THIS MEANS THAT THERE IS A REST DIRECTLY ON STEEL STRUCTURE.

CHECK BY

APPR. BY

DRW. BY

TRESS CALC. Nº

PIPE LAYOUT Nº

APPR. CLIENT

19-A-19-000-1-01-00001 sheet 117

19-L-19-000-2-00-86197 sheet 5

19-L-19-000-2-00-80602

4) FOR EXTRA PIPE LENGTH REFER TO 4274-LZ-PC-00000603.
5) GUSSETING TO BE IMPLEMENTED BY MECHANICAL SUBCONTRACTOR AS PER 45-L-45-000-2-00-80004 / 4274-XH-SG-00000002.

DENOTES PARTS LIST NO PIPE SUPPORT —

() CROSSING BETWEEN WEEDS ON THE ELING STALE NOT BE ADMITTED.

7) IN CASE OF DISCREPANCIES BETWEEN DATA SHOWN ON ISO AND IN LINE LIST (AS APPLICABLE, DATA SHOWN IN LINE LIST GOVERN.

8) ACTUAL CUT LENGTH OF PIPE AND FIELD WELDS SHALL BE DEFINED BY MECHANICAL SUBCONTRACTOR (REF.TO 4274-LZ-PC-00000603

SEE ISO 2121-LS91A05-1 SPEC B-5 E 139521732 N 113394135 10 STEM SOUTH HA - THK 40 mm INSUL: HA - THK 50 mn N 113393973 EL +17268 7 45.0° 11 STEM SOUTH \ N 113394071

BILL OF MATERIAL HOLD COMPONENT DESCRIPTION STATUS ITEM CODE QTY (IN) PIPE - A106-B PE SMLS T01AC03Z02 S-XS < PIPA010A11XS > (L-6679) I132793 2.4 M PIPE - A106-B PE SMLS T01AC03Z02 S-XS < PIPA010A13/4XS> (L-6679) I132785 0.3 M REDUCING TEE ASME B16.11 3000# A105N SWE SWE - R12FNC441101 NREQD 1X3/4 I1651305 <RTEA300KBK13/4> (L-RTE15) 45 ELBOW ASME B16.11 3000# A105N SWE SWE - R32FNC441101 NREQD I1651292 <45FA300LBK1> (L-184) NIPPLE - - A106-B PE MTE SMLS LENGTH 100mm R03AQC03ZW04 S-160 I2221187 <NTOA010E1120324> (L-7881) SPECIALTY COMPONENT SP-04-291A0-13 1 45 ELBOW ASME B16.11 3000# A105N SWE SWE - R32FNC441101 NREOD 11651294 <45FA300LBK3/4> (L-184) NIPPLE - - A106-B PE MTE SMLS LENGTH 100mm R03AQC03ZW04 S-160 I2221177 <NTOA010E1110324> (L-7881) CAP ASME B16.11 3000# A105N FTE NREQD - R41FNC442001 NREQD <CATA300KBK3/4> 3/4 I1651686 (L-79) 10 GLOBE VALVE API 602 800# A105N SWE SWE 5-HARDFACED API 602 B7/2H BB-OS&Y I11426473 API 602 HW V02GIC441162 NREQD < A61L-296> (L-296) GATE VALVE API 602 800# A105N SWE SWE 5-HARDFACED API 602 B7/2H BB-OS&Y SOW  $\,$  3/4  $\,$ I11426464 API 602 HW V01GIC441111 NREQD < G63\_4L-6566> (L-6566)

ISSUED FOR REFERENCE	PIPE MATERIAL  CS  HEAT TREATMENT (PWHT)
Signature for construction is shown on Iso list of relevant CWA	PAINTING SCHEME (3)  2 PIPING CLASS
ISOMETRIC DRAWING LINE	WELDING CLASS (4)  PED CATEGORY

1"-LS-91A36-B-5 (HA)

CONTRACTOR:

HA

NOTES: 1. FOR TECHNICAL DETAILS SEE LINE LIST. 2. FOR VENT, DRAIN OR INSTRUMENT CONNECTION DETAILS SEE 45-L-45-000-2-00-80102

3. WELDING ACCORDING TO 45-L-45-000-2-00-80021

5. CODE SHOWN IN BOM BETWEEN "<" & ">" DENOTES REPSOL UNICODE. "<N/A>" MEANS UNICODE IS "NOT AVAILABLE"

CONTRACTOR DRAWING NUMBER: PROJECT:

4274-XH-DL-2121LS91A36-2

LOW LINEAL DENSITY POLYETHILENE (PEL) AND POLYPROPYLENE (PP) PLANTS FOR PROJECT - ALBA PROJECT

CLIENT / COMPLEX REPSOL POLYMEROS/ SINES INDUSTRIAL COMPLEX

4001008

00

Art 4.3 REPSQL INSULATION CODE / THK. (mm) DRAWING NUMBER ANNEX 19-000-2-02-00001 sheet 2121LS91A36-2