





:ONG								REALIZADO <i>PREPARED</i>	28-Nov-23	M.AZHAR	ESCALA: SCALE:	CONTRATISTA: CONTRACTOR:
BEI								COMPROB.	28-Nov-23	II IADIIAV	1:25	4274-XH-DC-21210001
EN7	01	ISSUED FOR CONSTRUCTION	28-Nov-23	M.AZHAR	H.JADHAV	G.PAGANONI		CHECKED				127 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7
CUM,	00	ISSUED FOR CONSTRUCTION	25-May-23	M.AZHAR	H.JADHAV	G.PAGANONI		APROBADO <i>APPROVED</i>	25-May-23	G.PAGANONI	TAMAÑO: <i>SIZE:</i>	PROYECTO: PROJECT:
THIS DR	REV.	DESCRIPCIÓN <i>DESCRIPTION</i>	FECHA <i>DATE</i>	REALIZ. <i>PREP.</i>	COMPR. <i>CHCK.</i>	APROB. APPROV.	V°B° CLIENTE CLIENT APPROVAL	V'B' CLIENTE CLIENT APPROVAL			DIN-A3	4001008

PIPE SPECIAL SUPPORT DRAWING

	BILL OF MATERIAL		
SR.NO.	DESCRIPTION	QTY.	WIEGHT (Kg.)
1	SPRING, BY VENDOR	1	-
2	PLATE (100*88*10)	1	0.69
3	BE03 (HEA 100)	1	4.8
			·

"*" SUPPORT HEIGHT TO BE ADJUSTED AS PER SITE CONDITION.

NOTES:

- 1. ALL DIMENSIONS ARE IN MILLIMETER.
- 2. FULLY INSULATED TRUNION (SUPPORT) INSULATION SHALL COVER THE ENTIRE TRUNION UP TO THE BASE PLATE A PER THE DRAWING. TRUNION AND CLOSURE PLATE SHALL HAVE THE SAME INSULATION MATERIAL AND THICKNESS OF THE RUN PIPE.
- 3. ALL FILLET WELDS SHALL BE GROUND TO SMOOTH CONCAVE CONTOUR.
- 4. SUPPORT WELDING SHALL BE IN ACCORDANCE WITH DOC. 4274-XH-SW-0000001
- 5. WELDED JOINTS USED FOR FABRICATION OF SUPPORT SHALL HAVE CONTINUOUS SEAM EXAMINED BY LIQUID PENETRANT TEST ON 100% OF JOINTS.
- 6. PIPING LONGITUDINAL WELD SHALL BE ORIENTED TO AVOID INTERFERENCE WITH SUPPORT WELDINGS.
- 7. THE DRAWING REVISION INDEX SHOWN IN TITLE BLOCK IS REFERRED TO THIS SUPPORTS ONLY. FOR THIS WHOLE DOCUMENT REVISION REFER TO THE COVER PAGES.

APPROVED FOR CONSTRUCTION							
Date	Initials	Signature					
28-Nov-23	E.Simonito						

LINE NO.: 3"-FL-41C01-B32S1(P) UNIT: 2120 CWA: 2121 SP NO.: SP-026 SUPPORT NO.: 5187

ATTACHMENT SP-026 OF BELOW DOCUMENT



19

NEGOCIO: Business: Repsol Polymeros SINES INDUSTRIAL COMPLEX

19-000-2-03-85121

4274-XH-DC-21210001-SP-026.dwg